



Sydney
 1/9-11 Gallipoli St
 St Marys NSW 2760
 Ph: 02 9673 1111
 Fax: 02 9673 1311

Darwin
 GPO Box 208
 Darwin NT 0820
 Ph: 08 8942 1115
 Fax: 08 8942 1182

ABN: 52 116 520 097
 E-mail: admin@apollofire.com.au

ANNUAL/SUPPLEMENTARY FIRE SAFETY STATEMENT

(Under Part 9 of the Environmental Planning and Assessment Regulation 2000)

Address of Building: 2 – 10 Gallipoli Street St Marys NSW 2760

Owner's/Agent Name: Davis Property Consulting Pty Ltd

Owner's / Agent Address: Strata Plan 71778 C/- Davis Property Consulting Pty Ltd
 P.O Box 6328 Alexandria NSW 2015

Date of Assessment: 12th January 2016

List of Essential Fire Safety Measures

| Measures | Standard of Performance |
|-----------------------------|-------------------------------------|
| Fire Hose Reel System | AS2441 / BCA 2006 Part E1.4 |
| Portable fire extinguishers | AS2444 / BCA Part E1.6 |
| Fire Doors | AS/NZS 1905.1 – 2005 BCA C3.11 C3.8 |
| Light Weight Construction | AS1530.1 2005 – BCA C1.8 |
| Exit Signs | AS2293.1 2005 - BCA E4.5 |
| Emergency Lighting | AS2293.1 2005 – BCA E4.2 |



I, **Michiel Aspland of Apollo Fire Maintenance Services Pty Limited** certify that:

- (a) Each essential fire safety measure specified in this statement has been assessed by a properly qualified person and was found, when it was assessed, to be capable of performing:
 - (i) in the case of an essential fire safety measure applicable by virtue of a fire safety schedule, to a standard no less than that specified in the schedule, or
 - (ii) in the case of an essential fire safety measure applicable otherwise than by virtue of a fire safety schedule, to a standard no less than that to which the measure was originally designed and implemented, and
- (b) that a properly qualified person (whether the person referred to in paragraph (a) or another person) has inspected the building and has certified that, as at the date of the inspection, the condition of the building did not disclose any grounds for a prosecution under Division 7 of the *Environmental Planning and Assessment Regulation 2000*, and
- (c) The information contained in this certificate is, to the best of my knowledge and belief, true and accurate.

Date:- **12th January 2016**

Signed:-

Notes:

- ★ *A copy of this certificate together with the relevant fire safety schedule must be forwarded to the council and the Commissioner of the New South Wales Fire Brigades*
- ★ *A copy of this certificate together with the relevant fire safety schedule must be predominantly displayed in the building.*