THE EXTINGUISHER GUY

Phone: 02 4243 7509 - PO Box 290 Shellharbour City Centre, NSW, 2533

SUPPLEMENTARY FIRE SAFETY STATEMENT

Certificate for Whole Building

I, Barry Hayward, acting as representative for The Extinguisher Guy act as an agent for:

Premises Description: Circus tent
Address: Northcliffe Road, Warrawong, NSW, 2505

hereby certify that each essential fire safety measure specified in this statement has been assessed by a properly qualified person and was found, when assessed, to be capable of performing:

I. In the case of an essential fire safety measure applicable by virtue of a fire safety schedule, to a standard no less than specified in the schedule, or

II. In the case of an essential fire safety measure applicable otherwise than by virtue of a fire safety schedule, to a standard no less than to which the measure was originally designed or implemented, and

III. That a properly qualified person has inspected the building and has certified that, when it was inspected, that no fire safety offences under the Environmental Planning and Assessment Regulation 2000 in relation to the fire safety notices, fire exits and paths of travel to fire exits has been committed; and

IV. The information contained in this certificate is, to the best of my knowledge and belief, true and accurate

ESSENTIAL SERVCE	DATE OF INSPECTION	STANDARD OF PERFORMANCE	BCA REFERENCE	INSPECTED BY	W!S SERVICE MAINTAINED TO RELEVANT STANDARD	
					YES	NO
Portable Fire Extinguishers	25/03/18	AS 2444-2001	EI.6	Barry	✓	
Fire Blanket	25/03/18	: AS 2444-2001	-	Barry	✓	

Signature of Agent: _____ Print: Barry Hayward Date: 25 March 2018

Signature of Owner/Strata Manager: _____ Print:___ Date:

_____Seal if applicable: _____

- A copy of this certificate together with the relevant fire safety schedule must be forwarded to NSW Fire & Rescue
- A copy of this certificate should be prominently displayed in the building
- A copy of this certificate should be retained as Company Records