



Inhouse Consulting Engineers Pty Ltd

ABN: 44 066 587 719

216 Great Western Hwy, Kingswood

P.O. BOX 752 Kingswood NSW 2747

TEL: 02 4721 0044

FAX: 02 4721 1955

info@inhouseengineers.com.au

www.inhouseengineers.com.au

INSPECTION CERTIFICATE

REQUEST DETAILS

Instructed by LUKE of GW LANDSCAPES Ph. 0415 066 514.

Project: CADDENS KNOW
.....

Item to be Inspected: STAIR TYPE A
.....

Job No./Drawing No. 15500 Time 8AM Date 1-12-14

INSPECTION RESULT

Time 1:00 Date Inspected by

Site Instructions issued to: Results to:

Stair Type A - (North)

2 Flights of stairs including landings

From Bottom set

- Reinforcement good

- Good cover to reinforcement

- Extra reo char. installed to lift reo
in base

OK to pour



Inhouse Consulting Engineers Pty Ltd

ABN: 44 066 587 719

216 Great Western Hwy, Kingswood

P.O. BOX 752 Kingswood NSW 2747

TEL: 02 4721 0044

FAX: 02 4721 1955

info@inhouseengineers.com.au

www.inhouseengineers.com.au

INSPECTION CERTIFICATE

REQUEST DETAILS

Instructed by Luke of G.W. Landscapes Ph. 0415 066 514

Project: Caddens Knoll

Item to be Inspected: Stair Type A

Job No./Drawing No. 15500 Time 4:00 Date 11/12/2014

INSPECTION RESULT

Time 10:45 Date 12/12/2014 Inspected by Michael

Site Instructions issued to: Results to: Luke

Stair type A - (North)

2 Flights of stairs including landing

Top set of stairs

- Reinforcement good

- Formwork good

- Ensure water is pumped out before pour

OK to pour