

PENRITH CITY COUNCIL

FAST TRACK ASSESSMENT REPORT

Application number:	DA13/0738
Proposed development:	Residential-Single New Dwelling with Attached Garage
Property address:	30 Ghera Road, CADDENS NSW 2747
Property description:	Lot 18 DP 1166546
Date received:	23 July 2013
Assessing officer	Rebecca Larcombe
Zoning:	ZONE R1 GENERAL RESIDENTIAL LEP 2009 (CADDENS)
Class of building:	Class 1A
Recommendations:	Approve

Executive Summary

Council is in receipt of a development application for the subject development on the subject site and the proposal is a permissible land use with Council consent.

Site & Surrounds

The subject site is situated on the Ghera Road Caddens. It is 400m² in area, is orientated in a east direction and has is relatively flat. An inspection of the site was undertaken on 29 July 2013 and the site is currently vacant.

The surrounding area is characterised by residential development. The adjoining lots to the south is constructed to frame stage and the lot to the north is constructed to slab stage.

Proposal

The proposed development involves:

- Construction of single new dwelling including parking, landscaping and associated drainage works
- The application is accompanied by building and siting plans, BASIX certificate, Statement of Environmental Effects, Waste Management Plan and a Landscape Plan.

Plans that apply

- Penrith Local Environmental Plan 2009 (Caddens)
- Development Control Plan 2006
- Sydney Regional Environmental Plan No.20 - Hawkesbury Nepean River

Planning Assessment

• Section 79C - Evaluation

The development has been assessed in accordance with the matters for consideration under Section 79C of

the Environmental Planning and Assessment Act 1979, and having regard to those matters, the following issues have been identified for further consideration:

(a) (i) The provisions of any environmental planning instrument

A dwelling is permissible in this zoning and satisfies the objectives and provisions of the LEP.

(ii) The provisions of any draft environmental planning instrument

The proposed dwelling is consistent with objectives and provisions of relevant draft development control plan/s.

(iii) Any development control plan

The proposed dwelling is consistent with the provisions of the relevant development control plan.

(b) The likely impacts of the development

(i) Context and Setting (environmental impacts and impacts on built environment)

The proposed dwelling is consistent with the bulk, scale, colour and design of other development in the locality.

The proposed dwelling will have only minor impact on the amenity of the area and the streetscape.

The proposed dwelling is compatible with the surrounding and adjacent land uses.

It is considered the proposed dwelling will have minimal impact on the amenity of the area in terms of Sunlight Access (overshadowing) / visual and acoustic privacy / views or vistas.

The proposed dwelling will have no impacts on natural environment.

(ii) Access and transport

The proposed dwelling will have no or minimal impact on the local road system.

The proposed access arrangements and car parking on site will be adequate for the development.

(iii) Heritage

The property is not subject to any Heritage Order or identified as a heritage item under a planning instrument.

(iv) Soil

The proposed dwelling will have no impact on soil erosion and sedimentation:

Adequate sedimentation and erosion controls are proposed as part of the development.

(v) Natural and Technological Hazards

The development is not subject to flooding, subsidence or slip.

(vi) Site Design

The proposed dwelling is sensitive to environmental conditions and site attributes:

The proposed dwelling safeguards the health and safety of the occupants:

(c) The suitability of the site for development

A site inspection was carried out and the proposed dwelling fits the locality:

The site attributes are conducive to the development.

(d) Compliance with the BCA

The proposed dwelling will comply with the provisions of the Building Code of Australia.

The proposed dwelling is supported as it is demonstrated that it will comply with the performance requirements of the BCA.

(e) Any submissions made in accordance with the EPA Act and Regs

The proposed dwelling was not required to be publicly notified

(f) The public interest

The proposed dwelling will not generate any significant issues of public interest:

Conclusion

- Stormwater is to be connected to the Council's stormwater system.
- Cut and fill amounts are minimal.
- There will be minimal impact in regards to overshadowing. It is considered the requirements and objectives of the Solar Planning requirements in Section 5.5 of the Residential Lands DCP 2000 have been achieved.
- It is considered that the dwelling will have minimal impact on neighbouring properties and the environment.
- A BASIX certificate has been provided and commitments have been listed on the plans.
- The size, bulk and scale of the dwelling is consistent with surrounding development.
- The height will not impact on adjoining properties.
- The dwelling materials and colours are to compliment the existing surrounding developments.

Section 79C(1)(a)(i) The provisions of any environmental planning instrument

Penrith Local Environmental Plan 2009 (Caddens)

Provision	Compliance
Detailed Assessment - Appendix - Variation to Development Standard (This text will show in Appendix of your report)	
Schedule 1 Additional permitted uses	Complies
	FT - LEP 150 - Clause 10 - Objectives of the zone
Clause 1.2 Aims of Plan	Complies
Clause 2.2 Zoning of land to which Plan applies	Complies
Clause 2.3 Zone of objectives and land use table	Complies
Clause 2.5 Additional permitted uses for particular land	Complies
Clause 2.6 Subdivision - consent requirements	Complies
Clause 2.6A Demolition requires consent	Complies
Clause 2.6B Temporary use of land	Complies
Clause 4.1 Minimum subdivision lot size	Complies
Clause 4.3 Height of buildings	Complies
Clause 4.6 Exceptions to development standards	Complies
Clause 5.1 Relevant acquisition authority	Complies
Clause 5.10 Heritage conservation	Complies
Clause 5.11 Bush fire hazard reduction	Complies
Clause 5.12 Infrastructure development and use of existing buildings of the Crown	Complies
Clause 5.2 Classification and reclassification of public land	Complies
Clause 5.3 Development near zone boundaries	Complies
Clause 5.4 Controls relating to miscellaneous permissible uses	Complies
Clause 5.8 Conversion of fire alarms	Complies
Clause 5.9 Preservation of trees or vegetation	Complies
Clause 6.1 Arrangements for designated State public infrastructure	Complies
Clause 6.2 Public utility infrastructure	Complies
Clause 6.3 Development control plan	Complies
Clause 6.4 Relationship between Part and remainder of Plan	Complies
Clause 7.1 Sustainable development	Complies
Clause 7.2 Flood planning land	Complies
Clause 7.3 Zone B2 Local Cetre - floor area restrictions	Complies
Clause 7.4 Exhibition homes limited to 2 years	Complies

Sydney Regional Environmental Plan No.20 - Hawkesbury Nepean River
Please correct the following sentence to reflect your assessment of this policy:

As assessment has been undertaken of the application against relevant criteria with Sydney Regional Environmental Plan No 20—Hawkesbury-Nepean River (No 2—1997) and the application is satisfactory.

Section 79C(1)(a)(iii) The provisions of any development control plan

Development Control Plan 2006

Provision	Compliance
Chapter 6 - Area or site with specific controls	Complies - see Appendix - Development Control Plan Compliance

Referrals

The application was referred to the following stakeholders and their comments have formed part of the assessment:

Referral Body	Comments Received

Conclusion

In assessing this application against the relevant environmental planning policies being LEP 1998 (Urban Lands) and DCP 2006 (Caddens), the proposal satisfies the aims, objectives and provisions of these policies.

In its current form, the proposal will have a positive impact on the surrounding character of the area as a recent residential subdivision. Support for this application would set a favourable standard given it demonstrates compliance with all the applicable policies. The proposed design is site responsive, complies with key development standards and is in the public interest.

The site is suitable for the proposed development and there is unlikely to be negative impacts arising from the proposed development.

Therefore, the application is worthy of support, subject to recommended conditions.

Recommendation

1. That DA13/0738 for a single new dwelling at Lot 18 DP 1166546 30 Ghera Road Caddens, be approved subject to the attached conditions (Development Assessment Report Part B)

CONDITIONS

General

1 A001 - Approved plans that are architecturally drawn

The development must be implemented substantially in accordance with the plans numbered J002705 DRWG NO: 1 to 10 Issue C, drawn by Rawson Homes and dated 08.08.13 and stamped approved by Council, the application form, the BASIX Certificate and any supporting information received with the application, except as may be amended in red on the attached plans and by the following conditions.

2 A008 - Works to BCA requirements (Always apply to building works)

The work must be carried out in accordance with the requirements of the Building Code of Australia. If the work relates to a residential building and is valued in excess of \$20,000, then a contract of insurance for the residential development shall be in force in accordance with Part 6 of the Home Building Act 1989.

{Note: Residential building includes alterations and additions to a dwelling, and structures associated with a dwelling house/dwelling such as carport, garage, shed, rural shed, swimming pool and the like}.

3 A019 - OCCUPATION CERTIFICATE (ALWAYS APPLY)

The development shall not be used or occupied until an Occupation Certificate has been issued.

4 A046 - Obtain Construction Certificate before commencement of works

A **Construction Certificate** shall be obtained prior to commencement of any building works.

Environmental Matters

5 D001 - Implement approved sediment& erosion control measures

The approved sediment and erosion control measures are to be installed **prior to and maintained throughout the construction phase of the development until the landscaping, driveway and on-site parking areas have been completed for the development.** These measures shall ensure that mud and soil from vehicular movements to and from the site does not occur during the construction of the development.

6 D007 - Cut and fill of land requiring Validation Certificate –limited to footprint

Cut and fill operations on the property are only permitted in conjunction with the building works as detailed on the approved plans and specifications, and shall not extend more than 2 metres past the defined building footprint.

Before any fill material is imported to site, a validation certificate issued by an appropriately qualified person is to be provided to the Principal Certifying Authority. The validation certificate must demonstrate that the fill material is free from contaminants and weeds, that it is suitable for its intended purpose and land use, and that it will not pose an unacceptable risk to human health or the environment.

If Penrith City Council is not the Principal Certifying Authority, a copy of the validation certificate is to be submitted to Council for their reference.

{Note: Penrith Contaminated Land Development Control Plan defines an appropriately qualified person as "a person who, in the opinion of Council, has a demonstrated experience, or access to experience in hydrology, environmental chemistry, soils science, eco-toxicology, sampling and analytical procedures, risk evaluation and remediation technologies. In addition, the person will be required to have appropriate professional indemnity and public risk insurance."}

7 D009 - Covering of waste storage area

All waste materials stored on-site are to be contained within a designated area such as a waste bay or bin to ensure that no waste materials are allowed to enter the stormwater system or neighbouring properties. The designated waste storage area shall provide at least two waste bays / bins so as to allow for the separation of wastes, and are to be fully enclosed when the site is unattended.

8 D010 – Appropriate disposal of excavated or other waste

All excavated material and other wastes generated as a result of the development are to be re-used, recycled or disposed of in accordance with the approved waste management plan.

Waste materials not specified in the approved waste management plan are to be disposed of at a lawful waste management facility. Where the disposal location or waste materials have not been identified in the waste management plan, details shall be provided to the Certifying Authority as part of the waste management documentation accompanying the Construction Certificate application.

All receipts and supporting documentation must be retained in order to verify lawful disposal of materials and are to be made available to Penrith City Council on request.

BCA Issues

9 E001 - BCA compliance

All aspects of the building design shall comply with the applicable performance requirements of the Building Code of Australia so as to achieve and maintain acceptable standards of structural sufficiency, safety (including fire safety), health and amenity for the on-going benefit of the community. Compliance with the performance requirements can only be achieved by:

- (a) complying with the deemed to satisfy provisions, or
- (b) formulating an alternative solution which:
 - complies with the performance requirements, or
 - is shown to be at least equivalent to the deemed to satisfy provision, or
- (c) a combination of (a) and (b).

Health Matters and OSSM installations

10 F006 - Water tank & nuisance

The rainwater tank must be maintained so as not to create a nuisance and it must be protected against mosquito infestation.

Construction

11 H001 - Stamped plans and erection of site notice

Stamped plans, specifications, a copy of the development consent, the Construction Certificate and any other Certificates to be relied upon shall be available on site at all times during construction.

The following details are to be displayed in a maximum of 2 signs to be erected on the site:

- the name of the Principal Certifying Authority, their address and telephone number,
- the name of the person in charge of the work site and telephone number at which that person may be contacted during work hours,
- that unauthorised entry to the work site is prohibited,
- the designated waste storage area must be covered when the site is unattended, and
- all sediment and erosion control measures shall be fully maintained until completion of the construction phase.

Signage but no more than 2 signs stating the above details is to be erected:

- at the commencement of, and for the full length of the, construction works onsite, and
- in a prominent position on the work site and in a manner that can be easily read by pedestrian traffic.

All construction signage is to be removed when the Occupation Certificate has been issued for the development.

12 H002 - All forms of construction

Prior to the commencement of construction works:

(a) Toilet facilities at or in the vicinity of the work site shall be provided at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:

- a standard flushing toilet connected to a public sewer, or
- if that is not practicable, an accredited sewage management facility approved by the council, or
- alternatively, any other sewage management facility approved by council.

(b) All excavations and backfilling associated with the erection or demolition of a building must be executed safely and in accordance with the appropriate professional standards. All excavations associated with the erection or demolition of a building must be properly guarded and protected to prevent them from being dangerous to life or property.

(c) If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation to be made:

- must preserve and protect the building from damage, and
- if necessary, must underpin and support the building in an approved manner, and
- must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished. The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this condition, whether carried out on the allotment of land being excavated or on the adjoining allotment of land, (includes a public road and any other public place).

13 H009 - Cut / fill details

Cut and fill is limited to a maximum of 1 metre, in accordance with Penrith Residential Construction Works Development Control Plan.

14 H022 - Survey

The building shall be set out by a registered surveyor. A Survey Certificate shall be undertaken and submitted to the Principal Certifying Authority when the building is constructed to ground floor slab level and at frame stage with eaves and gutters installed.

15 H030 – Roof finishes (rural property)

The external finishes of the dwelling are to be in accordance with the approved colour schedule.

16 H036 - Rainwater Tank (Also impose H037, H038, H039, G005 & Q010)

The rainwater tank(s) is to be:

- erected on a self-supporting base in the approved location on the property in accordance with the stamped-approved site plans for the development,
- structurally sound and constructed in accordance with AS/NZS 3500 1.2- 1998: National Plumbing and Drainage - Water Supply - Acceptable Solutions,
- fully enclosed and all openings sealed to prevent access by mosquitoes,
- fitted with a first flush device,
- fitted with a trickle system to top up from mains water,
- provided with an air gap, and
- installed by a licensed plumber in accordance with Sydney Water's "Plumbing requirements Information for rainwater tank suppliers and plumbers April 2003" and the NSW Code of Practice: Plumbing and Drainage.

Additionally, the following are to be provided:

- A back flow prevention device shall be provided at the water meter in accordance with Sydney Water requirements.
- In the event of a power failure, a back up supply of mains water shall be provided to at least one toilet in the dwelling.
- The rainwater tank(s) and associated piping is to be labelled 'Rainwater - Not for Drinking' in accordance with Sydney Water requirements.
- The rainwater tank and pipework is to be painted in colours matching the external finishes of the dwelling and is to be of non-reflective finish.
- The overflow for the rainwater tank is to be connected into the existing stormwater disposal system on the site.

Before a rainwater tank(s) can be used, a certificate or suitable document is to be submitted to the Principal Certifying Authority stating that the rainwater tank has been installed in accordance with:

- the manufacturer's specifications, and
- Sydney Water and NSW Health requirements

This certificate or documentation is to be provided by the licensed plumber who installed the rainwater tank on the property, and is to be submitted prior to the issue of the Occupation Certificate.

17 H037 - Safe supply of water from catchment areas (Also impose H036, H038 & H039)

The catchment area (for the rainwater tank) includes the parts of the roof of the dwelling(s) from which water is collected and includes gutters. To ensure a safe supply of water:

- roof catchment areas must be kept clear of overhanging vegetation,
- gutters must have sufficient fall to downpipes to prevent pooling of water,
- overflow, discharge from bleed off pipes from roof mounted appliances such as airconditioners, hot water services and solar heaters must not discharge into the rainwater catchment area,
- for roofs containing lead based, tar based or asbestos material the tank supply must not be connected to drinking, bathing and gardening tap water outlets,
- appropriate measures must be installed to prevent foreign materials from contaminating the water which enters the rainwater tank.

18 H038 - Connection of rainwater tank supply (Also impose H036, H037 & H039)

The rainwater tank supply must not be connected to drinking and bathing water tap outlets.

19 H039 - Rainwater tank pumps (Also impose H036, H037 & H038)

The pump must not exceed 5dBA above ambient background noise level at the nearest residential property boundary. The provisions of the Protection of the Environment Operations Act 1997 apply to the development, in terms of regulating offensive noise.

20 [H041 - Hours of work \(other devt\)](#)

Construction works or subdivision works that are carried out in accordance with an approved consent that involve the use of heavy vehicles, heavy machinery and other equipment likely to cause offence to adjoining properties shall be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm (if inaudible on neighbouring residential premises), otherwise 8am to 1pm
- No work is permitted on Sundays and Public Holidays.

Other construction works carried out inside a building/tenancy and do not involve the use of equipment that emits noise are not restricted to the construction hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

Engineering

21 [K016 - Stormwater](#)

Roofwater drains shall be discharged into the street gutter or common line.

22 [K026 - Stabilised access](#)

All land required for vehicular access within the site is to be stabilised.

23 [K041](#)

An Infrastructure Restoration Bond is to be lodged with Penrith City Council for development involving works around Council's Public Infrastructure Assets. The bond is to be lodged with Council prior to the issue of a Construction Certificate. The bond is based upon the estimated value of the works with a bond of \$500 payable for the subject development.

The bond is refundable once a final inspection has been carried out by Council's Works Department and the works have been completed to Council's satisfaction. The bond may be used to repair or reinstate any damage that occurs to Council's Public Infrastructure Assets as a result of the development works. Contact Council's City Works Department on 4732 7777 or visit website to obtain the form and request for final inspection.

24 [K202 - Roads Act \(Minor Roadworks\)](#)

Prior to the issue of a Construction Certificate a Roads Act application, including payment of application and inspection fees shall be lodged with Penrith City Council, as the Roads Authority, for the following works:

- a) Provision of a vehicular crossing/s.
- b) Opening the road reserve for the provision of services including stormwater.
- c) Placing of hoardings, containers, waste skips, etc. in the road reserve.

All works within the road reserve shall be carried out in accordance with Penrith City Council's Design Guidelines and Construction Specification for Civil Works.

Penrith City Council (being the Roads Authority under the Roads Act) shall approve the works completed on or over the road reserve. Contact Council's **City Works Department** on (02) 4732 7777 to arrange an inspection of the works (and payment of inspection fees, if required).

25 [K501 Roads Authority clearance](#)

Prior to the issue of an Occupation Certificate, the Principal Certifying Authority shall ensure that all works within the road reserve have been inspected and approved by Penrith City Council.

26 [K Special \(BLANK\)](#)

Prior to the issue of a Construction Certificate the a Stormwater Management Plan is to be submitted to include subsoil drains around the perimeter of residences and connected to the stormwater system as per the Penrith Development Control Plan 2006 (6.21 Caddens).

Landscaping

27 [L008 - Tree Preservation Order](#)

No trees are to be removed, ringbarked, cut, topped or lopped or wilfully destroyed other than those within 3 metres of the proposed building footprint or as shown on the approved plans without the prior consent of Penrith City Council and in accordance with Council's Tree Preservation Order and Policy.

28 [L Special \(BLANK\)](#)

Vehicle crossover to be in plain grey concrete and existing footpaths to remain insitu.

Payment of Fees

29 P002 - Fees associated with Council land (Applies to all works & add K019)

Prior to the commencement of any works on site, all fees associated with Penrith City Council-owned land and infrastructure shall be paid to Council. These fees include Road Opening fees and Infrastructure Restoration fees.

Certification

30 Q01F - Notice of Commencement & Appointment of PCA2 (use for Fast Light only)

Prior to the commencement of any earthworks or construction works on site, the proponent is to:

- (a) employ a Principal Certifying Authority to oversee that the said works carried out on the site are in accordance with the development consent and related Construction Certificate issued for the approved development, and with the relevant provisions of the Environmental Planning and Assessment Act and accompanying Regulation, and
- (b) submit a Notice of Commencement to Penrith City Council.

The Principal Certifying Authority shall submit to Council an “Appointment of Principal Certifying Authority” in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

Information to accompany the Notice of Commencement

Two (2) days before any earthworks or construction/demolition works are to commence on site (including the clearing site vegetation), the proponent shall submit a “Notice of Commencement” to Council in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

31 Q05F - Occupation Certificate for Class10

An Occupation Certificate is to be obtained from the Principal Certifying Authority on completion of all works and prior to the occupation/use of the dwelling.

The Certificate shall not be issued if any conditions of this consent, but not the conditions relating to the operation of the development, are outstanding.

A copy of the Occupation Certificate and all necessary documentation supporting the issue of the Certificate is to be submitted to Penrith City Council, if Council is not the Principal Certifying Authority.

Appendix - Development Control Plan Compliance

Development Control Plan 2006

Part 6 - Site and area specific controls

The proposed dwelling is consistent with the provisions of the relevant development control plan/s.

4.2	Streetscape, Feature Elements and Roof Design	Complies Y/N	Comments
4.2.1	The primary street facade must incorporate an entry feature/portico and two other design features eg balcony to any first floor element; a variation in scale to adjoining properties; architectural elements which recess or project by at least 600mm; open verandah; mix of building materials or finishes; bay windows or similar features; pergola or similar feature above garage doors	Y	
4.2.2	The secondary street facade on a dwelling on a corner lot must incorporate a window from a habitable room and at least two other design features eg verandah; vertical architectural elements to reduce the horizontal emphasis of the façade; balcony; an architectural element which recesses or projects from the façade by at least 600mm; landscaping and/or fencing compatible with the treatments that have or will occur on neighbouring sites.	N/A	
4.2.3	Eaves minimum 450 mm (except on zero lot)	Y	
4.2.4	Roof clutter such as satellite dishes, water tanks, air conditioning units etc should not be prominent when viewed from any street.	Y	
4.2.5	Colours, materials and finishes are to be from a predominantly neutral palette (bright colours considered for architectural features.)	Y	Colour schedule included with application
4.2.6	Exact mirror-imaging of dwelling facades to form semidetached (duplex) housing is not permitted.	N/A	
4.3	Dwelling Height, Massing and Siting	Complies Y/N	Comments
4.3.2	Single and attached housing is to be 2 storeys. may permit a third storey if it is satisfied that it is on a prominent street corner and is not likely to impact adversely on the amenity of any adjoining land in terms of overshadowing and visual privacy.	Y	
4.3.3	50% of Principal Private Open receive at least 3 hours of sunlight between 9am and 3pm on property and adjoining property	Y	Oriented north west
4.3.4	lots >450m2, the second level of a dwelling is to be no more than 30% of the lot area.	N/A	

4.4	Building Setbacks	Complies Y/N	Comments
4.4.1	Detached (frontage: 12.5m – to less than 15m) Front: 4.5m Side: 0.9m Rear: 4m	Y	
4.4.2	corner lots secondary frontage: - 2 metres lots <18 metres wide - 3 metres lots >18 metres wide	N/A	
4.4.3	-Corner lots are to be splayed with the indent on both streets 5 metres. -setback from the splayed corner minimum of 2 metres.	N/A	
4.4.4	Any building contiguous with Caddens Road is to be set back 6 metres from the boundary to Caddens Road.	N/A	
4.4.6	Garages are to be set back a minimum of 1 metre behind the front building facade (including secondary street, excluding rear lane)	Y	
4.4.9	Projections permitted into side and rear setback areas include eaves, sun hoods, gutters, down pipes flues, light fittings and electricity or gas meters, rainwater tanks and hot water units.	Y	
4.7.6	The front setback is to be landscaped with the treatment to clearly delineate between the private and public domain. -The front setback is to incorporate two trees. -The rear garden must include at least one tree (may include existing trees that are to be retained.)	Y Y Y	
4.7.7	To prevent accumulation of water and concentration of salts, subsoil drains are to be installed around the perimeter of residences and connected to the stormwater system.	Not proposed	To be conditioned accordingly
4.8	Fencing	Complies Y/N	Comments
	Except for dwellings contiguous with Caddens Road, front and side fencing must be constructed with masonry piers that complement the streetscape. Infill panels are to consist of open slats, palisades or pickets.	Y	
	The fencing on the secondary street of a lot >17.5m set back 0.9 metres from secondary street boundary and incorporate landscaped vegetation between the fence and the boundary.	N/A	
	Metal sheet style fencing is not permitted anywhere.	Y	

	Dwellings located adjacent to open space, fencing is to be of a high quality material permit casual surveillance of the open space.	N/A	
4.9	Garages and Access	Complies Y/N	Comments
	Minimum of 5.5m from the front boundary and at least 1m behind the building façade	Y	
	Front loaded double garages only permissible on lots >12.5m	Y	
	Double garages -max 50% of the front façade -6 m in width -2.4 m in height. -Triple fronted garages are not permitted.	Y Y Y Y	
	Garages are to comply with AS 2890.1 minimum internal width: -3m for a single garage; -5.5m for a double garage.	Y	
	Driveways max 4.5m at the front boundary and min of 1.5m from street trees.	Y	
	Where possible garage for a corner lot should be accessed from the secondary street, unless the secondary street is Caddens Road.	N/A	
5.3	Sustainable Building Design	Complies Y/N	Comments
	Minimum dwelling floor to ceiling heights shall be as follows: (a) ground floor habitable rooms of two storey single dwellings - 2.65 metres; (b) upper floors and all non habitable rooms – 2.4 metres; (c) single storey dwellings – 2.65 metres; (d) attics – 1.5 metre wall height at edge of room with a 30 degree minimum ceiling slope; (e) all floors of multi-unit dwellings – 2.4 metres.	N/A N/A Y N/A N/A	
	The building envelope, depth, location of doors and windows, and internal layout of all residential development is to facilitate cross -ventilation.	Y	
	The main living area of all dwellings is to open directly onto the private open space via either glazed sliding bi-fold or French doors, or similar, to allow for adequate solar access.	Y	
	North and west facing windows are to be provided with appropriate external shading.	Y	

	All dwellings are to incorporate an outdoor clothes line/drying area in a sunny location not visible from a street or public place.	Y	
	A BASIX certificate is required for all new residential dwellings, including the residential component of a mixed use building.	Y	