

**FCF Fire & Electrical - South West Sydney**6 Derby Place  
Yarrawarra, NSW 2233Ph: 02 8518 6039 / Fax:  
1300 323 753

ABN 85 624 840 697

**Asset Record - Job No. 158575**269 Springwood Road  
269 Springwood Road  
Yarramundi NSW 2753

Inspection Date: 11/02/2021

Contact: Janice Lennon

Phone: 0408 945 518

**Asset Register - Fire Extinguisher - AS1851-2012**

Asset ID	FCFAssetID	Location	Type	Capacity	Rating	DOM/HT	Date	Service	Pass / Fail
266787	0015569	Shed 1	ABE	9.0kg	6A80BE	01/2018	11/02/2021	Annual	Pass
266785	0015567	Shed 2	ABE	9.0kg	6A80BE	01/2018	11/02/2021	Annual	Pass
266779	0015561	Shed 3	CO2	3.5kg	10BE	08/2017	11/02/2021	Annual	Pass
266786	0015568	Shed 3	ABE	9.0kg	6A80BE	01/2018	11/02/2021	Annual	Pass

**Asset Register - Fire Blanket - AS1851-2012**

Asset ID	FCFAssetID	Location	Size	Date	Service	Pass / Fail
266788	0015570	Shed 3	1m x 1m	11/02/2021	Six Monthly	Pass

**Asset Register - Fire Extinguisher - AS1851-2012**

Asset ID	FCFAssetID	Location	Type	Capacity	Rating	DOM/HT	Date	Service	Pass / Fail
266780	0015562	Canteen	BE	2.3kg	20BE	08/2017	11/02/2021	Annual	Pass

**Asset Register - Fire Blanket - AS1851-2012**

Asset ID	FCFAssetID	Location	Size	Date	Service	Pass / Fail
266789	0015579	Canteen	1m x 1m	11/02/2021	Six Monthly	Pass

**Asset Register - Fire Extinguisher - AS1851-2012**

Asset ID	FCFAssetID	Location	Type	Capacity	Rating	DOM/HT	Date	Service	Pass / Fail
266782	0015564	Circus Extinguisher Bank	Air/Water	9.0lt	3A	PT10/18	11/02/2021	Annual	Pass
266783	0015565	Circus Extinguisher Bank	Air/Water	9.0lt	3A	PT8/17	11/02/2021	Annual	Pass
Notes	Replaced maintenance tag and anti tamper								
266784	0015566	Circus Extinguisher Bank	Air/Water	9.0lt	3A	PT8/17	11/02/2021	Annual	Pass
Notes	Replaced maintenance tag								
266795	0015577	Circus Extinguisher Bank	Air/Water	9.0lt	3A	PT08/17	11/02/2021	Annual	Pass
266796	0015578	Circus Extinguisher Bank	Air/Water	9.0lt	3A	PT08/17	11/02/2021	Annual	Pass
266791	0015573	Circus Extinguisher Bank	ABE	9.0kg	10A80BE	07/2020	11/02/2021	Annual	Pass

**FCF Fire & Electrical - South West Sydney**6 Derby Place  
Yarrawarra, NSW 2233Ph: 02 8518 6039 / Fax:  
1300 323 753

ABN 85 624 840 697

**Asset Record - Job No. 158575****269 Springwood Road**  
269 Springwood Road  
Yarramundi NSW 2753**Inspection Date:** 11/02/2021**Contact:** Janice Lennon**Phone:** 0408 945 518

Notes	New extinguishers								
266792	0015574	Circus Extinguisher Bank	ABE	9.0kg	10A80BCE	07/2020	11/02/2021	Annual	Pass
Notes	New extinguisher								
266793	0015575	Circus Extinguisher Bank	ABE	4.5kg	6A80BE	01/2021	11/02/2021	Annual	Pass
Notes	New extinguisher								
266794	0015576	Circus Extinguisher Bank	ABE	4.5kg	6A80BE	01/2021	11/02/2021	Annual	Pass
Notes	New extinguisher								
266781	0015563	Circus Extinguisher Bank	ABE	4.5kg	4A60BE	06/2017	11/02/2021	Annual	Pass

**Description Of Work**

Technician to attend site and conduct routine maintenance on Portable Fire Equipment.

**Comments / Recommendations**

Technician Statement: I certify that system routine services have been carried out in accordance with AS1851, AS2293 and other relevant Australian Standards, as applicable to these assets and all safety requirements were in place during procedure.

Customer Acceptance: I have provided authorisation for FCF Fire & Electrical to carry out services as listed in this Asset Record and any other associated testing documentation. I accept the Terms and Conditions and confirm that the scope of work has been completed to my satisfaction.

Technician (Print Name): M. Sloggett

Licence No.

322563C/IT511  
86/F051186A

Customer (Print Name):

Technician (Signature): 

Customer (Signature):