NORTHROP

Level 11, 345 George Street, Sydney NSW 2000
T (02) 9241 4188 F (02) 9241 4324
E sydney@northrop.com.au ABN 81 094 433 100

23.04.2018

Ref: SY166993-ESOC-A

FDC Construction and Fitout
22-24 Junction Street
Forest Lodge
NSW 2037

Dear Peter,

Re: St Mary's RLC Western Foyer - Electrical Services Statement of Compliance

Subject Premises: Forester Road, St Mary
Development Application: 14/0932.1

Pursuant to the provisions of Clause A2.2 of the Building Code of Australia, I hereby certify that the above design will be carried out in accordance with normal engineering practice and will meet the requirements of the Building Code of Australia, relevant Australian Standards and relevant conditions of Developments Consent. In particular the design will comply with the following:

Power Distribution

The power distribution, including incoming supply, protection, and cabling has been designed in accordance with the following documents:

- AS/NZS 3000:2007 – Wiring Rules
- AS/NZS 3008.1.1:2009 - Cables for alternating voltages up to and including 0.61 kV—Typical Australian installation conditions
- NSW Service and Installation Rules (current edition)

External Façade Lighting

External lighting will be designed in accordance with the following documents:

- AS/NZS 1158.0:2005 (+ Amendment 2) – Lighting for Roads & Public Spaces (General)
- AS 4282:1997 – Control of the Obtrusive Effects of Outdoor Lighting

I am an appropriately qualified and competent person in this area and as such can certify that the design and performance of the design systems comply with the above and which are detailed on the following drawings.

I possess Indemnity Insurance to the satisfaction of the building owner or my principal.

Date	Rev	Issue	Author	Verifier
23.04.2018	A	Information	I. Kanalas	

Document Set ID: 8166916
Version: 1, Version Date: 02/05/2018

Civil Hydraulic Mechanical Electrical Sustainability Façades Environmental Structural

Full Name of Designer:	Ibby Kanalas
Qualifications:	BEng, FIES, Registered Lighting Practitioner of the IES NSW/NZ
Address of Designer:	Level 11, 345 George Street Sydney NSW 2000
Business Telephone No:	02 9241 4188
Name of Employer:	Northrop Consulting Engineers Pty Ltd

We confirm that in preparing the Electrical services documentation for this development, we have exercised due diligence and care, in accordance with standard practice. This Certificate however, does not relieve other parties from their responsibilities.

Yours faithfully,

Ibby Kanalas
Associate - Senior Electrical and Lighting Engineer
Northrop Consulting Engineers Pty Ltd

Document Set ID: 8166916
Version: 1, Version Date: 02/05/2018