

Our Ref: 2016-0268

27 September 2016

Xin Pan  
Morson Group  
By email: [xin@morsongroup.com.au](mailto:xin@morsongroup.com.au)

Dear Xin

**Restaurant Precinct, Tench Avenue, Penrith (Project)  
Certificate of Compliance for Hydraulic Services**

I, Paul McDonald, on behalf of Inline Hydraulic Services Pty Ltd, Professional and Qualified Hydraulic Engineers, certify in accordance with *clause A2.2* of the *Building Code of Australia (Evidence of Suitability)* (BCA) that the design for the above Project is compliant with the requirements of the BCA.

This certification is given subject to the following:

**1. Scope of Works – Hydraulic Services**

The services included under this Certificate are as follows:

- a) Fire Hydrant Service
- b) Fire Hose Reels

**2. Relevant Design Standards:**

In preparing the design for the Project, we have relied on the following standards:

Standard No	Description
AS 2419.1-2005	Fire Hydrant Systems
AS 2441-2005	Fire Hose Reel Systems
BCA E1.3	Fire Hydrant Service
BCA E1.4	Fire Hose Reels
Draft Fire Report	Draft Fire Engineering Report issued by HolmesFire dated 23 September 2016. Please note that the finalisation of this report is based on receiving sign off from Sydney Water. An application has been made for dispensation.

Yours faithfully



**Paul McDonald**  
Director  
**Inline Hydraulic Services Pty Ltd**