

18 September 2013
Secta Reference: SC_16032-SR2524

Firststyle Homes Pty Ltd
P.O. Box 171
HOXTON PARK NSW 2171

SECTA
CONSULTING ENGINEERS
PTY LTD
(STRUCTURAL - CIVIL)
ABN 91 136 407 835
Secta Consulting Engineers Pty Ltd
PO Box 259 Condell Park NSW 2200
office - (02) 9707 3414
web: www.sectaengineering.com.au
email: info@sectaengineering.com.au

Following your request, we can confirm that the following site has been inspected and subsequently classified by Secta Consulting Engineers in accordance with the relevant standards.

SITE REPORT

Re: Proposed Residential Property
LOT 1210 SYDNEY SMITH DRIVE THORNTON, PENRITH

Client:	Firststyle Homes
Slab Design Code:	SD2 - 225 pod, SL82 Referenced Code - AS 2870
Procedure's:	Bore test hole sample < 50mm diameter. Visual inspection. Identification of Soil Profile. Referenced Material
Basic Soil Profile:	Filled Site
Wind Classification:	"N2 (W33N)" in accordance with "AS 4055-2006"
Durability Classification:	"Exterior"
Concrete Quality:	20 Mpa
References:	AS 2870 – 1996 " Code for Residential Slabs and footings". Classification for N.S.W Soils for Housing. (NSW Builders Licensing Board). AS 4055-2006 Wind Loads for Housing. AS/NZS 4456.10:2003 Masonry units and segmental pavers and flags - Methods of test - Determining resistance to salt attack.

This report shall not be construed as relieving any other party of their responsibilities or contractual obligations.

Yours sincerely



Sharief Abdelfattah
MIEAUST CPENG NPER (structural/civil)
Accredited Certifier (structural/civil)

for **Secta Consulting Engineers**

