



Ref: .108313-C1
8 December 2021

Ms D M Garofali


**BUILDINGS ERECTED ON SITE AT
26 CAMDEN STREET
PENRITH.**

Reference drawing – 21-101-02

An inspection was made of the six separate structures at the above address being used as offices, lunch room and amenities all linked by an awning on 24.11.21.

The buildings are relocatable units and all appear to have been properly installed.

Based on our visual inspection we are satisfied that the building units including the attached awning are structurally adequate to withstand loading as required by AS/NZS 1170.1 & 2 for a Region A Terrain Category 3 wind area and as required by the structural provisions of the BCA (NCC).



Trevor B Hall, FIE Aust, CPEng. NER RPEQ 5081

KNEEBONE, BERETTA & HALL PTY LTD

Consulting Structural & Civil Engineers