



Association of Building
Sustainability Assessors

Class 2 Building Project Certification

Certification Number	1007577933
Certification Date	08/04/2015
Assessor Name	Reginald Hawkins
Assessor Number	20012
Assessor Signature	

Averaged Simulated Energy: HEATING: 64.6 MJ/m² pa
Averaged Simulated Energy: COOLING: 34.5 MJ/m² pa
Rated with Downlights: No

Averaged NatHERS Rating 99.0 MJ/m² pa

5.3/10



Document ID: 1007577933

Version: 1, Version Date: 10/07/2015

ABSAAssociation of Building
Sustainability Assessors**Class 2 Building
Sole Occupancy Unit
Certification**

Certification Number	1007577966
Certification Date	08/04/2015
Assessor Name	Reginald Hawkins
Assessor Number	20012
Assessor Signature	

Simulated Energy: HEATING: 89.9 MJ/m² pa**Simulated Energy: COOLING:** 45.1 MJ/m² pa**Rated with Downlights:** No**Unit#** Studio**NatHERS Rating** 135.0 MJ/m² pa**4.0/10**

Document ID: 1007577966

Version: 1, Version Date: 10/07/2015

ABSAAssociation of Building
Sustainability Assessors**Class 2 Building
Sole Occupancy Unit
Certification**

Certification Number	1007577941
Certification Date	08/04/2015
Assessor Name	Reginald Hawkins
Assessor Number	20012
Assessor Signature	

Simulated Energy: HEATING: 46.0 MJ/m² pa**Simulated Energy: COOLING:** 20.9 MJ/m² pa**Rated with Downlights:** No**Unit#**

Unit 1

NatHERS Rating 66.9 MJ/m² pa**6.5/10**

Document ID: 1007577941

Version: 1, Version Date: 10/07/2015

ABSAAssociation of Building
Sustainability Assessors**Class 2 Building
Sole Occupancy Unit
Certification**

Certification Number	1007577958
Certification Date	08/04/2015
Assessor Name	Reginald Hawkins
Assessor Number	20012
Assessor Signature	

Simulated Energy: HEATING: 57.8 MJ/m² pa**Simulated Energy: COOLING:** 37.4 MJ/m² pa**Rated with Downlights:** No**Unit#**

Unit 2

NatHERS Rating 95.2 MJ/m² pa**5.5/10**

Document ID: 1007577958

Version: 1, Version Date: 10/07/2015