


1 July 2013
Secta Reference: SC_15938-SR2425

Firststyle Homes Pty Ltd
P.O. Box 171
HOXTON PARK NSW 2171

SECTA
CONSULTING ENGINEERS
PTY LTD
(STRUCTURAL - CIVIL)
ABN 91 136 407 835
Secta Consulting Engineers Pty Ltd
PO Box 259 Condell Park NSW 2200
office - (02) 9707 3414
web: www.sectaengineering.com.au
email: info@sectaengineering.com.au

Following your request, we can confirm that the following site has been inspected and subsequently classified by Secta Consulting Engineers in accordance with the relevant standards.

SITE REPORT



Re: **Proposed Residential Property**
LOT 1157 SYDNEY SMITH DRIVE, THORNTON, PENRITH

Client: Firststyle Homes

Slab Design Code: SD2 - 225 pod, SL82
Referenced Code - AS 2870

Procedure's: Bore test hole sample < 50mm diameter.
Visual inspection.
Identification of Soil Profile.
Referenced Material

Basic Soil Profile: Filled profile

Wind Classification: "N2 (W33N)" in accordance with "AS 4055-2006"

Durability Classification: "Exterior"

Concrete Quality: 20 Mpa

References: AS 2870 - 1996 " Code for Residential Slabs and footings".
Classification for N.S.W Soils for Housing. (NSW Builders Licensing Board).
AS 4055-2006 Wind Loads for Housing.
AS/NZS 4456.10:2003 Masonry units and segmental pavers and flags - Methods of test - Determining resistance to salt attack.

This report shall not be construed as relieving any other party of their responsibilities or contractual obligations.

Yours sincerely

Sharief Abdelfattah
MIEAUST CPENG NPER (structural/civil)
Accredited Certifier (structural/civil)

for Secta Consulting Engineers

