

# PENRITH CITY COUNCIL

## NOTICE OF DETERMINATION

### DESCRIPTION OF DEVELOPMENT

Application number:	DA18/0729
Description of development:	Additions
Classification of development:	Class 1a

### DETAILS OF THE LAND TO BE DEVELOPED

Legal description:	Lot 39 DP 2120
Property address:	18 - 24 Farm Road, MULGOA NSW 2745

### DETAILS OF THE APPLICANT

Name & Address:	D Du Rieu 3 Montrose Road WINMALEE NSW 2777
-----------------	---------------------------------------------------

### DECISION OF CONSENT AUTHORITY

In accordance with Section 4.18(1) (a) of the Environmental Planning and Assessment Act 1979, consent is granted subject to the conditions listed in attachment 1.

Please note that this consent will lapse on the expiry date unless the development has commenced in that time.

Date from which consent operates	3 May 2019
Date the consent expires	3 May 2024
Date of this decision	24 August 2018

### POINT OF CONTACT

If you have any questions regarding this determination you should contact:

Assessing Officer:	Luke Caruana
Contact telephone number:	+612 4732 7553

## NOTES

---

### **Reasons**

The conditions in the attached schedule have been imposed in accordance with Section 4.17 of the Environmental Planning and Assessment Act 1979 as amended.

### **Conditions**

Your attention is drawn to the attached conditions of consent in attachment 1.

### **Certification and advisory notes**

You should also check if this type of development requires a construction certificate in addition to this development consent

It is recommended that you read any Advisory Note enclosed with this notice of determination.

### **Review of determination**

The applicant may request Council to review its determination pursuant to Division 8.2 of the Environmental Planning and Assessment Act 1979 within six months of receiving this Notice of Determination.

These provisions do not apply to designated development, complying development or crown development pursuant to Section 8.2(2) of the Environmental Planning and Assessment Act 1979.

### **Appeals in the Land and Environment Court**

The applicant can appeal against this decision in the Land and Environment Court within six months of receiving this Notice of Determination.

There is no right of appeal to a decision of the Independent Planning Commission or matters relating to a complying development certificate pursuant to clause 8.6(3) of the Environmental Planning and Assessment Act 1979.

### **Designated development**

If the application was for designated development and a written objection was made in respect to the application, the objector can appeal against this decision to the Land and Environment Court within 28 days after the date of this notice.

If the applicant appeals against this decision, objector(s) will be given a notice of the appeal and the objector(s) can apply to the Land and Environment Court within 28 days after the date of this appeal notice to attend the appeal and make submissions at that appeal.

### **Sydney Western City Planning Panels**

If the application was decided by the Sydney Western City Planning Panel, please refer to Section 2.16 of the Environmental Planning and Assessment Act, 1979 (as amended) for any further regulations.

# ATTACHMENT 1: CONDITIONS OF CONSENT

## General

1 The development must be implemented substantially in accordance with the plans prepared by Des Du Rieu Drafting, dated 09/07/18 and stamped approved by Council, the application form, the BASIX Certificate and any supporting information received with the application, except as may be amended in red on the attached plans and by the following conditions.

2 The work must be carried out in accordance with the requirements of the Building Code of Australia. If the work relates to a residential building and is valued in excess of \$20,000, then a contract of insurance for the residential development shall be in force in accordance with Part 6 of the Home Building Act 1989.

{Note: Residential building includes alterations and additions to a dwelling, and structures associated with a dwelling house/dwelling such as a carport, garage, shed, rural shed, swimming pool and the like}.

**3 The development shall not be used or occupied until an Occupation Certificate has been issued.**

4 All new works shall be constructed in accordance with the provisions of the "Planning for Bushfire Protection" December 2006 document including "Addendum: Appendix 3" and "AS3959 - 2009 'Construction of buildings in Bushfire Prone Areas'". In this regard the following applies:

\* Gutter and Valley Guards are to be installed in the development in accordance with Clause 4.3.5 of "Planning for Bushfire Protection" 2006; and

\* All development is required to comply with "Addendum: Appendix 3" of "Planning for Bushfire Protection" 2006 particularly Clause A3.7; and

\* The development is to be constructed to BAL-29 construction under "AS3959-2009 'Construction of buildings in bushfire-prone areas'".

5 A **Construction Certificate** shall be obtained prior to commencement of any building works.

## Demolition

6 All demolition works are to be conducted in accordance with the provisions of AS 2601-1991 "The Demolition of Structures". **Prior to demolition**, all services shall be suitably disconnected and capped off or sealed to the satisfaction of the relevant service authority requirements.

All demolition and excavated material shall be disposed of at a Council approved site or waste facility. Details of the proposed disposal location(s) of all excavated material from the development site shall be provided to the Principal Certifying Authority **prior to commencement of demolition**.

7 **Prior to commencement of demolition works on site**, a portaloo with appropriate washing facilities shall be located on the site and the Principal Certifying Authority is to be satisfied that:

- Measures are in place so as to comply with the WorkCover Authority's "Short Guide to Working with Asbestos Cement" and
- The person employed to undertake the works is a licensed asbestos removal contractor and is holder of a current WorkCover Asbestos Licence.

Any demolition works involving the removal of all asbestos shall only be carried out by a licensed asbestos removal contractor who has a current WorkCover Asbestos Licence.

All asbestos laden waste, including asbestos cement flat and corrugated sheeting must be disposed of at a tipping facility licensed by the Environmental Protection Authority to receive asbestos wastes.

8 Dust suppression techniques are to be employed during demolition to reduce any potential nuisances to surrounding properties.

9 Mud and soil from vehicular movements to and from the site must not be deposited on the road.

10 Demolition works will be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm (if inaudible on neighbouring residential premises), otherwise 8am to 1pm
- No demolition work is permitted on Sundays and Public Holidays.

In the event that the demolition relates to works inside the building and do not involve external walls or the roof, and do not involve the use of equipment that emits noise then the demolition works are not restricted to the hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

## Environmental Matters

11 Erosion and sediment control measures shall be installed **prior to the commencement of works on site** including approved clearing of site vegetation. The erosion and sediment control measures are to be maintained in accordance with the Department of Housing's "Managing Urban Stormwater: Soils and Construction" 2004.

(Note: To obtain a copy of the publication, you should contact Landcom on (02) 98418600).

The sediment and erosion control measures are to be installed **prior to and maintained throughout the construction phase of the development until the land, that was subject to the works, have been stabilised and grass cover established**. These measures shall ensure that mud and soil from vehicular movements to and from the site does not occur during the construction of the development.

- 12 Cut and fill operations on the property are only permitted in conjunction with the building works as detailed on the approved plans and specifications, and shall not extend more than 2 metres past the defined building footprint.

Before any fill material is imported to site, a validation certificate issued by an appropriately qualified person is to be provided to the Principal Certifying Authority. The validation certificate must demonstrate that the fill material is free from contaminants and weeds, that it is suitable for its intended purpose and land use, and that it will not pose an unacceptable risk to human health or the environment.

If Penrith City Council is not the Principal Certifying Authority, a copy of the validation certificate is to be submitted to Council for their reference.

{Note: Penrith Contaminated Land Development Control Plan defines an appropriately qualified person as “a person who, in the opinion of Council, has a demonstrated experience, or access to experience in hydrology, environmental chemistry, soil science, eco-toxicology, sampling and analytical procedures, risk evaluation and remediation technologies. In addition, the person will be required to have appropriate professional indemnity and public risk insurance.”}

- 13 All waste materials stored on-site are to be contained within a designated area such as a waste bay or bin to ensure that no waste materials are allowed to enter the stormwater system or neighbouring properties. The designated waste storage areas shall provide at least two waste bays / bins so as to allow for the separation of wastes, and are to be fully enclosed when the site is unattended.
- 14 All excavated material and other wastes generated as a result of the development are to be re-used, recycled or disposed of in accordance with the approved waste management plan.

Waste materials not specified in the approved waste management plan are to be disposed of at a lawful waste management facility. Where the disposal location or waste materials have not been identified in the waste management plan, details shall be provided to the Certifying Authority as part of the waste management documentation accompanying the Construction Certificate application.

All receipts and supporting documentation must be retained in order to verify lawful disposal of materials and are to be made available to Penrith City Council on request.

## **BCA Issues**

- 15 All aspects of the building design shall comply with the applicable performance requirements of the Building Code of Australia so as to achieve and maintain acceptable standards of structural sufficiency, safety (including fire safety), health and amenity for the on-going benefit of the community. Compliance with the performance requirements can only be achieved by: (a) complying with the deemed to satisfy provisions, or (b) formulating an alternative solution which:
- complies with the performance requirements, or
  - is shown to be at least equivalent to the deemed to satisfy provision, or
  - (c) a combination of (a) and (b)

16 In accordance with the requirements of clause 94 of the Environmental Planning and Assessment Regulation, you are required to install a hard wired smoke detector in the existing dwelling. This detector is to comply with the requirements of AS3786 and must be located in accordance with 3.7.2 of the Housing Provisions. A certificate from a Licensed Electrician attesting to the installation of the smoke detector is to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

## Health Matters and OSSM installations

17 The rainwater tank must be maintained so as not to create a nuisance and it must be protected against mosquito infestation.

## Construction

18 Stamped plans, specifications, a copy of the development consent, the Construction Certificate and any other Certificates to be relied upon shall be available on site at all times during construction.

The following details are to be displayed in a maximum of 2 signs to be erected on the site:

- the name of the Principal Certifying Authority, their address and telephone number,
- the name of the person in charge of the work site and telephone number at which that person may be contacted during work hours,
- that unauthorised entry to the work site is prohibited,
- the designated waste storage area must be covered when the site is unattended, and
- all sediment and erosion control measures shall be fully maintained until completion of the construction phase.

Signage but no more than 2 signs stating the above details is to be erected:

- at the commencement of, and for the full length of the, construction works onsite, and
- in a prominent position on the work site and in a manner that can be easily read by pedestrian traffic.

All construction signage is to be removed when the Occupation Certificate has been issued for the development.

19 Earthworks are only permitted in accordance with the stamped approved plans. All fill not shown to be retained shall be appropriately battered to natural ground level as per the stamped plans.

20 A certificate from a qualified practising Structural Engineer attesting to the adequacy of the structure to support the anticipated loads is to be submitted for consideration and approval prior to the issue of a Construction Certificate.

21 The roof of the structure is to be a dull, non-reflective surface and colour. The external finishes of the dwelling are to compliment and blend with the established streetscape and amenity of the area.

22 The rainwater tank(s) is to be:

- erected on a self-supporting base in the approved location on the property in accordance with the stamped-approved site plans for the development,
- structurally sound and constructed in accordance with AS/NZS 3500 1.2- 1998: National Plumbing and

- Drainage - Water Supply - Acceptable Solutions,
- fully enclosed and all openings sealed to prevent access by mosquitoes,
- fitted with a first flush device,
- fitted with a trickle system to top up from mains water,
- provided with an air gap, and
- installed by a licensed plumber in accordance with Sydney Water's "Plumbing requirements Information for rainwater tank suppliers and plumbers April 2003" and the NSW Code of Practice: Plumbing and Drainage.

Additionally, the following are to be provided:

- A back flow prevention device shall be provided at the water meter in accordance with Sydney Water requirements.
- In the event of a power failure, a back up supply of mains water shall be provided to at least one toilet in the dwelling.
- The rainwater tank(s) and associated piping is to be labelled 'Rainwater - Not for Drinking' in accordance with Sydney Water requirements.
- The rainwater tank and pipework is to be painted in colours matching the external finishes of the dwelling and is to be of non-reflective finish.
- The overflow for the rainwater tank is to be connected into the existing stormwater disposal system on the site.

Before a rainwater tank(s) can be used, a certificate or suitable document is to be submitted to the Principal Certifying Authority stating that the rainwater tank has been installed in accordance with:

- the manufacturer's specifications, and
- Sydney Water and NSW Health requirements.

This certificate or documentation is to be provided by the licensed plumber who installed the rainwater tank on the property, and is to be submitted prior to the issue of the Occupation Certificate.

- 23 The catchment area (for the rainwater tank) includes the parts of the roof of the dwelling(s) from which water is collected and includes gutters. To ensure a safe supply of water:
- roof catchment areas must be kept clear of overhanging vegetation,
  - gutters must have sufficient fall to downpipes to prevent pooling of water,
  - overflow, discharge from bleed off pipes from roof mounted appliances such as airconditioners, hot water services and solar heaters must not discharge into the rainwater catchment area,
  - for roofs containing lead based, tar based or asbestos material the tank supply must not be connected to drinking, bathing and gardening tap water outlets,
  - appropriate measures must be installed to prevent foreign materials from contaminating the water which enters the rainwater tank.
- 24 The rainwater tank supply must not be connected to drinking and bathing water tap outlets.
- 25 The pump must not exceed 5dBA above ambient background noise level at the nearest residential property boundary. The provisions of the Protection of the Environment Operations Act 1997 apply to the development, in terms of regulating offensive noise.
- 26 Construction works or subdivision works that are carried out in accordance with an approved consent that involve the use of heavy vehicles, heavy machinery and other equipment likely to cause offence to adjoining properties shall be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm (if inaudible on neighbouring residential premises), otherwise 8am to 1pm
- No work is permitted on Sundays and Public Holidays.

Other construction works carried out inside a building/tenancy and do not involve the use of equipment that emits noise are not restricted to the construction hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

## Swimming Pools

- 27 When the swimming pool construction has reached a stage where the pool is capable of holding water, the pool area shall be restricted from access in accordance with AS1926 "Swimming Pool Safety". Restriction of access to the pool area shall also comply with the Swimming Pools Act, 1992.
- 28 At all times, the swimming pool is to be surrounded by a child-resistant barrier that:
- separates the swimming pool from any residential building situated on the premises and from any place (whether public or private) adjoining the premises, and
  - is designed, constructed, installed and maintained in accordance with the standards prescribed by AS 1926 "Swimming Pool Safety".
- 29 The following means of access to the swimming pool shall be restricted to:
- (a) For each doorway giving access to the swimming pool:
- the door or, if there is a security door in addition to another door then either of those doors must be kept child-safe by means of a lock, latch, bolt, chain or another child-resistant device located at least 1.5 metres above finished floor level, and
  - there must not, on the door or on the door frame, be any footholds wider than 10 millimetres between the release mechanism of the door and any point 100 millimetres above finished floor level.
- (b) For each window giving access to the swimming pool (but does not apply to a child-safe window or to a window that is totally enclosed by a child - safe grille):
- the bottom of the lowest opening panel of the window must (when measured in the closed position) be at least 1.2 metres above finished floor level, and there must not be any footholds wider than 10 millimetres between the bottom of the lowest opening panel of the window and any point within 1.1 metres below the bottom of that panel.
- 30 The child-safe window grilles marked on the approved plan are required under the requirements of the Swimming Pools Act 1992 as an alternative means of restricting access from the dwelling to the swimming pool area. The child-safe window grilles are to remain as approved for the life of the swimming pool.
- 31 If a common boundary fence forms part of the pool enclosure, the provision, maintenance and effectiveness of the said boundary fence is the responsibility of the pool owner whilst ever the pool exists. Alternatively, the pool shall be fully enclosed by isolation fencing.
- 32 A smooth faced barrier is to be fixed to the existing boundary fence at a width of 1200mm externally and 300mm internally from the junction of the pool fence and shall extend to the height of the boundary fence. This is required so as to restrict holds for climbing in accordance with AS 1926 "Swimming Pool Safety".
- 33 A sign must be erected in a prominent position in the immediate vicinity of the swimming pool and must:

- be erected in accordance with the provisions relating to instructional posters of the document entitled “Policy Statement No. 9.4.1: Guidelines for the Preparation of Posters on Resuscitation” published by the Resuscitation Council. (A copy may be purchased from Penrith City Council's Civic Centre, 601 High Street, Penrith), and
- bear a notice that contains the words “YOUNG CHILDREN SHOULD BE SUPERVISED WHEN USING THIS SWIMMING POOL”, together with details of resuscitation techniques (for adults, children and infants) set out in the relevant provisions of the document entitled “CardioPulmonary Resuscitation” published by the Australian Resuscitation Council. (A copy may be purchased from Penrith City Council's Civic Centre, 601 High Street, Penrith).

34 The swimming pool must be registered on the NSW Swimming Pool Register when it is capable of holding water and before the issue of an Occupation Certificate. The swimming pool is to be registered at [www.swimmingpoolregister.nsw.gov.au](http://www.swimmingpoolregister.nsw.gov.au) or in person at Penrith City Council (\$10 fee applies when registering at Council).

35 All backwash from the swimming pool shall be directed into the mains sewer.

In areas where sewer is not available, the following requirements apply -

- The swimming pool shall be provided with filtration equipment that does not require a backwash facility (eg. a cartridge filtration system).
- Overspill water shall be diverted away from the swimming pool and not directed onto adjoining properties.
- The frequency of emptying of the swimming pool water shall be minimised. Water resulting from the emptying of the pool shall be collected and disposed of by a private wastewater disposal contractor. Disposal by other means is not permitted.

## Engineering

36 Stormwater drainage from the site shall be discharged to the:

- a) Existing drainage system or
- b) Level spreader system or
- c) Absorption trench

The proposed development and stormwater drainage system shall be designed to ensure no adverse impact on adjoining properties by the diversion, damming or concentration of stormwater flows.

37 All roadworks, stormwater drainage works, associated civil works and dedications, required to effect the consented development shall be undertaken at no cost to Penrith City Council.

38 An Infrastructure Restoration Bond is to be lodged with Penrith City Council for development involving works around Penrith City Council's Public Infrastructure Assets. The bond is to be lodged with Penrith City Council prior to commencement of any works on site or prior to the issue of any Construction Certificate, whichever occurs first. The bond and applicable fees are in accordance with Council's adopted Fees and Charges.

An application form together with an information sheet and conditions are available on Council's website.

Contact Penrith City Council's City Works Department on (02) 4732 7777 or visit Penrith City Council's

website for more information.

39 Prior to the issue of any Construction Certificate, a Section 138 Roads Act applications, including payment of application and inspection fees, shall be lodged and approved by Penrith City Council (being the Roads Authority for any works required in a public road). These works may include but are not limited to the following:

- a) Vehicular crossings (including kerb reinstatement of redundant vehicular crossings)
- b) Concrete footpaths and or cycleways
- c) Road opening for utilities and stormwater (including stormwater connection to Penrith City Council roads and other Penrith City Council owned drainage)
- d) Road occupancy or road closures
- e) The placement of hoardings, structures, containers, waster skips, signs etc. in the road reserve
- f) Temporary construction access

All works shall be carried out in accordance with the Roads Act approval, the development consent, including the stamped approved plans, and Penrith City Council's specifications, guidelines and best engineering practice.

Contact Penrith City Council's City Works Department on (02) 4732 7777 or visit Penrith City Council's website for more information.

Note:

- a) Where Penrith City Council is the Certifying Authority for the development, the Roads Act approval for the above works may be issued concurrently with the Construction Certificate.
- b) Separate approvals may also be required from the Roads and Maritime Services for classified roads.
- c) All works associated with the Roads Act approval must be completed prior to the issue of any Occupation Certificate or Subdivision Certificate as applicable.
- d) On completion of any awning over the road reserve, a certificate from a practising structural engineer certifying the structural adequacy of the awning is to be submitted to Council before Council will inspect the works and issue its final approval under the Roads Act

40 Prior to the issue of any Occupation Certificate, the Principal Certifying Authority shall ensure that all works associated with a S138 Roads Act approval or S68 Local Government Act approval have been inspected and signed off by Penrith City Council.

## Landscaping

41 No trees are to be removed, ringbarked, cut, topped or lopped or wilfully destroyed other than those within 3 metres of the proposed building footprint or as shown on the approved plans without the prior consent of Penrith City Council and in accordance with Council's Tree Preservation Order and Policy.

42 Existing landscaping is to be retained and maintained at all times.

## Payment of Fees

- 43 Prior to the commencement of any works on site, all fees associated with Penrith City Council-owned land and infrastructure shall be paid to Council. These fees include Road Opening fees and Infrastructure Restoration fees.

## Certification

- 44 Prior to the commencement of any earthworks or construction works on site, the proponent is to:
- (a) employ a Principal Certifying Authority to oversee that the said works carried out on the site are in accordance with the development consent and related Construction Certificate issued for the approved development, and with the relevant provisions of the Environmental Planning and Assessment Act and accompanying Regulation, and
  - (b) submit a Notice of Commencement to Penrith City Council.

The Principal Certifying Authority shall submit to Council an "Appointment of Principal Certifying Authority" in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

Information to accompany the Notice of Commencement

Two (2) days before any earthworks or construction/demolition works are to commence on site (including the clearing site vegetation), the proponent shall submit a "Notice of Commencement" to Council in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

- 45 An Occupation Certificate is to be obtained from the Principal Certifying Authority on completion of all works and prior to the occupation/use of the development.

The Certificate shall not be issued if any conditions of this consent, but not the conditions relating to the operation of the development, are outstanding.

A copy of the Occupation Certificate and all necessary documentation supporting the issue of the Certificate is to be submitted to Penrith City Council, if Council is not the Principal Certifying Authority.

## SIGNATURE

Name:	Luke Caruana
Signature:	

For the Development Services Manager