



LANDSCAPING GENERAL NOTES:

- Contractor to verify location of all underground services prior to commencement of work (including
- All works performed must be by licensed contractors in accordance with all Australian Standards, Natspec & local Government codes & standards, and the site management plan in regard to the protection from sediment movement off the site into waterways and stormwater systems.
- These notes do not waive any responsibilities or approvals required by other authorities.
- Plant selection shall be as per Council recommendations in areas shown as landscaping on the Landscaping
- root systems and plant and all other material shall be free of pests, diseases & pathogens. Site preparation for all garden bed areas involves 2 applications of a non-residue contract herbicide (Glyphosate or similar approved) following Manufacturer's specifications- 2 months prior to planting (the
- second application should be 1 month after the first). The herbicide shall be dyed red to identify exposed areas. Leave sprayed areas for a period of 10 days prior to being worked. Re-spray any weeds still alive after 10 days. Treat any nutgrass with sempra sprayed at regular intervals applied in accordance with the
- Determine pH of soil using pH kit available at most nurseries. pH should be slightly acidic to neutral PH -5.5 to 7.0. If pH is outside of this range contact your local nursery to obtain advice on how to improve the pH
- It is the proprietor's responsibility to ensure all relevant authorities are notified and requirements are met. . There shall be a 13 week Plant Establishment Period following the approval of Practical Completion by the responsible authority & will commence following an 'On Maintenance' Inspection of the 'As Constructed' landscape works. During this period the landscape contractor shall make good all defects in the scope of works. Maintenance and Establishment means the care & maintenance of the contract area by accepted horticultural practices, as well as rectifying any defects that become apparent in the work under normal use. This shall include, but shall not be limited to watering, fertilising, weeding, pruning, pest and disease control, cultivation, re-staking and replacement of any plants that fail or are damaged with plants of the same
- The Builder is to remove all trees on the site except otherwise noted on the Landscaping Plan. Irrigation for all Landscaped areas is to be a design and construct package (if required by the client) in accordance with local Council guidelines. If required; an approved drip irrigation system is to be supplied to all garden beds. It is the responsibility of the contractor to ensure that all irrigation meets manufacturers spec's. The system is to be connected to the mains water supply or nearby stormwater overflow dam. 13. Kerbing should be provided to protect all landscaped areas from vehicle encroachment by a proprietary

NOTE: The Mature height and width of plants will vary according to climate, soil conditions and rainfall.

Install timber edging (or approved similar equivalent) between all lawn areas and garden beds as per details if

Where required; areas of turf are to be re-graded to provide smooth contours and are to be raked to eliminate soil clouds, rubble, rock, weeds, seeds, roots (including nut grass and oxials), material toxic to plant growth & extraneous material for a depth of 25mm MIN within the topsoil zone.

Thoroughly eradicate weeds prior to the installation of turf by approved methods such as manual removal,

The soil attached to the turf shall be free from rubbish, sticks and other deleterious material, cut with a full 25mm

The moisture level in the turf should be kept relatively consistent so that it is not saturated or severely dried out

The turf shall be supplied as rolls in long lengths of uniform width, not less than 300mm, and shall be in sound

The moisture level in the cut turf should be kept relatively consistent so that it is not saturated or severely dried out when laying. Both of these situations can cause turf to fall apart during laying.

shall be used for un-irrigated areas and couch for irrigated areas.

f grass on Council verge area is damaged during construction, turf should be selected to match the existing

Sections to be turfed shall be watered within 24 hours prior to turfing at an approximate rate of 10mm of water in

Watering is to be carried out in such a way as to not cause any scouring or erosion.

Excavate/grade all proposed new turf areas to 120mm below the desired surface level.

DO NOT excavate the surface level within 1500mm MIN or within the structural root zone (whichever is greater)

Rip the subgrade to 150mm, place 100mm deep imported top soil (as per Top Soil Notes). Immediately prior to laying the turf spread "Shirley's No: 17 Lawn Fertilizer" over the top soil at the recommended rate. Place the turf. Fill all joints in turf with topsoil dressing. Water thoroughly in accordance with the current weather conditions

LANDSCAPING NOTES

GARDEN BED MULCH: Mulch for all planting areas shall be forest bark mulch or similar (no fines) approved by Council. 80% of particles shall be in the size range 20-35mm in plan & 5-10mm in thickness. No particle is to exceed 50mm in plan. Mulch is to be stockpiled and thoroughly weathered prior to delivery to site. Mulch is to be free of weed material and seed, debris and foreign matter.

Contractor is to submit a 5kg bag sample to the Council Representivive & Client for approval prior to delivery to site. All mulch used shall comply with the approved sample. Note: Rare timber species such as Jarrah and Red Gum must not be used.

The stems of all plants shall be kept free (ie: 100mm minimum back from tree stems) of mulch to protect the stem from possible collar rot. Top of the mulch is to be level with adjacent surface where appropriate.

All trees to be healthy specimens free of pests & diseases. Trees to be well watered a MAX of 24 hours prior to planting.

Planting shall be carried out using accepted horticultural practices with all plants conforming to the species, size and quantities indicated on the Landscape Plan and Schedule. Plants shall be thoroughly soaked through immersion in water prior to planting and if the planting soil is very dry then the planting hole is also to be filled with water and allowed to drain completely. The rootball of semi-advanced trees is to be well irrigated rather than immersed.

Backfill the hole gently. Do not tread-in any plants/trees/shrubs. Tree watering post planting (and prior to mulching), provide a MIN of 10 litres or water for tree in a 45 litre pot to the newly planted tree per 7 days. Water at a slow rate so as not to displace mulch. For trees in pot size larger than 45 litres. Provide quantity of water one third of that pot size.

GARDEN BEDS:

All garden beds shall be excavated to a minimum depth of 300mm. Where possible, site soil should be stockpiled and used for the garden beds. Subgrade within planting areas is to be ripped to a minimum depth of 150mm and cultivated with gypsum at a rate of 2.5kg/m². All soil, whether existing on site or imported must meet the requirements as stated in the "Top Soil & Testing" notes:

The subsoil is to be graded & lightly compacted to re-establish a finished soil level of a minimum of 300mm below paving level throughout. The soil is to be evenly compacted throughout to approximately 70% modified maximum dry density.

Supply and place 200mm minimum depth of approved garden soil, compliant with Technical Note 4 of the 'Subdivision Landscape works Practical Completion & Handover Procedures Manual' to establish a finished grade that is 100mm below paving and general levels throughout.

Supply and place 100mm depth of approved mulch.

The recommended fertiliser is Agriform pellets applied at a rate of 20H 21G tablets per planting hole. Fertiliser is to be placed in the bottom of the hole & covered with some soil prior to planting to prevent the fertiliser coming into direct contact with the roots.

Place water crystals at a rate at 250mm expanded crystals per planting hole.

WEED REMOVAL:

All weeds shall be thoroughly removed. All vegetative material, including roots and rhizomes of non-woody perennials and woody suckering weeds, are to be removed or appropriately controlled using chemical means. The stumps of non-suckering woody perennials are to be stump ground. All vegetative material shall be appropriately disposed of off site in a manner which will not allow their re-establishment elsewhere. Any chemical controls are to be used in accordance with manufacturer's instructions and standard occupational health & safety procedures.

MIN 3 No. 50 x 50 x 1800mm chisel pointed hardwood or recycled plastic stakes set vertically & clear of rootball & driven MIN 800mm into ground prior to planting tree. Stakes are to be offset from the nearest underground services a MIN of 200mm from underground services. It is recommended that 4 stakes are used to minimise truck damage to street trees. Trees should be staked for 1-2 years MIN.

Excavate a shallow planting hole with --rough & sloping sides 3 times the Ø of the root ball in highly compacted soils & 2 times the Ø minimum in all other soils where space is available & break up sides & base. Refirm base. Depth of planting hole no deeper than the height of the root ball. Plant root ball in the soil and never in the mulch. Backfill with 50/50 blend imported topsoil/site topsoil broken up to friable texture, firming progressively.

Use a slow release fertiliser (for exotic species only), or apply fertiliser specific to the individual plant's requirements. Mix slow release fertiliser with backfill material to prevent direct contact of fertiliser with tree roots.

-Tie trees immediately after planting with flexible canvas, hessian or rubber ties 50mm wide in a "figure 8" configuration around the tree trunk at $\frac{1}{3}$ tree height. Secure tie to stakes via staples/galv nails & allow some trunk movement.

with trunk. watering tree.

On sloping sites greater than 1:8 and if roc raised above grade, form a raised ring of s to direct water into the root ball.

VISub-soil

TYPICAL INTERNAL SITE TREE PLANTING DET

AT: LOT 3, 1-21 CRANEBROOK RC
CRANEBROOK, NSW, 2749.

FOR: CARWASH WORLD PTY LTD

ADDITION

TOP SOIL & TESTING:

Where possible site topsoil should be used for the garden beds. In acquiring site soil, the top 100mm layer shall be stripped of soil and vegetation and stockpiled on the site.

All top soil shall conform to AS 4419 "Soils for landscaping & Garden Use" & shall be a good quality landscaping soil mix imported from an approved source. Soil for use in garden beds may then be obtained from the site provided the soil meets the requirements below: Existing Soil:

- Free from perennial weeds and their roots, bulbs or rhizomes;
- Free from building rubble, including bricks, concrete, plaster, timber, oil or any other matter deleterious to plant growth, Free from rocks or stones greater than 5mm Ø, but in any case, to have less
- than 5% stone by dry weight, Texture to be light to medium friable. t is imperative that existing site topsoil be used in tree planting areas to help

educe the risk of root girdling and subsequent tree failure. Imported Soil: Top soil is to be laid over a prepared sub-base which has had any materials

- damaging to plant growth (eg: rubble and large rocks) removed. Should imported soils be required, provide samples of a one litre bag for approval
- The subsoil shall be ripped and cultivated to a depth of 300mm minimum to combine with existing soil/base.
- No imported top soil is to be used within the root zones of trees or shrubs to be retained. No cultivation of existing soil is to take place within this area. Holes (eg: as the result of plant removal) and uneven soil levels may be patched using imported topsoil as specified.
- Imported top soil is to be lightly and uniformly compacted in 150mm layers to a minimum depth of 300mm on excavated planting beds, 450mm in tree planting areas and cultivated into the existing site soil to a minimum depth of 150mm.
- Free from perennial weeds & their roots, bulbs, rhizomes or salts, Free from building rubble, including bricks, concrete, plaster, timber, oil or any other matter deleterious to plant growth,
- Free from rocks or stones greater than 5mm Ø, but in any case, to have less than 5% stone by dry weight,
- Texture to be light to medium friable (sandy loam),
- It shall contain approximately 70% sandy loam & 30% composted or mature organic matter PH to be 5.5 - 7.0,
- It shall be free from silt/clay material & not contain chemical fertilizers, Non-hydrophobic.
- The contractor is to make allowance for the stockpiled topsoil to be tested prior to spreading: Three samples of the site won soil shall be randomly selected from different
- locations. The samples shall be comprehensively laboratory tested by a nominated agency (as per the requirements above) for approval by the Council.
- The laboratory report shall be accompanied with recommendations for amelioration measures required to improve any deficiencies.
- Laboratory certificates shall accompany the sample soil mix submitted for approval at the commencement of the work, including details of the soil source.
- If the site topsoil fails to conform to the above tests, the material may be ameliorated in accordance with the recommendations of the laboratory report (to reach the relevant Australian Standards and the above requirements) as identified above.
- If the material is deemed unsuitable for amelioration, imported topsoil (meeting the above requirements) shall be used in landscape construction. A laboratory certificate shall accompany the imported soil demonstrating the
- mix is in accordance with the above requirements. During the progress of the works, the contractor shall select two further soil samples for analysis, to confirm compliance with the above requirements. In the event that the subsequent tests reveal unacceptable deviations from the
- approved, tested samples, the contractor (at their expense) will be responsible for undertaking further amelioration processes. All declared noxious weeds should be removed or treated accordingly.

Alternatively use another

similar approved product.

Place saw cuts max. 15mm

planting bed

75mm consolidated -

depth mulch. Type as

Fertiliser as specified

New topsoil 300mm -

depth, or as specified,

culitvated into existing

backfilling with topsoil.

Avoid contact with roots.

subsoil 150mm MIN.

specified.

deep to form smooth curves.

- Hardwood brace at joints nailed both

50x50x450 hardwood or treaded pine

stakes spacing as required to maintain

end. set 20mm below top of edge

cuves, MAX 1.5M.

–100x25 seasoned sawn

Tubestock or potted shrub.

Mulch kept clear of stem.

- Mound topsoil berm to

form a watering basin.

with soil.

- Top of rootball planted level

-Break up sides & base of hole.

Cultivated sub-soil to 150mm

hardwood edging.

TIMBER EDGE PLAN DETAIL

1. Dig hole twice as deep as root ball and allow at least 200mm around sides for

2. Apply fertiliser in base of hole, cover with topsoil (type & rate as per specification).

-Create dish to keep mulch clear of tree trunk top of root ball flush with finished level of planting hole.

-75mm high berm to form a watering basin. Trees to be well watered prior to planting. 100mm depth of approved mulch shall be spread a MIN of 1000mm Ø from the

centre of tree & beyond the edge of the planting hole, overlapping undisturbed soil. Ensure mulch is not in direct contact

Use a 50mm flexible AG. pipe around root ball & protrude from mulch for

-Set root ball on undisturbed soil or compact soil under root ball to prevent

All trees to be healthy well grown specimens free of pests & diseases with acceptable root to shoot ratios.

ceptable root to shoot ratios. than 1:8 and if root ball is a raised ring of soils & mulch ot ball. NG DETAIL	 Water wel Stake larg 	it in centre of hole, backfill with s l into saucer around crown of pla er shrubs where necessary usin POT PLANTING	ant. g 50x50x12	200mm hardwood sta		
DOK ROAD, 2749.	Design Matters	TMC Build P.O. Box 3494, Morningto	•	•		
LTD	National	E:mail- tracey@tmcdesign.com.au				
	The peak body for the	Scale: 1:100 (A1)	Date:	MAY 2021		lssu
T. MICHAELS	building design profession Member	Sheet No: 6 of 8.	Job No:	20-026 D)A	E