

Liquid Limit and Linear Shrinkage Test Results

Customer: GJ Gardner Homes	Ideal Job No: 36197-GJG	Report No 36197 L1
Address: Lot 322 Highland Views, GLENMORE PARK		Test Date: 23/10/18

Test No: L1	Depth (m): 0.7m	Borehole No: 1
-------------	-----------------	----------------

Sample No	Depth (m)	Material Description (visual)	Codes	Liquid Limit %	Linear Shrinkage %
L1	0.7m	Pale Brown silty Clay	1,6,**	59%	15.0%

CODES/LEGEND

NO - Not Obtainable

Sample History

1 - Air Dried 2 - Low Temperatures (<50C) Oven Dried 3 - Oven (105C) Dried 4 - Unknown 5 - Natural

Method of Preparation

6 - Dry Sieved 7 - Wet Sieved

Shrinkage sample

(CR) - Crumbled (CU) - Curled

** Mould Length is 125mm *** Mould Length is 150mm

Test Methods

Linear Shrinkage AS1289.3.4.1 & Liquid Limit AS1289.3.1.2



Accredited for compliance
with ISO/IEC 17025
Accreditation No 19226

Checked By D. Dwyer
Dated 24-Oct-18

Approved Signatory

