



Inhouse Consulting Engineers Pty Ltd

ABN: 44 066 587 719

216 Great Western Hwy, Kingswood P.O. BOX 752 Kingswood NSW 2747 TEL: 02 4721 0044 FAX: 02 4721 1955
info@inhouseengineers.com.au www.inhouseengineers.com.au

INSPECTION CERTIFICATE

REQUEST DETAILS

Instructed by LUKE of GREATER WEST Ph. 0415 066 514
Project: CHADDENS KNOLL

Item to be Inspected: FOOTINGS FOR WALL TYPE 2
Job No./Drawing No. Time 8:30 Date 3-2-15

INSPECTION RESULT

Time 8:30 Date 3/2/2015 Inspected by Michael
Site Instructions issued to: Results to: Ivan

Wall Type 2 - Footing - Reinforcement good
Boundary Wall - Ensure base is clean of rubble before pour

OK to pour

Signed 