

Nationwide House Energy Rating Scheme* — Class 2 summary



Certificate Number: **WM9PLX5BE6**

Date of Certificate: **20 Aug 2018**

★ Average star rating: **6.8**


Assessor details

Accreditation number: **101399**
 Name: **Nermein Loka**
 Organisation: **Loka Consulting Engineers**
 Email: **civil5@lceng.com.au**
 Phone: **80659689**
 Declaration of interest: **See individual certificates**
 Software: **FirstRate5 v5.2.9**
 AAO: **ABSA**

Dwelling details

Address: **1 Station Lane**
 Suburb: **Penrith**
 State: **NSW**
 Postcode: **2750**

Summary of all dwellings



Certification details

Certificate number	Unit number	Annual thermal performance loads (MJ/m ²)			Star rating
		Heating load	Cooling load	Total load	
F9LS99BKMI	Unit 1	57.4	27.5	84.9	6.1
2ZQDI8LTN0	Unit 10	48.1	22.8	70.9	6.8
57AIET8PCV	Unit 11	42.7	22.5	65.2	7
J1B510LDEY	Unit 12	29.7	32.1	61.8	7.2
3VKMPH3FU2	Unit 13	34.4	45	79.4	6.4
D6J4M44987	Unit 14	45.2	20.9	66.1	6.9
NBJ3QBIVLR	Unit 15	51.1	17.6	68.7	6.9
WHOZ7JXY27	Unit 16	51.5	27.1	78.6	6.4
Z25KSNSGS7	Unit 17	62.3	24.9	87.2	5.9
3FUXXH04DN	Unit 2	59.2	15.3	74.5	6.6
6TAWAP7YEJ	Unit 3	56.8	18.7	75.5	6.6
S1EOOGLTX4	Unit 4	55.3	17.6	72.9	6.7
RRENB2WCQB	Unit 5	14.3	18.1	32.4	8.6
3GJ29YOVCU	Unit 6	38.8	22.9	61.7	7.2
VTGV9L7YCI	Unit 7	49.5	18.6	68.1	6.9
6JI30OPXUH	Unit 8	33.8	20	53.8	7.6

continued

Nationwide House Energy Rating Scheme* — Class 2 summary



Certificate Number: **WM9PLX5BE6**

Date of Certificate: **20 Aug 2018**

★ Average star rating: **6.8**

Summary of all dwellings continued

Certification details continued

Certificate number	Unit number	Annual thermal performance loads (MJ/m ²)			Star rating
		Heating load	Cooling load	Total load	
24ICQLRMOZ	Unit 9	40.4	22.6	63	7.1

This building achieves an average star rating of: **6.8**