

26 June, 2021

To whom it may concern

This certification has been completed based on the purchaser's advice of the building's intended purpose. Any approving authority should confirm that the Importance Level nominated is appropriate for the building's usage as this is not able to be ascertained by the engineer.

I certify that I am an independent technical expert and have reviewed Steelx Shed Management System Software that has produced the design and drawings detailed below. I have reviewed the documents based in the site specific analysis produced by the Shed Safe Sitecheck Software (*Refer to the Site Specific Design Criteria Analysis*):

<b>Job Number:</b>	WSS212462	<b>Design Criteria:</b>	Building Class 10,
<b>Customer:</b>	Robert Stutsel	<b>Max Design Wind Speed</b>	of 39.2m/s
<b>Address:</b>	426 The Driftway Londonderry NSW 2753 Australia (-33.62534 and 150.73013)		

Drawing Number	Date	Number of Pages	Description
WSS212462 - 2	26/06/2021	1	General Notes
WSS212462 - 3	26/06/2021	1	Layout
WSS212462 - 4	26/06/2021	3	Specification Sheet
WSS212462 - 5	26/06/2021	1	Bracing
WSS212462 - 6	26/06/2021	1	Concrete Piers
WSS212462 - 7	26/06/2021	1	Slab Dimensions
WSS212462 - 8	26/06/2021	7	Connection Details
WSS212462 - 9	26/06/2021	3	Flashing Fixing Details
WSS212462 - 10	26/06/2021	2	Component Position
WSS212462 - 11	26/06/2021	5	Purlin And Girt

*(Some drawings have multiple pages, eg: "1 of 3")*

As an independent technical expert, I verify this design complies with the following codes and standards:

<b>NCC:2019</b>	<b>AS/NZS 4600:2018</b>
<b>AS/NZS 1170.1:2002</b>	<b>AS/NZS 1170.2:2011</b>
<b>AS/NZS 1170.3:2002</b>	<b>AS 4100:1998</b>
<b>AS 2870:2011</b>	<b>AS 3600:2018</b>

Unless nominated, the building has not been designed for any additional loads including, but not limited to, earthquake, snow, solar panels or lining with any materials.

Signed

J. Ronaldson  
for and on behalf of  
Apex Engineering Group PTY LTD  
ACN 632 588 562

Member Institution of Engineers (Aust.), CPEng (NER Structural) Regn. No. 5276680  
Registered Professional Engineer (Structural) - Queensland: Regn. No. 24223  
Registered Building Designer & Professional Engineer (Structural) - Tasmania: Regn. No. 185770492  
Registered Professional Engineer (Structural) - Victoria: Regn. No. EC67493