

LPB FIRE SERVICES PTY. LTD.

ABN 39 079 032 456

FIRE PROTECTION ENGINEERS

Design - Consulting - Training

15 Farrell Road NSW Bass Hill 2197

POBox 7069 Bass Hill NSW 2197

Email: lpbfire@hotmail.com

Ph: (02) 9727 5215 Fax: (02) 9724 3842

John Billinghamst

Director

Mob: 0419 220 037

Nick Alejandro B.Eng

Principal Design Engineer

Mob: 0434 690 712

Email: nick@lpbfire.com.au

ANNUAL FIRE SAFETY STATEMENT

AFSS 07/0737

Issued under the

Environmental Planning & Assessment Regulation 2000

Name Owner/Agent

I, SEAN DRANSFIELD

of Pared Foundation, 839 Old Northern Road, Dural
certify that:

- (a) That each of the essential fire safety measures specified in this statement has been assessed by a properly qualified person and was found, when it was assessed, to be capable of performing:
- i. in the case of an essential fire safety measure applicable by virtue of a fire safety schedule, to a standard no less than specified in the schedule, or
 - ii. in the case of an essential fire safety measure applicable otherwise than by virtue of a fire safety schedule, to a standard no less than that to which the measure was originally designed and implemented, and
- (b) the building has been inspected by a properly qualified person and was found, when it was inspected to be in a condition that did not disclose any grounds for a prosecution under Division 7 of Part 9 of the Environmental Planning & Assessment Regulation 2000, and
- (c) the information contained in this certificate is, to the best of my knowledge & belief, true & accurate.

Address of Building: Wollemi College -- Gipps Street. (Lot2 Water Street), Werrington

Use of Premises: Private School

Owner's Name: Pared Foundation

Owner's Address: 839 Old Northern Road, Dural NSW 2158

Contact Phone No: 9651 1177

ESSENTIAL/CRITICAL FIRE SAFETY MEASURES

Fire Safety Measure

Standard of Performance

Date of Assessment

Refer to attached List of Essential/Critical Fire Safety Measures


Date of Certificate: Dated this 26th day of June, 2015.

Signature:

(owner/agent)

Service Provider: L P B Fire Services





LPB FIRE SERVICES PTY. LTD.

ABN 39 079 032 456

FIRE PROTECTION ENGINEERS Design - Consulting - Training

15 Farrell Road NSW Bass Hill 2197
POBox 7069 Bass Hill NSW 2197
Email: lpbfire@hotmail.com
Ph: (02) 9727 5215 Fax: (02) 9724 3842

John Billingham
Director
Mob: 0419 220 037

Nick Alejandro B.Eng.
Principal Design Engineer
Mob: 0434 690 712
Email: nick@lpbfire.com.au

**Wollemi College – Gipps Street
(Lot2 Water Street). Werrington**

Fire Safety Measure	Standard of Performance	Date of Assessment
Smoke Alarms	AS 3786.1993	13.06.15
Automatic Shutdown of Mechanical Ventilation System	BCA E2.2b/Spec.E2.2a	26.06.15
Fire Seals (protecting openings in fire resisting components of building)	BCA C3.15 & AS 4072.1	13.06.15
Emergency Lighting	BCA E4.2,E4.3,E4.4, AS 2293.1.1998	13.06.15
Exit Signs	BCA E4.5, E4.6, E4.8 & AS 2293.1.2005	13.06.15
Fire Doors	BCA C3.11 & AS 1905.1.2005	13.06.15
Fire Hose Hydrant System	BCA E1.3 & AS 2419.1.1994	13.06.15
Portable Fire Extinguishers	BCA E1.6 & AS 2444.2001	13.06.15
Fire Blankets	BCA E1.6AS/NZS 3504.1995	13.06.15

L P B Fire Services.

J. Billingham
J. Billingham

