

PENRITH CITY COUNCIL

NOTICE OF DETERMINATION

DESCRIPTION OF DEVELOPMENT

Application number:	DA18/0663.02
Description of development:	Section 4.55(1A) Modifications to Consent Conditions - Torrens Title Subdivision x 2 Lots & Construction of Eight (8) Single Storey Seniors Housing Dwellings
Classification of development:	Class 1a

DETAILS OF THE LAND TO BE DEVELOPED

Legal description:	Lot 1100 DP 1217686
Property address:	1 Leonay Parade, LEONAY NSW 2750

DETAILS OF THE APPLICANT

Name & Address:	Leonay Links Pty Ltd C/- Think Planners PO Box W287 PARRAMATTA NSW 2150
-----------------	---

DECISION OF CONSENT AUTHORITY

In accordance with Sections 4.18(1) (a) and 4.55 of the Environmental Planning and Assessment Act 1979, consent is granted subject to the conditions listed in attachment 1.

Please note that this consent will lapse on the expiry date unless the development has commenced in that time.

Date from which consent operates	9 July 2020
Date the consent expires	9 July 2025
Date of this decision	6 July 2020 as amended on 26 August 2020 under Section 4.55 of the Environmental Planning and Assessment Act.

POINT OF CONTACT

If you have any questions regarding this determination you should contact:

Assessing Officer:	Lauren Van Etten
Contact telephone number:	+612 4732 8222

NOTES

Reasons

The conditions in the attached schedule have been imposed in accordance with Section 4.17 of the Environmental Planning and Assessment Act 1979 as amended.

Conditions

Your attention is drawn to the attached conditions of consent in attachment 1.

Certification and advisory notes

You should also check if this type of development requires a construction certificate in addition to this development consent.

It is recommended that you read any Advisory Note enclosed with this notice of determination.

Review of determination

The applicant may request Council to review its determination pursuant to Division 8.2 of the Environmental Planning and Assessment Act 1979 within twelve months of receiving this Notice of Determination.

These provisions do not apply to designated development, complying development or crown development pursuant to Section 8.2(2) of the Environmental Planning and Assessment Act 1979.

Appeals in the Land and Environment Court

The applicant can appeal against this decision in the Land and Environment Court within twelve months of receiving this Notice of Determination.

There is no right of appeal to a decision of the Independent Planning Commission or matters relating to a complying development certificate pursuant to clause 8.6(3) of the Environmental Planning and Assessment Act 1979.

Designated development

If the application was for designated development and a written objection was made in respect to the application, the objector can appeal against this decision to the Land and Environment Court within 56 days after the date of this notice.

If the applicant appeals against this decision, objector(s) will be given a notice of the appeal and the objector(s) can apply to the Land and Environment Court within 56 days after the date of this appeal notice to attend the appeal and make submissions at that appeal.

Sydney Western City Planning Panels

If the application was decided by the Sydney Western City Planning Panel, please refer to Section 2.16 of the Environmental Planning and Assessment Act, 1979 (as amended) for any further regulations.

ATTACHMENT 1: CONDITIONS OF CONSENT

General

- 1 The development must be implemented substantially in accordance with the plan numbers tabled below and stamped approved by Council, the application form, BASIX Certificate No. 658431M, and the General Terms of Agreement issued by the Rural Fire Service dated 27 September 2019, and any supporting information received with the application, except as may be amended in red on the attached plans and by the following conditions.

The development is to be carried out in accordance with the requirements imposed on determination (listed in Schedule 2) of the Site Compatibility Certificate dated 22 June 2020, issued by the Sydney Western City Planning Panel for the development.

Drawing	Drawing Ref	Revision	Prepared By	Dated
Subdivision Plan	19110-C3	-	Vince Morgan	06-09-18
Site & Ground Floor Plan	A01	G	PreTech Pty Ltd	06-12-19
Elevations	A03	D	PreTech Pty Ltd	06-12-19
Elevations	A04	D	PreTech Pty Ltd	06-12-19
Stormwater Concept Design	SW301	A	SGC	10.9.18

2 **Prior to the issue of a Construction Certificate**, architectural and landscape plans are to be amended and are to be endorsed by the Manager of Development Services at Penrith City Council as follows:

- (a) To delete the formalised waste bin storage areas for all units and any related bin storage decking and bin screen walls.
- (b) Rainwater tanks are not positioned in front of window openings.
- (c) The north and south facing decks attached to the side elevations of Units 1, 2 and 3 are to be reduced in width (minimum 2m from boundary fencing) to allow side boundary plantings and to ensure privacy between units is protected.
- (d) The materials and finishes schedule is to be amended to detail that the proposed roofs of each dwelling are constructed of a light colour so as to reduce heat loading. The colour material of the roofs are to be nominated on plans.
- (e) A final set of landscape plans and documentation is to be submitted which details 'two for one' replacement tree planting, and which is to have had regard to the final endorsed arboricultural report, the requirements of Schedule 2 of the issued site compatibility certificate, and which correlates with other landscape related conditions of this consent.

All plans and documents are to correlate.

A final fencing layout plan is to be provided to and endorsed by Penrith City Council. A copy of the endorsed plans are to be provided to the Principal Certifying Authority **prior to the issue of a Construction Certificate**. The fencing layout plan is to include fencing materials, locations and heights and is to include details of protective netting or fencing between the golf course and the approved residential dwellings.

A final set of stormwater and civil design plans are to be provided to and endorsed by Penrith City Council **prior to the issue of a Construction Certificate**. Amended plans are to correlate with the final endorsed set of architectural and landscape plans.

As amended on 26 August 2020 under Section 4.55(1A) of the Environmental Planning and Assessment Act 1979.

3 The work must be carried out in accordance with the requirements of the Building Code of Australia. If the work relates to a residential building and is valued in excess of \$20,000, then a contract of insurance for the residential development shall be in force in accordance with Part 6 of the Home Building Act 1989.

{Note: Residential building includes alterations and additions to a dwelling, and structures associated with a dwelling house/dwelling such as a carport, garage, shed, rural shed, swimming pool and the like}.

4 **The development shall not be used or occupied until an Occupation Certificate has been issued.**

5 **Prior to the issue of an Occupation Certificate**, a lighting system shall be installed for the development to provide uniform lighting across common areas and driveways. Exterior lighting shall be located and directed in such a manner so as not to create a nuisance to surrounding land uses. The lighting shall be the minimum level of illumination necessary for safe operation. The lighting shall be in accordance with AS 4282 "Control of the obtrusive effects of outdoor lighting" (1997).

6 The finishes of all structures and buildings are to be maintained at all times and any graffiti or vandalism immediately removed/repaired.

7 **A Construction Certificate** shall be obtained prior to commencement of any building works.

8 Prior to the erection of any crane or any temporary construction structure at a height greater than the roof of the subject development, written notice shall be provided to Council and the Nepean Blue Mountains Local Health District at least 21 days prior to the erection, indicating at least the following:

- Name of responsible company and relevant contact details.
- Dimensions (height, length, etc.).
- Position and orientation of boom/jib and counterboom/jib.
- Length of time that such a crane or structure will be erected on site.
- The management plan and measures that will ensure that the crane or structure will be of least possible impact on flight operations for Ambulance NSW.

Any crane or any temporary construction structure erected at a height greater than the roof of the subject development shall comply with the following:

- Be equipped with medium intensity steady red lighting positioned at the highest point and both ends of the boom/jib and counterboom/jib, such that the lighting will provide an indication of the height of the crane and the radius of the crane boom/jib. Such lighting, which should be displayed at night, should be positioned so that when displayed it is visible from all directions.
- When a crane is unattended for an extended period of time ensure the crane's boom is retracted and lowered as far as possible.
- No part of the crane or structure shall extend beyond the boundaries of the subject development site unless approved by Penrith City Council in consultation with the Nepean Blue Mountains Local Health District. Any encroachment beyond the boundaries of the subject site shall be the minimum amount required to facilitate construction and access all parts of the construction site.

9 **Prior to the issue of a Construction Certificate**, a final materials and finishes schedule is to be submitted to and approved by Penrith City Council.

10 **Prior to the issue of an Occupation Certificate**, any golf course components made redundant by the subject application, or in close proximity to the proposed development, shall become inoperable.

11 In accordance with Clause 18 of State Environmental Planning Policy (Housing for Seniors or People with a Disability) 2004, a restriction as to user must be registered against the title of the property on which the development is to be carried out, in accordance with Section 88E of the *Conveyancing Act 1919*, limiting the use of any accommodation to which the development relates to the kinds of people referred to in subclause (1) of Clause 18. The restriction shall be registered on the land title **prior to the issue of an Occupation Certificate**.

12 **Prior to the issue of a Construction Certificate**, documentation shall be submitted to, and approved by, the principal certifying authority demonstrating compliance with the requirements of Schedule 3 of State Environmental Planning Policy (Housing for Seniors or People with a Disability) 2004.

13 In accordance with Clause 18 of State Environmental Planning Policy (Housing for Seniors or People with a Disability) 2004, the development can only be occupied by the following people:

- (a) seniors or people who have a disability,
- (b) people who live within the same household with seniors or people who have a disability.

As amended on 26 August 2020 under Section 4.55(1A) of the Environmental Planning and Assessment Act 1979.

14 **Prior to the issue of a Construction Certificate** the Certifying Authority shall ensure that the stormwater

plans are amended to include site specific cross-section details for each of the four raingardens including all levels (e.g. inlet, outlet, grates etc.).

Demolition

- 15 Any demolition works are to be conducted in accordance with the provisions of AS 2601-1991 "The Demolition of Structures". **Prior to demolition**, all services shall be suitably disconnected and capped off or sealed to the satisfaction of the relevant service authority requirements.

All demolition and excavated material shall be disposed of at a Council approved site or waste facility. Details of the proposed disposal location(s) of all excavated material from the development site shall be provided to the Principal Certifying Authority **prior to commencement of demolition**.

- 16 You should read Council's Fact Sheet titled "Handling and Disposal of Fibrous Cement Products" **before any demolition works commence on the site**.

Prior to commencement of demolition works on site, a portaloo with appropriate washing facilities shall be located on the site and the Principal Certifying Authority is to be satisfied that:

- Measures are in place so as to comply with the WorkCover Authority's "Short Guide to Working with Asbestos Cement" and
- The person employed to undertake the works is a licensed asbestos removal contractor and is holder of a current WorkCover Asbestos Licence.

Any demolition works involving the removal of all asbestos shall only be carried out by a licensed asbestos removal contractor who has a current WorkCover Asbestos Licence.

All asbestos laden waste, including asbestos cement flat and corrugated sheeting must be disposed of at a tipping facility licensed by the Environmental Protection Authority to receive asbestos wastes.

- 17 Dust suppression techniques are to be employed during demolition to reduce any potential nuisances to surrounding properties.

- 18 Mud and soil from vehicular movements to and from the site must not be deposited on the road.

- 19 Demolition works will be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm if inaudible on neighbouring residential premises, otherwise 8am to 1pm
- No demolition work is permitted on Sundays and Public Holidays.

In the event that the demolition relates to works inside the building and do not involve external walls or the roof, and do not involve the use of equipment that emits noise then the demolition works are not restricted to the hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

Heritage/Archaeological relics

- 20 If any archaeological relics are uncovered during the course of the work no further work shall be undertaken until further directed by Penrith City Council or the NSW Heritage Office.

The applicant is advised that depending on the possible significance of the relics, an archaeological assessment and an excavation permit under the Heritage Act, 1977 may be required before any further work can be recommenced in that area of the site.

Environmental Matters

- 21 Erosion and sediment control measures shall be installed **prior to the commencement of works on site** including approved clearing of site vegetation. The erosion and sediment control measures are to be maintained in accordance with the approved erosion and sediment control plan(s) for the development and the Department of Housing's "Managing Urban Stormwater: Soils and Construction" 2004.

- 22 No fill material is to be imported to the site without the prior approval of Penrith City Council in accordance with Sydney Regional Environmental Plan No.20 (Hawkesbury- Nepean River) (No.2-1997). No recycling of material for use as fill material shall be carried out on the site without the prior approval of Council.

- 23 All waste materials stored on-site are to be contained within a designated area such as a waste bay or bin to ensure that no waste materials are allowed to enter the stormwater system or neighbouring properties. The designated waste storage areas shall provide at least two waste bays / bins so as to allow for the separation of wastes, and are to be fully enclosed when the site is unattended.

- 24 All excavated material and other wastes generated as a result of the development are to be re-used, recycled or disposed of in accordance with the approved waste management plan.

Waste materials not specified in the approved waste management plan are to be disposed of at a lawful waste management facility. Where the disposal location or waste materials have not been identified in the waste management plan, details shall be provided to the Certifying Authority as part of the waste management documentation accompanying the Construction Certificate application.

All receipts and supporting documentation must be retained in order to verify lawful disposal of materials and are to be made available to Penrith City Council on request.

- 25 Noise levels from the premises shall not exceed the relevant noise criteria detailed in "Acoustic Assessment 1a Leonay Parade, Leonay NSW 2750" prepared by Envirotech dated 13th March 2019, reference number: REP-18-7068-A1. The recommendations provided in the above-mentioned acoustic report shall be implemented and incorporated into the design and construction of the development, and shall be shown on plans accompanying the Construction Certificate application. A certificate is to be obtained from a qualified acoustic consultant certifying that the building has been constructed to meet the noise criteria in accordance with the approved acoustic report. This certificate is to be submitted to the Principal Certifying Authority prior to the issue of an Occupation Certificate.

The provisions of the Protection of the Environment Operations Act 1997 apply to the development, in terms of regulating offensive noise.

- 26 Only clean and unpolluted water is to be discharged into Penrith City Council's stormwater drainage system. Liquid wastes suitable for discharge to the mains sewer are to be discharged in accordance with Sydney Water requirements.

If mains sewer is not available or if Sydney Water will not allow disposal to the sewer then a licensed waste contractor is to remove the liquid waste from the premises to an appropriate waste facility.

The waste contractor and waste facility are to hold the relevant licenses issued by the NSW Environment Protection Authority.

- 27 No fill material shall be imported to the site until such time as a Validation Certificate(with a copy of any report forming the basis for the validation) for the fill material has been submitted to Council. The Validation Certificate shall:
- state the legal property description of the fill material source site,
 - be prepared by an appropriately qualified person (as defined in Penrith Contaminated Land Development Control Plan) with consideration of all relevant guidelines (e.g. EPA, ANZECC, NH&MRC), standards, planning instruments and legislation,
 - clearly indicate the legal property description of the fill material source site,
 - provide details of the volume of fill material to be used in the filling operations,
 - provide a classification of the fill material to be imported to the site in accordance with the Environment Protection Authority's "Environmental Guidelines: Assessment, Classification & Management of Non-Liquid Wastes" 1997, and
 - (based on the fill classification) determine whether the fill material is suitable for its intended purpose and land use and whether the fill material will or will not pose an unacceptable risk to human health or the environment.

An appropriately qualified person/s (as defined in the Penrith City Council Contaminated Land Development Control Plan) shall:

- Supervise the filling works,
- (On completion of filling works) carry out an independent review of all documentation relating to the filling of the site, and shall submit a review findings report to Council and any Principal Certifying Authority,
- Certify by way of a Compliance Certificate or other written documentation that fill materials have been placed on the site in accordance with all conditions of this consent and that the site will not pose an unacceptable risk to human health or the environment. A copy of the Compliance Certificate or other documentation shall be submitted to Council and any Principal Certifying Authority.

The contact details of any appropriately qualified person/s engaged for the works shall be provided with the Notice of Commencement.

If the Principal Certifying Authority or Penrith City Council is not satisfied that suitable fill materials have been used on the site, further site investigations or remediation works may be requested. In these circumstances the works shall be carried out prior to any further approved works.

{Note: Penrith Contaminated Land Development Control Plan defines an appropriately qualified person as "a person who, in the opinion of Council, has a demonstrated experience, or access to experience in hydrology, environmental chemistry, soilscience, eco-toxicology, sampling and analytical procedures, risk evaluation and remediation technologies. In addition, the person will be required to have appropriate professional indemnity and public risk insurance."}

- 28 Should any "unexpected finds" occur during site excavation and earthworks including, but not limited to, the

identification/ finding of contaminated soils, buried building materials, asbestos, odour and/or staining, works are to cease immediately and Council notified. Any such "unexpected finds" shall be addressed by an appropriately qualified environmental consultant.

All remediation works within the Penrith Local Government Area are considered to be Category 1 works under the State Environmental Planning Policy 55-Remediation of Land. Should any contamination be found during development works and should remediation be required, development consent is to be sought from Penrith City Council before the remediation works commence.

BCA Issues

- 29 All aspects of the building design shall comply with the applicable performance requirements of the Building Code of Australia so as to achieve and maintain acceptable standards of structural sufficiency, safety (including fire safety), health and amenity for the on-going benefit of the community. Compliance with the performance requirements can only be achieved by:
- (a) complying with the deemed to satisfy provisions, or
 - (b) formulating an alternative solution which:
 - complies with the performance requirements, or
 - is shown to be at least equivalent to the deemed to satisfy provision, or
 - (c) a combination of (a) and (b).
- 30 Access and sanitary facilities for persons with disabilities are to be provided and maintained in accordance with the requirements of the Building Code of Australia and AS 1428 "Design for Access and Mobility". Details of compliance are to be provided in the relevant plans and specifications accompanying the Construction Certificate application.
- 31 The external walls of the building including attachments must comply with the relevant requirements of the National Construction Code (NCC). Prior to the issue of a Construction Certificate and Occupation Certificate the Certifying Authority and Principal Certifying Authority must:
- (a) Be satisfied that suitable evidence is provided to demonstrate that the products and systems proposed for use or used in the construction of external walls including finishes and claddings such as synthetic or aluminium composite panels comply with the relevant requirements of the NCC; and
 - (b) Ensure that the documentation relied upon in the approval processes include an appropriate level of detail to demonstrate compliance with the NCC as proposed and as built.
- 32 **Prior to the issue of a Construction Certificate**, an Accessibility Report shall be submitted to and approved by Council. The report shall detail the development's compliance with the Building Code of Australia, Disability (Access to Premises - Buildings) Standards 2010, AS 1428 and AS 4299 and any relevant requirements of Schedule 3 of State Environmental Planning Policy (Housing for Seniors or People with a Disability) 2004.

Utility Services

- 33 A Section 73 Compliance Certificate under the Sydney Water Act 1994 shall be obtained from Sydney Water. The application must be made through an authorised Water Servicing Coordinator. Please refer to “Your Business” section of Sydney Water’s website at www.sydneywater.com.au then the “e-developer” icon, or telephone 13 20 92.

The Section 73 Compliance Certificate must be submitted to the Principal Certifying Authority **prior to the issue of an Occupation Certificate.**

- 34 Prior to the issue of a Construction Certificate, a written clearance is to be obtained from Endeavour Energy stating that electrical services have been made available to the development or that arrangements have been entered into for the provision of services to the development.

In the event that a pad mounted substation is necessary to service the development, Penrith City Council shall be consulted over the proposed location of the substation before the Construction Certificate for the development is issued as the location of the substation may impact on other services and building, driveway or landscape design already approved by Council.

- 35 **Prior to the issue of a Construction Certificate**, the Principal Certifying Authority shall be satisfied that telecommunications infrastructure may be installed to service the premises which complies with the following:
- The requirements of the Telecommunications Act 1997;
 - For a fibre ready facility, the NBN Co’s standard specifications current at the time of installation; and
 - For a line that is to connect a lot to telecommunications infrastructure external to the premises, the line shall be located underground.

Unless otherwise stipulated by telecommunications legislation at the time of construction, the development must be provided with all necessary pits and pipes, and conduits to accommodate the future connection of optic fibre technology telecommunications.

Prior to the issue of an Occupation Certificate, written certification from all relevant service providers that the telecommunications infrastructure is installed in accordance with the requirements above and the applicable legislation at the time of construction, must be submitted to the Principal Certifying Authority.

Construction

36 Stamped plans, specifications, a copy of the development consent, the Construction Certificate and any other Certificates to be relied upon shall be available on site at all times during construction.

The following details are to be displayed in a maximum of 2 signs to be erected on the site:

- the name of the Principal Certifying Authority, their address and telephone number,
- the name of the person in charge of the work site and telephone number at which that person may be contacted during work hours,
- that unauthorised entry to the work site is prohibited,
- the designated waste storage area must be covered when the site is unattended, and
- all sediment and erosion control measures shall be fully maintained until completion of the construction phase.

Signage but no more than 2 signs stating the above details are to be erected:

- at the commencement of, and for the full length of the, construction works onsite, and
- in a prominent position on the work site and in a manner that can be easily read by pedestrian traffic.

All construction signage is to be removed when the Occupation Certificate has been issued for the development.

37 Prior to the commencement of construction works:

(a) Toilet facilities at or in the vicinity of the work site shall be provided at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:

- a standard flushing toilet connected to a public sewer, or
- if that is not practicable, an accredited sewage management facility approved by the council, or
- alternatively, any other sewage management facility approved by council.

(b) All excavations and backfilling associated with the erection or demolition of a building must be executed safely and in accordance with the appropriate professional standards. All excavations associated with the erection or demolition of a building must be properly guarded and protected to prevent them from being dangerous to life or property.

(c) If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation to be made:

- must preserve and protect the building from damage, and
- if necessary, must underpin and support the building in an approved manner, and
- must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished. The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this condition, whether carried out on the allotment of land being excavated or on the adjoining allotment of land, (includes a public road and any other public place).

(d) If the work involved in the erection or demolition of a building is likely to cause pedestrian or vehicular traffic in a public place to be obstructed or rendered inconvenient, or involves the enclosure of a public place, a hoarding or fence must be erected between the work site and the public place:

- if necessary, an awning is to be erected, sufficient to prevent any substance from, or in connection with, the work falling into the public place,
- the work site must be kept lit between sunset and sunrise if it is likely to be hazardous to persons in the public place, and
- any such hoarding, fence or awning is to be removed when the work has been completed.

38 Clothes drying facilities are to be positioned and screened from public view.

39 The catchment area (for the rainwater tank) includes the parts of the roof of the dwelling(s) from which water is collected and includes gutters. To ensure a safe supply of water:

- roof catchment areas must be kept clear of overhanging vegetation,
- gutters must have sufficient fall to downpipes to prevent pooling of water,
- overflow, discharge from bleed off pipes from roof mounted appliances such as airconditioners, hot water services and solar heaters must not discharge into the rainwater catchment area,
- for roofs containing lead based, tar based or asbestos material the tank supply must not be connected to drinking, bathing and gardening tap water outlets,
- appropriate measures must be installed to prevent foreign materials from contaminating the water which enters the rainwater tank.

40 The rainwater tank supply must not be connected to drinking and bathing water tap outlets.

41 The rainwater tank pump must not exceed 5dBA above ambient background noise level at the nearest residential property boundary. The provisions of the Protection of the Environment Operations Act 1997 apply to the development, in terms of regulating offensive noise.

42 Construction works or subdivision works that are carried out in accordance with an approved consent that involve the use of heavy vehicles, heavy machinery and other equipment likely to cause offence to adjoining properties shall be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm (if inaudible on neighbouring residential premises), otherwise 8am to 1pm
- No work is permitted on Sundays and Public Holidays.

Other construction works carried out inside a building/tenancy and do not involve the use of equipment that emits noise are not restricted to the construction hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

Engineering

43 All roadworks, stormwater drainage works, associated civil works and dedications, required to effect the consented development shall be undertaken at no cost to Penrith City Council.

44 An Infrastructure Restoration Bond is to be lodged with Penrith City Council for development involving works around Penrith City Council's Public Infrastructure Assets. The bond is to be lodged with Penrith City Council prior to commencement of any works on site or prior to the issue of any Construction Certificate, whichever occurs first. The bond and applicable fees are in accordance with Council's adopted Fees and Charges.

An application form together with an information sheet and conditions are available on Council's website.

Contact Penrith City Council's City Works Department on (02) 4732 7777 or visit Penrith City Council's website for more information.

45 Prior to the issue of any Construction Certificate, a Section 138 Roads Act applications, including payment of application and inspection fees, shall be lodged and approved by Penrith City Council (being the Roads Authority for any works required in a public road). These works may include but are not limited to the following:

- a) Vehicular crossings (including kerb reinstatement of redundant vehicular crossings)
- b) Concrete footpaths and or cycleways
- c) Road opening for utilities and stormwater (including stormwater connection to Penrith City Council roads and other Penrith City Council owned drainage)
- d) Road occupancy or road closures
- e) The placement of hoardings, structures, containers, waste skips, signs etc. in the road reserve
- f) Temporary construction access

All works shall be carried out in accordance with the Roads Act approval, the development consent, including the stamped approved plans, and Penrith City Council's specifications, guidelines and best engineering practice.

Contact Penrith City Council's City Works Department on (02) 4732 7777 or visit Penrith City Council's website for more information.

Note:

- a) Where Penrith City Council is the Certifying Authority for the development, the Roads Act approval for the above works may be issued concurrently with the Construction Certificate.
- b) Separate approvals may also be required from the Roads and Maritime Services for classified roads.
- c) All works associated with the Roads Act approval must be completed prior to the issue of any Occupation Certificate or Subdivision Certificate as applicable.
- d) On completion of any awning over the road reserve, a certificate from a practising structural engineer certifying the structural adequacy of the awning is to be submitted to Council before Council will inspect the works and issue its final approval under the Roads Act

46

The stormwater management system shall be provided generally in accordance with the concept plan/s lodged for development approval, prepared by SGC Consulting Engineers reference 20180063, drawings SW100 to SW402 revision A dated 10 September 2018 **as amended in red**.

Engineering plans and supporting calculations for the stormwater management systems are to be prepared by a suitably qualified person and shall accompany the application for a Construction Certificate.

Prior to the issue of a Construction Certificate the Certifying Authority shall ensure that the stormwater management system has been designed in accordance with Council's Stormwater Drainage for Building Developments and Water Sensitive Urban Design Policy.

- 47 The stormwater management system shall be provided generally in accordance with the concept plan/s lodged for development approval, prepared by SGC, reference number 20180063 - SW100-SW402, revision A, dated 10.09.2018.

Engineering plans and supporting calculations for the stormwater management systems are to be prepared by a suitably qualified person and shall accompany the application for a Construction Certificate.

Prior to the issue of any Construction Certificate, the Certifying Authority shall ensure that the stormwater management system has been designed in accordance with Penrith City Council's Stormwater Drainage for Building Developments and Water Sensitive Urban Design (WSUD) policies.

- 48 Prior to the issue of any Construction Certificate, the Certifying Authority shall ensure that vehicular access, circulation, manoeuvring, pedestrian and parking areas associated with the subject development are in accordance with AS 2890.1, AS2890.2, AS2890.6 and Penrith City Council's Development Control Plan.
- 49 Prior to commencement of works sediment and erosion control measures shall be installed in accordance with the approved Construction Certificate and to ensure compliance with the Protection of the Environment Operations Act 1997.

The erosion and sediment control measures shall remain in place and be maintained until all disturbed areas have been rehabilitated and stabilised.

- 50 Upon completion of all works in the road reserve, all verge areas fronting and within the development are to be turfed. The turf shall extend from the back of kerb to the property boundary, with the exception of concrete footpaths, service lids or other infrastructure which is not to be turfed over. Turf laid up to concrete

footpaths, service lids or other infrastructure shall finish flush with the edge.

- 51 All existing (aerial) and proposed services for the development, including those across the frontage of the development are to be located or relocated underground in accordance with the relevant authorities regulations and standards.
- 52 Prior to the issue of any Occupation Certificate, works-as-executed drawings, final operation and maintenance management plans and any other compliance documentation shall be submitted to the Principal Certifying Authority in accordance with Penrith City Council's Engineering Construction Specification for Civil Works, WSUD Technical Guidelines and Stormwater Drainage for Building Developments Policy.

An original set of works-as-executed drawings and copies of the final operation and maintenance management plans and compliance documentation shall also be submitted to Penrith City Council with notification of the issue of the Occupation Certificate where Penrith City Council is not the Principal Certifying Authority.

As amended on 26 August 2020 under Section 4.55(1A) of the Environmental Planning and Assessment Act 1979.

- 53 Prior to the issue of any Occupation Certificate, the Principal Certifying Authority shall ensure that the:
- a) Stormwater management systems (water sensitive urban design)
- Have been satisfactorily completed in accordance with the approved Construction Certificate and the requirements of this consent.
 - Have met the design intent with regard to any construction variations to the approved design.
 - Any remedial works required to been undertaken have been satisfactorily completed.

Details of the approved and constructed system/s shall be provided as part of the works-as-executed drawings.

As amended on 26 August 2020 under Section 4.55(1A) of the Environmental Planning and Assessment Act 1979.

- 54 Prior to the issue of any Occupation Certificate, a restriction as to user and positive covenant relating to the:
- a) Stormwater management systems (Water sensitive urban design)

Shall be registered on the title of the property. The restriction as to user and positive covenant shall be in Penrith City Council's standard wording as detailed in Penrith City Council's Stormwater Drainage Specification for Building Development – Appendix F.

- 55 The stormwater management systems shall continue to be operated and maintained in perpetuity for the life of the development in accordance with the final operation and maintenance management plan.

Regular inspection records are required to be maintained and made available to Penrith City Council on request. All necessary improvements are required to be made immediately upon awareness of any deficiencies in the stormwater management systems.

- 56 **Prior to the issue of an Occupation Certificate** the Principal Certifying Authority is to ensure that the plans, including landscaping plans, comply with the requirements set out in AS 2890.1 Figure 3.2 - Sight

Distance Requirements at Access Driveways and Figure 3.3 - Minimum Sight Lines for Pedestrian Safety.

- 57 Prior to the issue of any Construction Certificate the Certifying Authority shall ensure that a S138 Roads Act application, including the payment of application and inspection fees, has been lodged with, and approved by Penrith City Council (being the Roads Authority under the Roads Act), for provision of path paving works on the western side of Leonay Parade.

Engineering plans are to be prepared in accordance with the development consent, Penrith City Council's Design Guidelines for Engineering Works for Subdivisions and Developments, Engineering Construction Specification for Civil Works, Austroads Guidelines and best engineering practice.

Contact Penrith City Council's Development Engineering Department on 4732 7777 or visit Penrith City Council's website for more information.

Note: Where Penrith City Council is the Certifying Authority for the development the Roads Act approval for the above works may be issued concurrently with the Construction Certificate. Separate Approvals may also be required from the Roads and Maritime Service for classified roads.

All works associated with the Roads Act approval must be completed prior to the issue of any Occupation Certificate or Subdivision Certificate as applicable.

- 58 **Prior to the issue of any Occupation Certificate** and in accordance with the requirements of the State Environmental Planning Policy (Housing for Seniors or People with a Disability) 2004 for a suitable access pathway, Principal Certifying Authority is to ensure that a 1.5 metre wide concrete footpath, with maximum cross fall of 2.5% is installed and completed, along Leonay Parade across the frontage of the site spanning to the nearest bus stop with shelter, close to the Emu Plains Sporting & Recreation Club entry, and that a 1.5m wide concrete footpath, with maximum cross fall of 2.5% is installed and completed, in accordance with Council's civil specifications, which spans from the western side of the existing pedestrian crossing (south of the site) to the southern end of paving across the site's frontage.

Suitable documentation is to be provided to the PCA confirming that the paving is generally compliant with the overall average gradients specified in State Environmental Planning Policy (Housing for Seniors or People with a Disability) 2004.

Landscaping

- 59 Prior to the issue of a Construction Certificate a revised Arborist statement is to be prepared by a suitably qualified and experienced landscape professional shall be submitted to, and approved by, Council. This statement shall detail which trees are to be retained and removed, the impacts and how impacts will be managed, and be consistent with the revised tree retention plan and revised landscape plan required as a condition of this consent.

- 60 All landscape works are to be constructed in accordance with Appendix F5, Section 2.9 Landscape Technical Specifications of the Penrith Development Control Plan 2014.

Landscaping shall be maintained:

- in accordance with the approved plan, and
- in a healthy state, and in perpetuity by the existing or future owners and occupiers of the property.

If any of the vegetation comprising that landscaping dies or is removed, it is to be replaced with vegetation of the same species and, to the greatest extent practicable, the same maturity as the vegetation which died or was removed.

- 61 The approved landscaping for the site must be constructed by a suitably qualified and experienced landscape professional.
- 62 The following series of reports relating to landscaping are to be submitted to the nominated consent authority at the appropriate time periods as listed below. These reports shall be prepared by a suitably qualified and experienced landscape professional.

i. Implementation Report

Upon completion of the landscape works associated with the development and prior to the issue of an Occupation Certificate for the development, an Implementation Report must be submitted to the Principal Certifying Authority attesting to the satisfactory completion of the landscaping works for the development. The report is to be prepared by a suitably qualified and experienced landscape professional.

An Occupation Certificate should not be issued until such time as a satisfactory Implementation Report has been received. If Penrith City Council is not the Principal Certifying Authority, a copy of the satisfactory Implementation Report is to be submitted to Council together with the Occupation Certificate for the development.

ii. Maintenance Report

On the first anniversary of the date of the Occupation Certificate issued for the development, a Landscape Maintenance Report is to be submitted to Penrith City Council certifying that the landscape works are still in accordance with the development consent and the plant material is alive and thriving.

This report is to be prepared by a suitably qualified and experienced landscape professional.

iii. 3 Year Landscaping Report

Three years after an Occupation Certificate was issued for the development, a suitably qualified and experienced landscape professional. shall prepare a Landscaping Report for Council's consideration and approval, certifying to one of the following:

- (a) The landscaping on site has matured and is in accordance with the original landscape approval.
- (b) The landscaping on site has not matured in accordance with the original design philosophy and requires significant restoration.

In this case, restoration plans are to be submitted to Council for its consideration and approval. The approved plans shall be implemented at the expense of the property owners.

- 63 All plant material associated with the construction of approved landscaping is to be planted in accordance with Appendix F5, Landscape Technical Specifications of the Penrith Development Control Plan 2014.
- 64 All landscape works are to meet industry best practice and the following relevant Australian Standards:

- AS 4419 Soils for Landscaping and Garden Use,
- AS 4454 Composts, Soil Conditioners and Mulches, and
- AS 4373 Pruning of Amenity Trees.

65 All trees that are required to be retained as part of the development are to be protected in accordance with the minimum tree protection standards prescribed in Council's Development Control Plan 2014 and Australian Standards, Protection of trees on development sites, AS 4970 -2009.

66 Prior to the issue of an Occupation Certificate, an ongoing Tree Management Plan (TMP) shall be submitted. The TMP shall detail how the retained trees on the site will be managed and cared for in the long-term. The recommendations of the TMP shall be implemented in perpetuity

67 **Prior to the issue of a Construction Certificate**, a Landscape Design Report, a Tree Replacement and Retention Plan and a Fencing Plan shall be submitted to, and approved by the Manager of Development Services at Penrith City Council.

The Report and Plan are to be prepared by a suitably qualified and experienced landscape professional and must include the retention of trees and is to ensure an increase in native planting diversity from the following suggestions: *Melaleuca bracteata* revolution green/gold, *Angophora floribunda* or *Acacia melanoxylon*. The landscape design must identify retained trees and their species, and shall ensure that more trees are being planted than are being removed. Trees planted are to be a minimum 75L pot size and are to be planted **prior to the issue of the Occupation Certificate**. Plans must include details of all perimeter fencing to be installed. Fencing must respond to the interface between the seniors development and the golf club uses. Any fencing forward of the front building alignment shall be in accordance with Council's requirements for fences within Section D2.5.18 of the DCP 2014. In addition, mail box design is to be submitted on the landscape plans.

The revised plans and reports shall be consistent with each other and also correlate with the revised arborist's and stormwater report. All plant species shall be clearly nominated.

Subdivision

68 **Prior to the issue of the Subdivision Certificate**, the following is to be submitted:

An original plan of subdivision and two (2) copies of the plan. The plan of subdivision must indicate, where relevant -

- All drainage easements, rights of way, restrictions and covenants.
- All proposed dedications of roads/drainage/public reserve, which are to be undertaken at no cost to Penrith City Council.

The following information is to be shown on one (1) copy of the plan.

- The location of all buildings and/or other permanent improvements shall comply with any statutory boundary clearances or setbacks as defined by the Building Code of Australia and Council's resolutions.
- All existing services are wholly contained within the lot served and/or covered by an appropriate easement.

Prior to lodgement of the Subdivision Certificate Application, street address numbering must be obtained/approved by Penrith City Council's Rates Team. Proposed street addresses can be forwarded to council@penrith.city for approval.

69 A Surveyors Certificate is to be lodged with the application for a Subdivision Certificate that certifies that all pipes and services are located wholly within the property or within appropriate easements and that no services encroach boundaries.

Section 94

70 This condition is imposed in accordance with Penrith City Council's Section 7.11 Contributions Plan for Local Open Space. Based on the current rates detailed in the accompanying schedule attached to this Notice, \$8,652.00 is to be paid to Council prior to a Construction Certificate being issued for this development (the rates are subject to quarterly reviews). If not paid within the current quarterly period, this contribution will be reviewed at the time of payment in accordance with the adopted Section 7.11 plan. The projected rates of this contribution amount are listed in Council's Fees and Charges Schedule.

Council should be contacted prior to payment to ascertain the rate for the current quarterly period. The Section 7.11 invoice accompanying this consent should accompany the contribution payment. The Section 7.11 Contributions Plan for Local Open Space may be inspected at Council's Civic Centre, 601 High Street, Penrith.

Note: The timing of contributions payable may be otherwise affected in accordance with Planning Circular PS20-003 dated 3 July 2020 and the associated NSW Government Ministerial Direction - Infrastructure Contributions.

- 71 This condition is imposed in accordance with Penrith City Council's Section 7.11 Contributions Plan for District Open Space. Based on the current rates detailed in the accompanying schedule attached to this Notice, \$23,928.00 is to be paid to Council prior to a Construction Certificate being issued for this development (the rates are subject to quarterly reviews). If not paid within the current quarterly period, this contribution will be reviewed at the time of payment in accordance with the adopted Section 7.11 plan. The projected rates of this contribution amount are listed in Council's Fees and Charges Schedule.

Council should be contacted prior to payment to ascertain the rate for the current quarterly period. The Section 7.11 invoice accompanying this consent should accompany the contribution payment. The Section 7.11 Contributions Plan for District Open Space may be inspected at Council's Civic Centre, 601 High Street, Penrith.

Note: The timing of contributions payable may be otherwise affected in accordance with Planning Circular PS20-003 dated 3 July 2020 and the associated NSW Government Ministerial Direction - Infrastructure Contributions.

Payment of Fees

- 72 All roadworks, dedications and drainage works are to be carried out at the applicant's cost.
- 73 Prior to the commencement of any works on site, all fees associated with Penrith City Council-owned land and infrastructure shall be paid to Council. These fees include Road Opening fees and Infrastructure Restoration fees.

Certification

- 74 A Subdivision Certificate is to be obtained prior to the release of the linen plan of subdivision. The Subdivision Certificate will not be issued if any of the conditions in this consent are outstanding.
- 75 Prior to the commencement of any earthworks or construction works on site, the proponent is to:
- (a) employ a Principal Certifying Authority to oversee that the said works carried out on the site are in accordance with the development consent and related Construction Certificate issued for the approved development, and with the relevant provisions of the Environmental Planning and Assessment Act and accompanying Regulation, and
 - (b) submit a Notice of Commencement to Penrith City Council.

The Principal Certifying Authority shall submit to Council an "Appointment of Principal Certifying Authority" in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

Information to accompany the Notice of Commencement

Two (2) days before any earthworks or construction/demolition works are to commence on site (including the clearing site vegetation), the proponent shall submit a "Notice of Commencement" to Council in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

- 76 An Occupation Certificate is to be obtained from the Principal Certifying Authority on completion of all works and prior to the occupation/use of the buildings.

The Certificate shall not be issued if any conditions of this consent, but not the conditions relating to the operation of the development, are outstanding.

A copy of the Occupation Certificate and all necessary documentation supporting the issue of the Certificate is to be submitted to Penrith City Council, if Council is not the Principal Certifying Authority.

SIGNATURE

Name:	Lauren Van Etten
Signature:	

For the Development Services Manager