



Date: 12.02.2016

**PENRITH CITY COUNCIL, JOAN SUTHERLAND
PERFORMING ARTS CENTRE
SOLAR PANEL ARRAY ON ROOF**

The existing roof structure of the Joan Sutherland Performing Arts Centre has been inspected and assessed to support a permanent superimposed load of up to 0.25 kPa and wind loads from the proposed layout of solar panel.

THIS IS TO CERTIFY that the existing roof structure is adequate for the proposed layout of solar panels and associated structure, to be installed as per the photovoltaic design drawings.

This certification excludes the proprietary solar panel frame and mounting system and associated fixings to the existing roof.

This certification shall not be construed as relieving any other party of their responsibilities, liabilities or contractual obligations.

Mikhail Kogan

Senior Structural Engineer
Structural & Civil Engineering Section
Government Architect's Office
A Division of the Department of Finance, Services & Innovation