DA Number	DA18/0132
LGA	Penrith City Council
Proposed Development	Demolition of Existing Structures and Construction of a Five (5) Storey Residential Flat Building Containing 17 x Apartments & Basement Car Parking
Street Address	29 – 31 Castlereagh Street Penrith
Applicant	CAD Plans Pty Ltd
Owner	BB & B Penrith Pty Ltd
Date of DA Lodgement	14 February 2018
Local Planning Panel Criteria	Residential Flat Building under the Provisions of State Environmental Planning Policy No. 65 – Design Quality of Residential Apartment Development
Addendum Report Author	Lauren van Etten, Development Assessment Planner, Penrith City Council
Addendum Report Date	15 October, 2019

Assessment Report Addendum

Background

This report provides an addendum to the previous Assessment Report prepared by Council officers dated 5 September, 2019, and follow up memorandum to the Penrith Local Planning Panel on the 11 September, 2019 with respect to the above matter.

On the 11 September 2019, Development Application DA18/0132 was reported to a Penrith Local Planning Panel meeting for determination. The application included a recommendation for approval subject to recommended conditions of consent. The assessment report acknowledged that the proposal was non-compliant with waste management provisions within the DCP, that Council's waste management team did not support the proposal and that as the development could not be serviced by Council's contracted waste service the proposal was recommended to be serviced through private contract.

A separate memorandum was however tabled with the Panel following continued discussions with Council's Waste Officer. This memorandum outlined the potential for servicing by Council subject to amendments to the plans and continued discussions with Council's Waste Management Team.

In response to the supplementary memorandum and a suggested for the matter to be deferred, the Panel unanimously agreed to defer determination of the application for further information to be provided and amendments to be made to the built form. The requested amendments related in part to resolution of waste management measures but also sought increased side boundary setbacks to achieve greater spatial separation between the built form on the southern adjoining site, noting that both sites are located within a heritage conservation area pursuant to Penrith Local Environmental Plan 2010.

The resolution of the Panel provided for the following amendments to be made:-

- Further amendment to the development to achieve a compliant 6.0m side southern boundary setback for the first 15m into the site as measured from the front property boundary;
- Further amendment of Unit 2 to accommodate an acceptable waste and bulky waste storage area similar to what is reflected within the concept plan supporting the above memorandum;
- Revision to the private open space for Unit 2 as indicated within the concept plan to provide built form / landscape separation to the proposed waste storage facilities and useable private open space areas for the use of the future residents of Unit 2:
- Amendment to the landscape plan to reflect the above design changes including paths of access from the kerb line to the waste storage areas. This includes deletion of front boundary fencing as indicated within the current architectural plans and embellished planting within the southern boundary setback zone:
- Deletion of the footpath within the southern side boundary setback zone
- Amendment to the civil design drawings to reflect the design changes referenced above;
- Submission of an amended BASIX Certificate that reflects the amended development resulting from the above requirements.

Following the Local Planning Panel Meeting, further discussions have been undertaken with Council's Waste Management Team and amendments have been made by the applicant to respond, in part, to the outcomes of those discussions. This additional addendum report provides information on the further modifications made to the application following Penrith Local Planning Panel meeting on the 11 September 2019.

Resolution of Waste Management Measures and Servicing

As addressed within the previous assessment report, there were three (3) primary matters that Council's Waste Management Team raised as reasons not to support the development application. These were:-

- The proposal did not provide chute systems on each floor
- The proposal did not provide an on-site waste storage and servicing arrangement that could accommodate Council's contracted vehicle;
- Where on site waste servicing cannot be provided, consideration to an indented bay may be considered however kerb side collection in the road is not permitted.

As a result of recommended amendments being made to the ground floor to provide suitable storage dimensions for waste bins and bulky waste, the requirement for chutes is no longer considered to be warranted due to the moderate scale of the development being only 17 dwellings.

As a consequence of further meetings, it has been agreed that the site dimensions cannot accommodate on site collection from Council's contracted waste service and an alternate arrangement is both necessary, and available, within Council's adopted Waste Management

Guideline.

It has been agreed that an indented bay is the only available option to achieve acceptable waste servicing through Council's waste collection service and the provision of an indented bay has been accepted by Council's Waste Management Team as indicated on the amended plans attached to this addendum report.

While the provision of an indented bay is not ideal, this is the only available servicing option. The bay measuring 22.5m can be measured from the outer edge of the driveway effectively reducing the additional hard stand implications to the streetscape. Diagrammatically this does not extend significantly into the site as the bay must be 2.5m in width as measured from the kerb line into the verge. This would necessitate consideration of services in the verge and realignment of the pedestrian footpath. An amended ground floor plan has incorporated this bay.

Further to this, opportunities exist for tree and compensatory planting within the site to address the resulting absence of street trees as consequence of the required indented bay. This aspect is further addressed below.

In addition, Councils Traffic Engineering Coordinator has considered the location of the proposed bay and raised no objection to its construction having regard to its proximity to the nearby intersection on the functionality of the local road network.

Proposed Design Amendments to the Built Form

Below is further consideration of the individual matters resolved to be addressed by the Panel and the amended plans subsequently submitted:-

 a) Further amendment to the development to achieve a compliant 6.0m side southern boundary setback for the first 15m into the site as measured from the front property boundary;

Comments in Response:

It is understood that the intention of the requested amendment was to provide suitable spatial separation between the existing built form on the adjacent southern site and the proposed built form which can accommodate suitable landscaping works within the resulting setback zone. While the Planning Panel has stipulated a 6.0m setback measured 15m from the front property boundary, discussions with the applicant culminated in the consideration of minor departures from these dimensional requirements where the intention of the resolution can still be met.

Amended architectural plans have provided which provide for an increased southern boundary side setback from 3.0m to a minimum of 5.0m which is noted as being 1.0m less than the resolution requirement. The southern boundary is irregular in alignment and as such the impacts of the minor departure from the 6.0m resolution is not considered to undermine the intent of the resolution, or compromise landscaping opportunities in the setback zone that is better reflective of the heritage conservation character of the area.

In addition to the 1.0m setback departure to the terms of resolution, the depth of the setback is also marginally less than the requested 15m as measured from the front property boundary. The applicant has provided for a 13m depth to the increased setback however in preparing the amendments, it has been found that 13m is approximately half of the side boundary length and 13m rather than 15m is not considered to detrimentally impact on the design of Unit 3.

In further support of the minor departures to the terms of the resolution, the ground floor studio unit (Unit 2) would be insufficient in size and furniture arrangement and would require reduction / deletion. The necessary additional amendments to the waste storage area to achieve compliant storage dimensions would reduce the size of this studio even more.

If a unit is retained in this location, it must be suitably sized and dimensioned to be functional and enable furniture and suitable circulation. Considering this and in the interest of maintaining a residential street address / façade at the ground floor in combination with requested waste storage arrangements, a reduced side setback of 5.0m for a 13m depth length is considered to be supportable and is considered to still meet the intent of the Panel's resolution.

b) Further amendment of Unit 2 to accommodate an acceptable waste and bulky waste storage area similar to what is reflected within the concept plan supporting the above memorandum.

Comments in Response:

The size and configuration of the waste collection area now includes internal dimensions of 3.2m wide and 5.4m deep which is in accordance with section 3.5.2 of the 'residential flat building waste management guideline' document. Address of waste collection arrangements has been previously addressed within this report.

c) Revision to the private open space for Unit 2 as indicated within the concept plan to provide built form / landscape separation to the proposed waste storage facilities and useable private open space areas for the use of the future residents of Unit 2;

Comments in Response:

The private open space area associated with Unit 2 was re-located and reconfigured from within the front setback to the southern side setback. This enables greater planting opportunities in the front setback to compensate for the street tree loss and verge treatment resulting for the waste collection bay while also enhancing the amenity and usability of the open space associated with Unit 2 which is now substantially separated from the waste storage area.

d) Amendment to the landscape plan to reflect the above design changes including paths of access from the kerb line to the waste storage areas. This includes deletion of front boundary fencing as indicated within the current architectural plans and embellished planting within the southern boundary setback zone;

Comments in Response:

While the landscape plans have not yet been amended as yet, it was considered reasonable that a position on the architectural amendments and spatial arrangement of the built form be made first with a recommended deferred commencement condition of consent for the built form changes to be incorporated within amended landscape plans. These would be required to be submitted to Council for approval prior to the issue of an operational consent.

e) Deletion of the footpath within the southern side boundary setback zone Amendment to the civil design drawings to reflect the design changes referenced above;

Comments in Response:

While the civil design plans have not yet been amended as yet, it was considered reasonable that a position on the architectural amendments and spatial arrangement of the built form be made first with a recommended deferred commencement condition of consent for the built form changes to be incorporated within amended civil design plans. These would be required to be submitted to Council for approval prior to the issue of an operational consent.

f) Submission of an amended BASIX Certificate that reflects the amended development resulting from the above requirements.

Comments in Response:

While a revised BASIX Certificate has not yet been submitted, it was considered reasonable that a position on the architectural amendments and spatial arrangement of the built form be made first with a recommended deferred commencement condition of consent for the built form changes to be incorporated within an amended BASIX Certificate. This would be required to be submitted to Council for approval prior to the issue of an operational consent.

Conclusion and Recommendation

The amended plans which are addressed within the body of this report are considered to have sufficiently addressed and resolved the matters raised within the issued statement of reasons from the Local Planning Panel on 11 September, 2019.

The amended development provides for improved building separation to the southern side setback and is also considered to have adequately demonstrated that waste servicing by Council can now be achieved.

It is therefore considered that the DA18/0132 for the demolition of existing structures and construction of a five (5) storey residential flat building containing 17 apartments and two (2) basement car parking is supportable and is recommended for approval subject to the imposition of amended recommended conditions of consent.

CONDITIONS SUMMARY

Application Number:	DA18/0132
Assessing Officer	Lauren Van Etten
Land to be developed (Address):	Lot 2 DP 1190616 29 - 31 Castlereagh Street PENRITH NSW 2750
Proposed Development:	Construction of a Five (5) Storey Residential Flat Building containing 17 Apartments & Two (2) Levels of Basement Car Parking

General

1 A001

The development must be implemented substantially in accordance with the following plans stamped approved by Council, BASIX Certificate, the application form and any supporting information received with application, except as may be amended in red on the approved plans and by the following conditions.

Plan	Prepared by	Dated
DA00 Cover Page	Pens Design Studio	Rev E
		14/10/19
DA01 Site Context	Pens Design Studio	Rev E
		14/10/19
DA02 Site Plan	Pens Design Studio	Rev E
		14/10/19
DA03 Basement Plan Level 2	Pens Design Studio	Rev E
		14/10/19
DA04 Basement Plan Level 1	Pens Design Studio	Rev E
		14/10/19
DA05 Ground Floor Plan	Pens Design Studio	Rev E
		14/10/19
DA06 Level 1	Pens Design Studio	Rev E
		14/10/19
DA07 Level 2	Pens Design Studio	Rev E
		14/10/19
DA08 Level 3	Pens Design Studio	Rev E
		14/10/19
DA09 Level 4	Pens Design Studio	Rev E
		14/10/19
DA10 Roof Terrace	Pens Design Studio	Rev E
		14/10/19
DA11 Elevations	Pens Design Studio	Rev E
		14/10/19
DA12 Elevations	Pens Design Studio	Rev E
	3	14/10/19
DA13 Sections	Pens Design Studio	Rev E
	3	14/10/19
DA14.1 Shadow Diagrams	Pens Design Studio	Rev E
		14/10/19
DA14.2 Shadow Diagrams	Pens Design Studio	Rev E
	. Sing 2 doi.git diddie	14/10/19
DA14.3 Solar Study	Pens Design Studio	Rev E
	. one beengn etadio	14/10/19
I	I	1, 10, 10

DA14.4 Solar Study	Pens Design Studio	Rev E
-		14/10/19
DA14.5 Solar Study	Pens Design Studio	Rev E
		14/10/19
DA14.6 Solar Study	Pens Design Studio	Rev E
		14/10/19
DA15 View from Sun	Pens Design Studio	Rev E
		14/10/19
BASIX Certificate 806709M (as amended)		
Stormwater Design Statement Report	Zait Engineering	28/3/17
17DZ1289.DSWC1	Solutions	
MUSIC Model and associated MUSIC-link report 08812	Zait Engineering	27/4/17
	Solutions	
Stormwater Drainage Plans	Zait Engineering	
	Solutions	
Periodic Maintenance Procedures and Operations and	Stormwater360	26/4/17
Maintenance Manual 08812		
Survey Plans 4104-16DET	C&A Surveyors	19/4/16
Geotechnical Report	Brink & Associates	8/6/2004
Waste Management Plan	CAD Plans	undated

Note: The plans and supporting documents referenced above will be amended in Condition 1 to reflect those submitted to satisfy requirements in deferred commencement conditions.

2 A019 - OCCUPATION CERTIFICATE (ALWAYS APPLY)

The development shall not be used or occupied until an Occupation Certificate has been issued.

3 A038 - LIGHTING LOCATIONS

Prior to the issue of an Occupation Certificate, a lighting system shall be installed for the development to provide uniform lighting across common areas and driveways. Exterior lighting shall be located and directed in such a manner so as not to create a nuisance to surrounding land uses. The lighting shall be the minimum level of illumination necessary for safe operation. The lighting shall be in accordance with AS 4282 "Control of the obtrusive effects of outdoor lighting" (1997).

4 A039 - Graffiti

The finishes of all structures and buildings are to be maintained at all times and any graffiti or vandalism immediately removed/repaired.

- 5 A046 Obtain Construction Certificate before commencement of works
 - A Construction Certificate shall be obtained prior to commencement of any building works.
- 6 A Special (BLANK)

Prior to the issue of a Construction Certificate, details of a sign posted 'loading zone' associated with the indented waste servicing bay are to be prepared, submitted to Council's Traffic Management Team and reported to Council's Local Traffic Committee for consideration and endorsement.

Prior to the issue of an Occupation Certifciate, the sign posting required above is to be implimented and installed at no cost to Council.

7 A Special (BLANK)

Any plant or unsightly structures installed on the external facades or rooftop must be screened from view.

8 A Special (BLANK)

Prior to the erection of any crane or any temporary construction structure at a height greater than the roof of the subject development, written notice shall be provided to Council and the Nepean Blue Mountains Local Health District at least 21 days prior to its erection, indicating at least the following:

- Name of responsible company and relevant contact details.
- Dimensions (height, length, etc).
- Position and orientation of boom/jib and counter boom/jib.
- Length of time that such a crane or structure will be erected on site.
- The management plan and measures that will ensure that the crane or structure will be of least possible impact on flight operations for Ambulance NSW.

Any crane or any temporary construction structure erected at a height greater than the roof of the subject development shall comply with the following:

- Be equipped with medium intensity steady red lighting positioned at the highest point and both ends of the boom/jib and counterboom/jib, such that the lighting will provide an indication of the height of the crane and the radius of the crane boom/jib. Such lighting, which should be displayed at night, should be positioned so that when displayed it is visible from all directions.
- When a crane is unattended for a period of time ensure the crane's boom is retracted and lowered as far as possible.
- No part of the crane or structure shall extend beyond the boundaries of the subject development site
 unless approved by Penrith City Council in consultation with the Nepean Blue Mountains Local Health
 District. Any encroachment beyond the boundaries of the subject site shall be the minimum amount
 required to facilitate construction and access all parts of the construction site.

9 A Special (BLANK)

Prior to the issue of a Construction Certificate, a dilapidation report prepared by a structural engineer shall be submitted recording the condition of any dwelling or ancillary structures on the northern, southern and western adjoining properties within the likely zone of influence from any excavation, dewatering or construction induced vibration. The report is to be submitted to Council and the appointed certifying authority.

10 A Special (BLANK)

Prior to the issue of an Occupation Certificate, an updated dilapidation report must be prepared and submitted to Council and the Certifying Authority. The updated report must identify any damage to adjoining properties and the means of rectification for the approval of Council.

11 A Special (BLANK)

Prior to the issue of an Occupation Certificate, 2.1m high fencing shall be erected along side and rear property boundaries (behind the building line). Such fencing and any required retaining walls shall be constructed entirely at the expense of the persons having the benefit of this consent. Timber retaining walls are not permitted.

12 A Special 1

Prior to the issue of a Construction Certificate for the development, development consent No. 13/0443 shall be surrendered to Penrith City Council in accordance with the provisions of the Environmental Planning and Assessment Act 1979.

If Council is not the certifier issuing the Construction Certificate then before the Construction Certificate is issued a letter from Council is to be provided to the certifier stating that the development has ben surrendered to Council.

13 A Special 2

Prior to the issue an Occupation Certificate, the property owner or agent acting for the owner shall arrange for the commencement of a domestic waste service with Council. The service is to be arranged no earlier than two days prior to occupancy and no later than two days after occupancy of the development. All requirements of Council's domestic collection service must be complied with at all times. Please telephone Council on (02) 4732 7615 for the commencement of waste services.

14 A Special CPTED Requirements

The following community safety and crime prevention through environmental design (CPTED) requirements are required to be implemented:

Lighting

All outdoor/public spaces throughout the development, in particular all entrances and pathways, must be
lit to the minimum Australian Standard of AS 1158. Lighting must be consistent in order to reduce the
contrast between shadows and illuminated areas and must be designed in accordance with AS 4282 Control of the obtrusive effects of outdoor lighting.

Basement Car Parking

- A security system must be installed on any pedestrian and vehicle entry/exit points to the car park, including the lift and stairwell, to minimise opportunities for unauthorised access.
- All areas of the car park must be well-lit, with consistent lighting to prevent shadowing or glare.
- Car park surfaces including walls and ceilings are to be light coloured with details included with the **Construction Certificate** application.

Building Security & Access Control

- Intercom, code or card locks or similar must be installed for all entries to the building and the unit complex grounds.
- Australian Standard 220 door and window locks must be installed in all dwellings.
- CCTV is to be provided to cover communal public space areas. Cameras must be of sufficient standard
 to be useful for police in the event of criminal investigations. Lighting must be provided to support
 cameras at night (alternatively infra-red cameras are recommended). Signage must be displayed to
 indicate that CCTV cameras are in use.
- Letterboxes (which are not detailed on the plans) must be incorporated near the front entry point, with access for residents from within a secure lobby area.

Graffiti/Vandalism

- Graffiti resistant coatings must be used to external surfaces where possible, including signage, furniture, retaining walls etc.
- Procedures must be in place to ensure the prompt removal and/or repair of graffiti or vandalism to the buildings, fencing, and common areas. This includes reporting incidents to police and/or relevant authorities.

Landscaping

All vegetation must be regularly pruned to ensure that sight lines are maintained.

Environmental Matters

15 D001 - Implement approved sediment& erosion control measures

Erosion and sediment control measures shall be installed **prior to the commencement of works on site** including approved clearing of site vegetation. The erosion and sediment control measures are to be maintained in accordance with the approved erosion and sediment control plan(s) for the development and the Department of Housing's "Managing Urban Stormwater: Soils and Construction" 2004.

16 D005 – No filling without prior approval (may need to add D006)

No fill material is to be imported to the site without the prior approval of Penrith City Council in accordance with Sydney Regional Environmental Plan No.20 (Hawkesbury- Nepean River) (No.2-1997). No recycling of material for use as fill material shall be carried out on the site without the prior approval of Council.

17 D009 - Covering of waste storage area

All waste materials stored onsite are to be contained within a designated area such as a waste bay or bin to ensure that no waste materials are allowed to enter the stormwater system or neighbouring properties. The designated waste storage areas shall provide at least two waste bays / bins so as to allow for the separation of wastes, and the areas are to be fully enclosed when the site is unattended.

18 D010 – Appropriate disposal of excavated or other waste

All excavated material and other wastes generated as a result of the development are to be re-used, recycled or disposed of in accordance with the approved waste management plan.

Waste materials not specified in the approved waste management plan are to be disposed of at a lawful waste management facility. Where the disposal location or waste materials have not been identified in the waste management plan, details shall be provided to the Certifying Authority as part of the waste management documentation accompanying the Construction Certificate application.

All receipts and supporting documentation must be retained in order to verify lawful disposal of materials and are to be made available to Penrith City Council on request.

19 D014 - Plant and equipment noise

The operating noise level of plant and equipment shall not exceed 5dB(A) above the background noise level when measured at the boundaries of the premises. The provisions of the Protection of the Environment Operations Act 1997 apply to the development, in terms of regulating offensive noise.

20 D026 - Liquid wastes

Only clean and unpolluted water is to be discharged into Penrith City Council's stormwater drainage system. Liquid wastes suitable for discharge to the mains sewerare to be discharged in accordance with Sydney Water requirements.

If mains sewer is not available or if Sydney Water will not allow disposal to the sewer then a licensed waste contractor is to remove the liquid waste from the premises to an appropriate waste facility.

The waste contractor and waste facility are to hold the relevant licenses issued by the NSW Environment Protection Authority.

21 D Special (BLANK)

Dust suppression techniques are to be employed during demolition and construction to reduce any potential nuisances to surrounding properties.

22 D Special (BLANK)

Mud and soil from vehicular movements to and from the site must not be deposited on the road.

23 D Special (BLANK)

Should any "unexpected finds" occur during the excavation and earthworks, including, but not limited to, the identification/finding of contaminated soils, buried building materials, asbestos, odour and/or staining, works are to cease immediately and Council is to be notified. Any such "unexpected finds" shall be addressed by an appropriately qualified environmental consultant, including preparation of an environmental management plan to be submitted to and approved by Council.

All remediation works within the Penrith Local Government Area are considered to be Category 1 works under State Environmental Planning Policy No. 55 - Remediation of Land. Should any contamination be found during development works and should remediation be required, development consent is to be sought from Penrith City Council prior to remediation works commencing.

24 D Special (BLANK)

The following details shall be shown on the Construction Certificate plans following satisfaction of deferred commencement requirements within this consent:

- All on-site waste collection infrastructure, doors and access points are to be locked through Councils Abloy Key System. System specifications are outlined in section 3.5.5 of the 'Residential Flat Building Guideline' document.
- All on-site waste collection infrastructure are to provide wash facilities through the use of a centralised mixing valve and hose cock. Respective drainage and water proofing to be installed to support the use of hose facilities.
- The Bulky Households Waste Room to replace the roller door with 1.8m wide, outwards opening dual doors.

25 D Special (BLANK)

Prior to the issue of an Occupation Certificate, and only where Council's waste collection service is being relied upon, the developer is to enter into a formal agreement with Penrith City Council for the utilisation of Councils Waste Collection Service. This is to include Council being provided with indemnity against claims for loss and damage.

Note: By entering into an agreement with Council for Waste Collection, the development will be required to operate in full compliance with Penrith City Councils Waste Collection and Processing Contracts for Standard Waste Collection. The provision of Councils waste collection service will not commence until formalisation of the agreement.

BCA Issues

26 E001 - BCA compliance

All aspects of the building design shall comply with the applicable performance requirements of the Building Code of Australia so as to achieve and maintain acceptable standards of structural sufficiency, safety (including fire safety), health and amenity for the on-going benefit of the community. Compliance with the performance requirements can only be achieved by:

- (a) complying with the deemed to satisfy provisions, or
- (b) formulating an alternative solution which:
- complies with the performance requirements, or
- is shown to be at least equivalent to the deemed to satisfy provision, or (c) a combination of (a) and (b).

27 E006 - Disabled access and facilities

Access and sanitary facilities for persons with disabilities are to be provided and maintained in accordance with the requirements of the Building Code of Australia and AS 1428 "Design for Access and Mobility". Details of compliance are to be provided in the relevant plans and specifications accompanying the Construction Certificate application.

28 E008 - FIRE SAFETY LIST WITH CONSTRUCTION CERTIFICATE

A fire safety list of essential fire or other safety measures shall be submitted to Penrith City Council prior to the issue of the Construction Certificate. The fire safety list shall specify all measures (both current and proposed) that are required for the building so as to ensure the safety of persons in the building in the event of fire. The fire safety list must distinguish between:

- the measures that are currently implemented in the building premises,
- and the measures that are to be proposed to be implemented in the building premises, and must specify the minimum standard of performance for each measure.

29 E009 - Annual fire safety-essential fire safety (Class 2-9 buildings)

The owner of a building, to which an essential fire safety measure is applicable, shall provide Penrith City Council with an annual fire safety statement for the building. The annual fire safety statement for a building must:

(a) deal with each essential fire safety measure in the building premises, and

(b) be given:

- within 12 months after the last such statement was given, or
- if no such statement has previously been given, within 12 months after a final fire safety certificate was first issued for the building.

As soon as practicable after the annual fire safety statement is issued, the owner of the building to which the statement relates:

- must also provide a copy of the statement (together with a copy of the current fire safety schedule) to the Commissioner of New South Wales Fire Brigades, and
- prominently display a copy of the statement (together with a copy of the current fire safety schedule) in the building.

30 E01A - BCA compliance for Class 2-9

All aspects of the building design shall comply with the applicable performance requirements of the Building Code of Australia so as to achieve and maintain acceptable standards of structural sufficiency, safety (including fire safety), health and amenity for the on-going benefit of the community. Compliance with the performance requirements can only be achieved by:

- (a) complying with the deemed to satisfy provisions, or
- (b) formulating an alternative solution which:
- complies with the performance requirements, or
- is shown to be at least equivalent to the deemed to satisfy provision, or
- (c) a combination of (a) and (b).

It is the owner's responsibility to place on display, in a prominent position within the building at all times, a copy of the latest fire safety schedule and fire safety certificate/ statement for the building.

31 E Special (BLANK)

The external walls of the building including attachments must comply with the relevant requirements of the National Construction Code (NCC). Prior to the issue of a Construction Certificate and Occupation Certificate the Certifying Authority and Principal Certifying Authority must:

- (a) Be satisfied that suitable evidence is provided to demonstrate that the products and systems proposed for use or used in the construction of external walls including finishes and claddings such as synthetic or aluminium composite panels comply with the relevant requirements of the NCC; and
- (b)Ensure that the documentation relied upon in the approval processes include an appropriate level of detail to demonstrate compliance with the NCC as proposed and as built.

Health Matters and OSSM installations

32 F006 - Water tank & nuisance

The rainwater tank must be maintained so as not to create a nuisance and it must be protected against mosquito infestation.

Utility Services

33 G002 - Section 73 (not for

A Section 73 Compliance Certificate under the Sydney Water Act 1994 shall be obtained from Sydney Water. The application must be made through an authorised Water Servicing Coordinator. Please refer to "Your Business" section of Sydney Water's website at www.sydneywater.com.au then the "e-developer" icon, or telephone 13 20 92.

The Section 73 Compliance Certificate must be submitted to the Principal Certifying Authority prior to the issue of an Occupation Certificate.

34 G004 - Integral Energy

Prior to the issue of a Construction Certificate, a written clearance is to be obtained from Endeavour Energy stating that electrical services have been made available to the development or that arrangements have been entered into for the provision of services to the development.

In the event that a pad mounted substation is necessary to service the development, Penrith City Council shall be consulted over the proposed location of the substation before the Construction Certificate for the development is issued as the location of the substation may impact on other services and building, driveway or landscape design already approved by Council.

35 G006 -

Prior to the issue of a Construction Certificate, the Principal Certifying Authority shall be satisfied that telecommunications infrastructure may be installed to service the premises which complies with the following:

- The requirements of the Telecommunications Act 1997;
- For a fibre ready facility, the NBN Co's standard specifications current at the time of installation; and
- For a line that is to connect a lot to telecommunications infrastructure external to the premises, the line shall be located underground.

Unless otherwise stipulated by telecommunications legislation at the time of construction, the development must be provided with all necessary pits and pipes, and conduits to accommodate the future connection of optic fibre technology telecommunications.

Prior to the issue of an Occupation Certificate, written certification from all relevant service providers that the telecommunications infrastructure is installed in accordance with the requirements above and the applicable legislation at the time of construction, must be submitted to the Principal Certifying Authority.

Construction

36 H001 - Stamped plans and erection of site notice

Stamped plans, specifications, a copy of the development consent, the Construction Certificate and any other Certificates to be relied upon shall be available on site at all times during construction.

The following details are to be displayed in a maximum of 2 signs to be erected on the site:

- the name of the Principal Certifying Authority, their address and telephone number,
- the name of the person in charge of the work site and telephone number at which that person may be contacted during work hours,
- that unauthorised entry to the work site is prohibited,
- the designated waste storage area must be covered when the site is unattended, and
- all sediment and erosion control measures shall be fully maintained until completion of the construction phase.

Signage but no more than 2 signs stating the above details are to be erected:

- at the commencement of, and for the full length of the, construction works onsite, and
- in a prominent position on the work site and in a manner that can be easily read by pedestrian traffic.

All construction signage is to be removed when the Occupation Certificate has been issued for the development.

37 H002 - All forms of construction

Prior to the commencement of construction works:

- (a) Toilet facilities at or in the vicinity of the work site shall be provided at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:
- a standard flushing toilet connected to a public sewer, or
- if that is not practicable, an accredited sewage management facility approved by the council, or
- alternatively, any other sewage management facility approved by council.
- (b) All excavations and backfilling associated with the erection or demolition of a building must be executed safely and in accordance with the appropriate professional standards. All excavations associated with the erection or demolition of a building must be properly guarded and protected to prevent them from being dangerous to life or property.
- (c) If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation to be made:
- must preserve and protect the building from damage, and
- if necessary, must underpin and support the building in an approved manner, and
- must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished. The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this condition, whether carried out on the allotment of land being excavated or on the adjoining allotment of land, (includes a public road and any other public place).
- (d) If the work involved in the erection or demolition of a building is likely tocause pedestrian or vehicular traffic in a public place to be obstructed orrendered inconvenient, or involves the enclosure of a public place, ahoarding or fence must be erected between the work site and the public place:
- if necessary, an awning is to be erected, sufficient to prevent any substance from, or in connection with, the work falling into the publicplace,
- the work site must be kept lit between sunset and sunrise if it is likely to be hazardous to persons in the public place, and
- any such hoarding, fence or awning is to be removed when the work has been completed.

38 H014 - Slabs/ footings

Residential slabs and footings shall be designed and certified by a qualified practising Structural Engineer or a suitably qualified person in accordance with the requirements of AS2870-1996 "Residential Slabs and Footings". Details are to be provided for consideration and approval prior to the issue of a Construction Certificate.

39 H015 - Termites

Details of the proposed termite management system shall be submitted for consideration and approval prior to the issue of a Construction Certificate. Council recommends that consideration be given to protection against subterranean termites in situations where termite resistant construction is used.

40 H018 - Load bearing walls

A certificate from a qualified practising Structural Engineer shall accompany the Construction Certificate application, certifying the structural adequacy of all load bearing walls prior to their erection.

41 H022 - Survey

The building shall be set out by a registered surveyor. A Survey Certificate shall be undertaken and submitted to the Principal Certifying Authority when the building is constructed to ground floor slab level.

42 H024 - Glass installations AS1288

Glass installations within the building shall comply with AS 1288 and the Building Code of Australia. On completion of the glass installation, a report shall be submitted certifying compliance with AS 1288.

43 H033 - Clothes line

Clothes drying facilities are to be positioned and screened from public view.

44 H036 - Rainwater Tank (Also impose H037, H038, H039, G005 & Q010)

The rainwater tank(s) is to be:

- erected on a self-supporting base in the approved location on the property in accordance with the stampedapproved site plans for the development,
- structurally sound and constructed in accordance with AS/NZS 3500 1.2- 1998: National Plumbing and Drainage - Water Supply - Acceptable Solutions,
- fully enclosed and all openings sealed to prevent access by mosquitoes,
- fitted with a first flush device,
- fitted with a trickle system to top up from mains water,
- provided with an air gap, and
- installed by a licensed plumber in accordance with Sydney Water's "Plumbing requirements Information for rainwater tank suppliers and plumbers April 2003" and the NSW Code of Practice: Plumbing and Drainage.

Additionally, the following are to be provided:

- A back flow prevention device shall be provided at the water meter in accordance with Sydney Water requirements.
- In the event of a power failure, a back up supply of mains water shall be provided to at least one toilet in the dwelling.
- The rainwater tank(s) and associated piping is to be labelled 'Rainwater Not for Drinking' in accordance with Sydney Water requirements.
- The rainwater tank and pipework is to be painted in colours matching the external finishes of the dwelling and is to be of non-reflective finish.
- The overflow for the rainwater tank is to be connected into the existing stormwater disposal system on the site.

Before a rainwater tank(s) can be used, a certificate or suitable document is to be submitted to the Principal Certifying Authority stating that the rainwater tank has been installed in accordance with:

- the Manufacturer's Specifications, and
- Sydney Water and NSW Health requirements.

This certificate or documentation is to be provided by the licensed plumber who installed the rainwater tank on the property, and is to be submitted prior to the issue of the Occupation Certificate.

45 H037 - Safe supply of water from catchment areas (Also impose H036, H038 & H039)

The catchment area (for the rainwater tank) includes the parts of the roof of the dwelling(s) from which water is collected and includes gutters. To ensure a safe supply of water:

- roof catchment areas must be kept clear of overhanging vegetation,
- gutters must have sufficient fall to downpipes to prevent pooling of water,
- overflow, discharge from bleed off pipes from roof mounted appliances such as airconditioners, hot water services and solar heaters must not discharge into the rainwater catchment area,
- for roofs containing lead based, tar based or asbestos material the tank supply must not be connected to drinking, bathing and gardening tap water outlets,
- appropriate measures must be installed to prevent foreign materials from contaminating the water which enters the rainwater tank.
- 46 H038 Connection of rainwater tank supply (Also impose H036, H037 & H039)

The rainwater tank supply must not be connected to drinking and bathing water tap outlets.

47 H039 - Rainwater tank pumps (Also impose H036, H037 & H038)

The rainwater tank pump must not exceed 5dBA above ambient background noise level at the nearest residential property boundary. The provisions of the Protection of the Environment Operations Act 1997 apply to the development, in terms of regulating offensive noise.

48 H041 - Hours of work (other devt)

Construction works or subdivision works that are carried out in accordance with an approved consent that involve the use of heavy vehicles, heavy machinery and other equipment likely to cause offence to adjoining properties shall be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm (if inaudible on neighbouring residential premises), otherwise 8am to 1pm
- No work is permitted on Sundays and Public Holidays.

Other construction works carried out inside a building/tenancy and do not involve the use of equipment that emits noise are not restricted to the construction hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

49 H042 - Adaptable Dwelling Certification

The Construction Certificate must be accompanied by certification from an accredited Access Consultant confirming that the adaptable dwellings are capable of being modified, when required by the occupant, to comply with the Australian Housing Standard (AS 4299- 2009).

50 H Special (BLANK)

The building construction materials shall have low reflective qualities to minimize glare.

Engineering

51 K101 - Works at no cost to Council

All roadworks, stormwater drainage works, associated civil works and dedications, required to effect the consented development shall be undertaken at no cost to Penrith City Council.

52 K201 - Infrastructure Bond

An Infrastructure Restoration Bond is to be lodged with Penrith City Council for development involving works around Penrith City Council's Public Infrastructure Assets. The bond is to be lodged with Penrith City Council prior to commencement of any works on site or prior to the issue of any Construction Certificate, whichever occurs first. The bond and applicable fees are in accordance with Council's adopted Fees and Charges.

An application form together with an information sheet and conditions are available on Council's website.

Contact Penrith City Council's City Works Department on (02) 4732 7777 or visit Penrith City Council's website for more information.

53 K202 - S138 Roads Act – Works and Structures - Minor Works in the public road DRIVEWAYS ROAD OPENINGS

Prior to the issue of any Construction Certificate, a Section138 Roads Act applications, including payment of application and inspection fees, shall be lodged and approved by Penrith City Council (being the Roads Authority for <u>any works required</u> in a public road). These works may include but are not limited to the following:

- a) Vehicular crossings (including kerb reinstatement of redundant vehicular crossings)
- b) Concrete footpaths and or cycleways
- c) Road opening for utilities and stormwater (including stormwater connection to Penrith City Council roads and other Penrith City Council owned drainage)
- d) Road occupancy or road closures
- e) The placement of hoardings, structures, containers, waster skips, signs etc. in the road reserve
- f) Temporary construction access

All works shall be carried out in accordance with the Roads Act approval, the development consent, including the stamped approved plans, and Penrith City Council's specifications, guidelines and best engineering practice.

Contact Penrith City Council's City Works Department on (02) 4732 7777 or visit Penrith City Council's website for more information.

Note:

- a) Where Penrith City Council is the Certifying Authority for the development, the Roads Act approval for the above works may be issued concurrently with the Construction Certificate.
- b) Separate approvals may also be required from the Roads and Maritime Services for classified roads.
- c) All works associated with the Roads Act approval must be completed prior to the issue of any Occupation Certificate or Subdivision Certificate as applicable.
- d) On completion of any awning over the road reserve, a certificate from a practising structural engineer certifying the structural adequacy of the awning is to be submitted to Council before Council will inspect the works and issue its final approval under the Roads Act

54 K209 - Stormwater Concept Plan

The stormwater management system shall be provided generally in accordance with the MUSIC modelling and associated concept plan/s lodged for development approval, prepared by Zait Engineering Solutions reference 17DZ1289, drawings D01 to D11 issue B dated 6/6/2019.

The stormwater treatment systems shall include a minimum of 6 * 460mm Stormwater 360 Stormfilter Cartridges and per the WSUD Strategy and supporting MUSIC modelling.

Engineering plans and supporting calculations for the stormwater management systems are to be prepared by a suitably qualified person and shall accompany the application for a Construction Certificate.

Prior to the issue of a Construction Certificate the Certifying Authority shall ensure that the stormwater management system has been designed in accordance with Council's Stormwater Drainage for Building Developments and Water Sensitive Urban Design Policy.

55 K210 - Stormwater Management

The stormwater management system shall be provided generally in accordance with the concept plan/s lodged for development approval, prepared by ZAIT Engineering Solutions, reference number 17DZ1289, revision B, dated 06 June 2019.

Engineering plans and supporting calculations for the stormwater management systems are to be prepared by a suitably qualified person and shall accompany the application for a Construction Certificate.

Prior to the issue of any Construction Certificate, the Certifying Authority shall ensure that the stormwater management system has been designed in accordance with Penrith City Council's Stormwater Drainage for Building Developments, Water Sensitive Urban Design (WSUD) policies and the following items are addressed:

- The above ground Onsite Stormwater Detention basin shall be constructed of masonry walls and water tight. The above ground basin shall be designed and constructed to allow for stormwater ponding to reach the designed Top Of Water level in the 1% AEP storm event.
- The section detail of the DCP 1 on drawing D09 shows the top of masonry wall lower than the Top of Water Level of the Onsite Stormwater Detention (OSD) system. As such, this will not allow the OSD system to function as intended. In this regard, the plans shall be amended accordingly.

56 K211 - Stormwater Discharge – Basement Car parks

Prior to the issue of any Construction Certificate, the Certifying Authority shall ensure that the stormwater drainage system for the basement car park has been designed in accordance with the requirements for pumped systems in AS3500.3 (or as amended) (Plumbing and Drainage – Stormwater Drainage).

57 K222 - Access, Car Parking and Manoeuvring – General

Prior to the issue of any Construction Certificate, the Certifying Authority shall ensure that vehicular access, circulation, manoeuvring, pedestrian and parking areas associated with the subject development are in accordance with AS 2890.1, AS2890.2, AS2890.6 and Penrith City Council's Development Control Plan.

58 K224 - Construction Traffic Management Plan

Prior to the commencement of any works on-site (including demolition works) or prior to the issue of any Construction Certificate, whichever occurs first, a Construction Traffic Management Plan (CTMP) shall be submitted to Council for approval. The CTMP shall be prepared in accordance with Council's Engineering Construction Specification for Civil Works. The CTMP shall be prepared by a suitably qualified consultant with appropriate training and certification from the Roads & Maritime Services (RMS), and in accordance with Council's Engineering Construction Specification for Civil Works. Approval of the CTMP may require approval of the Local Traffic Committee.

59 K226 - Basement Geotechnical Testing/ Dilapidation Report

Prior to the issue of a Construction Certificate the Certifying Authority shall ensure that a Geotechnical investigation, report and strategy has been conducted to ensure stability of the Council infrastructure and surrounding developments. The geotechnical investigation, report and strategy shall comply with the recommendations contained in the technical direction GTD 2012/001 prepared by the Road and Maritime Services as amended. The development shall undertake a dilapidation report for all surrounding buildings and Council owned infrastructure that confirms that no damage occurs due to the excavations associated with the development. If Council is not the Certifying Authority the dilapidation report shall be submitted to Council prior to Construction Certificate and then updated and submitted prior to any Occupation Certificate confirming no damage has occurred.

60 K227 - Stormwater Legal Discharge Point

Prior to the issued of any Construction Certificate issued for internal works associated with the development the site must be services by a legal point of discharge including and required infrastructure drainage works. The drainage works may include inter-allotment drainage construction, upgrades and / or road drainage extensions located on lands owned by others.

61 K301 - Sediment & Erosion Control

Prior to commencement of works sediment and erosion control measures shall be installed in accordance with the approved Construction Certificate and to ensure compliance with the Protection of the Environment Operations Act 1997.

The erosion and sediment control measures shall remain in place and be maintained until all disturbed areas have been rehabilitated and stabilised.

62 K302 - Traffic Control Plan

Prior to commencement of any works associated with the development, a Traffic Control Plan, including details for pedestrian management, shall be prepared in accordance with AS1742.3 "Traffic Control Devices for Works on Roads" and the Roads and Maritime Services' publication "Traffic Control at Worksites" and certified by an appropriately accredited Roads and Maritime Services Traffic Controller.

Traffic control measures shall be implemented during the construction phase of the development in accordance with the certified plan. A copy of the plan shall be available on site at all times.

Note:

- a) A copy of the Traffic Control Plan shall accompany the Notice of Commencement to Penrith City Council.
- b) Traffic control measures may require road occupancy / road closure approvals issued under Section 138 of the Roads Act by Penrith City Council prior to the issue of a Construction Certificate.

63 K405 - Turf to Verge

Upon completion of all works in the road reserve, all verge areas fronting and within the development are to be turfed. The turf shall extend from the back of kerb to the property boundary, with the exception of concrete footpaths, service lids or other infrastructure which is not to be turfed over. Turf laid up to concrete footpaths, service lids or other infrastructure shall finish flush with the edge.

64 K406 - Underground Services

All existing (aerial) and proposed services for the development, including those across the frontage of the development are to be located or relocated underground in accordance with the relevant authorities regulations and standards.

65 K501 - Penrith City Council clearance - Roads Act/ Local Government Act

Prior to the issue of any Occupation Certificate, the Principal Certifying Authority shall ensure that all works associated with a S138 Roads Act approval or S68 Local Government Act approval have been inspected and signed off by Penrith City Council.

66 K502 - Works as executed - General and Compliance Documenation

Prior to the issue of an Occupation Certificate, works-as-executed drawings, final operation and maintenance management plans and any other compliance documentation shall be submitted to the Principal Certifying Authority in accordance with Penrith City Council's Engineering Construction Specification for Civil Works, WSUD Technical Guidelines and Stormwater Drainage for Building Developments.

An original set of works-as-executed drawings and copies of the final operation and maintenance management plans and compliance documentation shall also be submitted to Penrith City Council with notification of the issue of the Occupation Certificate where Council is not the Principal Certifying Authority.

67 K503 - Stormwater Compliance

Prior to the issue of an Occupation Certificate the Principal Certifying Authority shall ensure that the:

- a) Stormwater management systems (including on-site detention and water sensitive urban design)
- Have been satisfactorily completed in accordance with the approved Construction Certificate and the requirements of this consent.
- Have met the design intent with regard to any construction variations to the approved design.
- Any remedial works required to been undertaken have been satisfactorily completed.

Details of the approved and constructed system/s shall be provided as part of the works-as-executed drawings.

68 K503 - Works as executed – General and Compliance Documentation

Prior to the issue of a Occupation Certificate, works-as-executed drawings, final operation and maintenance management plans and any other compliance documentation shall be submitted to the Principal Certifying Authority in accordance with Penrith City Council's Engineering Construction Specification for Civil Works, WSUD Technical Guidelines and Stormwater Drainage for Building Developments.

An original set of Works As Executed drawings and copies of the final operation and maintenance management plans and compliance documentation shall also be submitted to Penrith City Council with notification of the issue of the Occupation and / or Subdivision (Strata) Certificate where Penrith City Council is not the Principal Certifying Authority.

69 K504 - Restriction as to User and Positive Covenant

Prior to the issue of an Occupation Certificate a restriction as to user and positive covenant relating to the:

Stormwater management systems (including on-site detention and water sensitive urban design)

Shall be registered on the title of the property. The restriction as to user and positive covenant shall be in Penrith City Council's standard wording as detailed in Penrith City Council's Stormwater Drainage for Building Development.

70 K504 - Stormwater Compliance

Prior to the issue of any Occupation Certificate, the Principal Certifying Authority shall ensure that the:

- a) Stormwater management systems (including on-site detention and water sensitive urban design)
- Have been satisfactorily completed in accordance with the approved Construction Certificate and the requirements of this consent.
- Have met the design intent with regard to any construction variations to the approved design.
- Any remedial works required to been undertaken have been satisfactorily completed.

Details of the approved and constructed system/s shall be provided as part of the Works As Executed drawings.

71 K505 - Restriction as to User and Positive Covenant

Prior to the issue of any Occupation Certificate, a restriction as to user and positive covenant relating to the:

a) Stormwater management systems (including on-site detention and water sensitive urban design)

Shall be registered on the title of the property. The restriction as to user and positive covenant shall be in Penrith City Council's standard wording as detailed in Penrith City Council's Stormwater and Drainage for Building Developments policy.

72 K - Waterways - Stormwater Management system operation and maintenance

The stormwater management systems shall continue to be operated and maintained in perpetuity to the satisfaction of Council in accordance with the final operation and maintenance management plan. Regular inspection records are required to be maintained and made available to Council upon request. All necessary improvements are required to be made immediately upon awareness of any deficiencies in the treatment measure/s

73 K Special (BLANK)

- (a) All car parking and manoeuvring must be in accordance with AS 2890.1-2004; AS 2890.6-2009 and Council's requirements.
- (b) All vehicles are to enter and exit in a forward direction.
- (c) The ramp to the basement car park is to be fitted with an appropriately placed access-point traffic light system and convex mirror/s to ensure that vehicles due not simultaneously traverse the basement ramp in opposing directions. Signage is required indicating that vehicle headlights are to be switched on when entering or exiting via the ramp. The traffic light system and convex mirrors are to be maintained in good working order and in perpetuity, for the life of the development.
- (d) The required sight lines around driveway entrances are not to be compromised by landscaping, fencing, signage or other obstructions.
- (e) All car spaces are to be line marked and dedicated for the parking of vehicles only and not to be used for storage of materials and/or waste materials, etc.

Landscaping

74 L001 - General

All landscape works are to be constructed in accordance with the stamped approved plan Landscape Plan 17082 DA 1 prepared by Vision Dynamics, Sections F5 "Planting Techniques", F8 "Quality Assurance Standards" and F9 "Site Management Plan" of Penrith Council's Landscape Development Control Plan.

Landscaping shall be maintained:

- in accordance with the approved plan, and
- in a healthy state, and in perpetuity by the existing or future owners and occupiers of the property.

If any of the vegetation comprising that landscaping dies or is removed, it is to be replaced with vegetation of the same species and, to the greatest extent practicable, the same maturity as the vegetation which died or was removed.

75 L002 - Landscape construction

The approved landscaping for the site must be constructed by a suitably qualified and experienced landscape professional.

76 L003 - Report requirement

Upon completion of the landscape works associated with the development and prior to the issue of an Occupation Certificate, an Implementation Report must be submitted to the Principal Certifying Authority attesting to the satisfactory completion of the landscaping works for the development.

An Occupation Certificate should not be issued until such time as a satisfactory Implementation Report has been received. If Penrith City Council is not the Principal Certifying Authority, a copy of the satisfactory Implementation Report is to be submitted to Council together with the Occupation Certificate for the development.

property owners.

77 L006 - Aust Standard

All landscape works are to meet industry best practice and the following relevant Australian Standards:

- AS 4419 Soils for Landscaping and Garden Use,
- AS 4454 Composts, Soil Conditioners and Mulches, and
- AS 4373 Pruning of Amenity Trees.

78 L008 - Tree PreservationOrder

No trees are to be removed, ringbarked, cut, topped or lopped or wilfully destroyed (other than those within the proposed building footprint or as shown on the approved plans) without the prior consent of Penrith City Council and in accordance with Council's Tree Preservation Order and Policy.

Development Contributions

79 N001 - Section 94 contribution (apply separate condition for each Contribution Plan)

This condition is imposed in accordance with Penrith City Council's Section 94 Contributions Plan(s) for Cultural Facilities. Based on the current rates detailed in the accompanying schedule attached to this Notice, \$6,464 is to be paid to Council prior to a Construction Certificate being issued for this development (the rates are subject to quarterly reviews). If not paid within the current quarterly period, this contribution will be reviewed at the time of payment in accordance with the adopted Section 94 plan. The projected rates of this contribution amount are listed in Council's Fees and Charges Schedule.

Council should be contacted prior to payment to ascertain the rate for the current quarterly period. The S94 invoice accompanying this consent should accompany the contribution payment. The Section 94 Contributions Plan for Cultural Facilities may be inspected at Council's Civic Centre, 601 High Street, Penrith.

80 N001 - Section 94 contribution (apply separate condition for each Contribution Plan)

This condition is imposed in accordance with Penrith City Council's Section 94 Contributions Plan(s) for District Open Space. Based on the current rates detailed in the accompanying schedule attached to this Notice, \$61,120 is to be paid to Council prior to a Construction Certificate being issued for this development (the rates are subject to quarterly reviews). If not paid within the current quarterly period, this contribution will be reviewed at the time of payment in accordance with the adopted Section 94 plan. The projected rates of this contribution amount are listed in Council's Fees and Charges Schedule.

Council should be contacted prior to payment to ascertain the rate for the current quarterly period. The S94 invoice accompanying this consent should accompany the contribution payment. The Section 94 Contributions Plan for District Open Space may be inspected at Council's Civic Centre, 601 High Street, Penrith.

81 N001 - Section 94 contribution (apply separate condition for each Contribution Plan)

This condition is imposed in accordance with Penrith City Council's Section 94 Contributions Plan(s) for Local Open Space. Based on the current rates detailed in the accompanying schedule attached to this Notice, \$22,093 is to be paid to Council prior to a Construction Certificate being issued for this development (the rates are subject to quarterly reviews). If not paid within the current quarterly period, this contribution will be reviewed at the time of payment in accordance with the adopted Section 94 plan. The projected rates of this contribution amount are listed in Council's Fees and Charges Schedule.

Council should be contacted prior to payment to ascertain the rate for the current quarterly period. The S94 invoice accompanying this consent should accompany the contribution payment. The Section 94 Contributions Plan for Local Open Space may be inspected at Council's Civic Centre, 601 High Street, Penrith.

Payment of Fees

82 P001 - Costs

All roadworks, dedications and drainage works are to be carried out at the applicant's cost.

83 P002 - Fees associated with Council land (Applies to all works & add K019)

Prior to the commencement of any works on site, all fees associated with Penrith City Council-owned land and infrastructure shall be paid to Council. These fees include Road Opening fees and Infrastructure Restoration fees.

Certification

84 Q006 - Occupation Certicate (Class 2 - 9)

An Occupation Certificate is to be obtained from the Principal Certifying Authority on completion of all works and prior to the occupation of the building/tenancy and commencement of the approved use. The Occupation Certificate shall not be issued if any conditions of this consent, but not the conditions relating to the operation of the development, are outstanding, and/or if the development does not comply with the provisions of the Environmental Planning and Assessment Act and Regulation.

Before the Occupation Certificate can be issued for the development, Fire Safety Certificates issued for the building are to be submitted to Penrith City Council and the New South Wales Fire Brigades.

A copy of the Occupation Certificate and all necessary documentation supporting the issue of that Certificate including the abovementioned documents shall be submitted to Penrith City Council, if Council is not the Principal Certifying Authority.

85 Q01F - Notice of Commencement & Appointment of PCA2 (use for Fast Light only)

Prior to the commencement of any earthworks or construction works on site, the proponent is to:
(a) employ a Principal Certifying Authority to oversee that the said works carried out on the site are in accordance with the development consent and related Construction Certificate issued for the approved development, and with the relevant provisions of the Environmental Planning and Assessment Act and accompanying Regulation, and (b) submit a Notice of Commencement to Penrith City Council.

The Principal Certifying Authority shall submit to Council an "Appointment of Principal Certifying Authority" in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

Information to accompany the Notice of Commencement

Two (2) days before any earthworks or construction/demolition works are to commence on site (including the clearing site vegetation), the proponent shall submit a "Notice of Commencement" to Council in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

Schedule 1 (Deferred Commencement)

86 S Special (Deferred commencement condition)

Prior to the issue of an operational consent, the following issues must be resolved through the submission of amended plans and supporting information:-

- a) An amended BASIX Certificate is to be submitted to, and approved by Council. which reflects the amended design. All resulting BASIX Committments identified for the DA stage must be reflected on revised plans.
- b) Amended Detailed Landscape Plans shall be submitted to Council which are consistent with the approved ground floor plan and incorporates the following inclusions:
- A landscaped southern side setback without any paved pathway for egress.
- Street Tree planting either brushbox or lophotemon confertus
- Additional large trees within the front, rear and southern setback zones coinciding with deep soil areas c) Amended stormwater and civil design plans to ensure consistancy with the approved / amended architectural drawings and landacape plans

The documents and amended plans relied upon to satisfy this condition are to be incorporated into Condition No. 1 prior to the issue of an Operational Consent.

EXECUTIVE SUMMARY

	REQUIRED		PROPOSED
01. SITE AREA	800.00m²		SITE AREA
02. ZONE	R4		887.00m² R4
03. BUILDING HEIGHT	MAX. 18m		17.80m
04. FSR	-		-
FSA	-		-
05. SITE COVERAGE	MAX. 443.50m ² (50% OF SITE)		351.675m²/ 887.00m² 39.65% OF SITE
			PROVIDED OPEN SPACE: 535.325m² =60.35% OF SITE
06. DEEP SOIL ZONE	133.05m ² 15% OF SITE (ADC	5)	259.64m ² 29.27% OF SITE
07. LANDSCAPE	310.45m²	Ground 290.45m ²	353.99m²
07. E. 11.0007 L	35% OF SITE	32.75% Roof Terrace 63.54m ² 7.16%	39.91% OF SITE
08.COMMUNAL OPEN	221.75m²	Ground 163.60m ²	315.86m²
SPACE	25% OF SITE	18.44% Roof Terrace 152.26m ² 17.17%	35.60% OF SITE
09. NUMBER OF UNITS		11.11%	17 UNITS 1 BEDROOM=3 2 BEDROOM=12 3 BEDROOM=2
10. CAR SPACE			
1 BEDROOM	1per UNIT	4 UNIT=4	4 SPACES
2 BEDROOM	1per UNIT	11 UNIT=11	11 SPACES
3 BEDROOM	1.5 per UNIT	2 UNIT=3	3 SPACES
VISITOR	1 SPACE per 5 UNI	IT 17/5=4	4 SPACES
	CAR SPACES REC	QUIRED =22	22 SPACES
ADAPTABLE	17(10%)	=2	2 SPACES
BICYCLE	3 per UNIT 17/3	3 =5.66	6 SPACES
11. SOLAR ACCESS	70% OF UNITS TO 2HRS OF SOLAR A		82.40%(14/17 UNITS)
12. CROSS VENTILATION	60% OF UNITS TO CROSS VENTILAT		94.12%(16/17 UNITS)
13. ADAPTABLE UNIT	10% OF 17 UNITS=	=2	2 UNITS
14. LIVABLE UNIT	20% OF 17 UNITS=	-4	4 UNITS Including the 2 adaptable units

NatHERS Thermal Performance Specifications (BASIX Thermal Comfort)

29-31 Castlereagh Street, Penrith

These are the Specifications upon which the NatHERS Assessment is based. If details included in these Specifications vary from other drawings or written specifications, these Specifications shall take precedence. If only one specification option is detailed for a building

Windows	Glass	Frame	U value	SHGC	Detail
Default	Single glazed, clear	Aluminium	6.7	0.57	Generally for window types: Awning, bi-fold, casement, tilt 'n' turn
Default	Single glazed, clear	Aluminium	6.7	0.70	Generally for window types: Sliding window/ door, double hung, fixed, louvre
Default	Single glazed, low E high solar gain	Aluminium	5.4	0.58	To unit: 1 – east facing glazing To unit: 2 – all glazing
Default	Double glazed, low E high solar gain	Aluminium	4.3	0.53	To unit: 1 – south facing glazing
Default	Double glazed, low E low solar gain	Aluminium	4.9	0.33	To units: 15, 16, 17 – all glazing

Skylights	Glass	Frame (U value	SHGC	Detail	
External walls	Construction	Added Insula	ition	Detail		
Brick veneer		R 2.0		As per drawings		
Hebel panel		R 2.0		As per drawings		
Framed with met	al cladding	R 2.5		As per drawings		
Last a sum of a confile	0	A data at language	47	D-4-7		

Internal walls Construction	Added Insulation	Detail
Plasterboard on studs	None	Within units
Hebel	None	Party/ common walls generally
Hebel / Concrete	R 1.0	Internal apartment walls adjoining common lobbies, lift core, stairwells to units: 1, 3, 7, 16
Hebel / Concrete	R 2.0	Internal apartment walls adjoining common lobbies, lift core, stairwells to units: 2, 6

0				
Floors	Construction	Added Insulation	Detail	
Concrete		None	Generally	
Concrete		R 1.0	To units: 4, 6	
Concrete		R 1.5	To units: 1, 2, 3	

Ceilings	Construction	Added Insulation	Detail	
Plasterboard	i	(see roof detail below)		

To units: 15, 16, 17

ń				_
ı	Other	Real	ireme	n

ist fans and downlights (if installed) to be sealed to prevent air-infiltration

p		9	n	S	
De	Si	igr	S	tud	io
ABN			2 4 6		
REGIS	TRA	TION N	IUMBE	R: 5968	

			_ ^ ^ _	PTY LTD
Α	23.5.17	ISSUE FOR D.A.	(ΔI)	Plans
В		ISSUE FOR D.A.		1 Idiis
С	30.11.18	REFER TO NOTES AS REQUESTED BY COUNCIL	DESIGN	Solutions
D	30.08.19	AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19	39 Cumberland Rd Auburn NS\	W 2144
E	14.10.19	AMENDED AS REQUESTED BY COUNCIL	P: (02) 8068 2177	ABN 88 606 740 381
			M: 0416009172	
			 E: info@cadplans.net. 	au





RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH,NSW 2750

COVER PAGE

16011 DA00



PERSPECTIVE-CAMERA VIEW FROM CASTLEREAGH STREET

ARCHITECTURAL DRAWINGS ARCHITECTURAL DRAWINGS DRAWING NUMBERS SHEET NAME DRAWING NUMBERS SHEET NAME

DRAWING NUMBERS	SHEET NAME	Issue	DRAWING NUMBERS	SHEET INAIVIE	Issue
16011 DA00	COVER PAGE	E	16011 DA14	SHADOW DIAGRAMS	E
16011 DA01	SITE CONTEXT	E	16011 DA14.1	SHADOW DIAGRAMS	E
16011 DA02	SITE PLAN	E	16011 DA14.2	SHADOW DIAGRAMS	E
16011 DA03	BASEMENT PLAN LVL-2	E	16011 DA14.3	SHADOW DIAGRAMS	E
16011 DA04	BASEMENT PLAN LVL-1	E	16011 DA14.4	SOLAR STUDY	E
16011 DA05	GROUND FLOOR PLAN	E	16011 DA14.5	SOLAR STUDY	E
16011 DA06	LEVEL-1	E	16011 DA14.6	SOLAR STUDY	E
16011 DA07	LEVEL-2	E	16011 DA14.7	SOLAR STUDY	E
16011 DA08	LEVEL-3	E	16011 DA14.11	SOLAR ANALYSIS	E
16011 DA09	LEVEL-4	E	16011 DA14.12	SOLAR ANALYSIS	E
16011 DA10	ROOF TERRACE	E	16011 DA14.13	SOLAR ANALYSIS	E
16011 DA11	ELEVATIONS	E	16011 DA14.14	SOLAR ANALYSIS	E
16011 DA12	ELEVATIONS	E	16011 DA15	VIEW FROM SUN	E
16011 DA13	SECTIONS	E			

PROPOSED RESIDENTIAL DEVELOPMENT 29/31 CASTLEREAGH STREET PENRITH, NSW 2750

DEVELOPMENT APPLICATION

+ P-18 m: Range [17.0-18.9 m] (pub. 2015-02-25)

+ Conservation Area - General : Hornseywood (pub. 2015- 02-25)




+ R4 - High Density Residential : (pub. 2015-02-25)

+ S - 800 m2 : Range [800 - 899 sqm] (pub. 2015-02-25)

LEP MAPS



SITE LOCATION





VIEW FROM CASTLEREAGH STREET-THE SITE



VIEW FROM DERBY ST-APARTMENT BLDG.

PROJECT STATUS:



VIEW FROM CASTLEREAGH STREET-PENRITH RSL



VIEW FROM CASTLEREAGH STREET



VIEW FROM DERBY STREET-PENRITH BOWLING CLUB VIEW FROM DERBY STREET-KMART

Design Studio

 A
 23.5.17
 ISSUE FOR D.A.

 B
 ISSUE FOR D.A.

 C
 30.11.18
 REFER TO NOTES AS REQUESTED BY COUNCIL

 D
 30.08.19
 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19

CAD Plans

DESIGN Solutions


DIAL BEFORE YOU DIG

DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH, NSW 2750

SHEET TITLE:
SITE CONTEXT

DATE: SCALE: A1 - 1:100 A3 - 1:200 A3 - 1:200 A6011 DA01



BASEMENT PLAN LVL-2

Design Studio

CAD Plans

DESIGN Solutions A 23.5.17 ISSUE FOR D.A.

B ISSUE FOR D.A.

C 30.11.18 REFER TO NOTES AS REQUESTED BY COUNCIL

D 30.08.19 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19 E 14.10.19 AMENDED AS REQUESTED BY COUNCIL

DIAL BEFORE YOU DIG

PROJECT STATUS: DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH,NSW 2750 CLIENT:

BASEMENT PLAN LVL-2

16011 DA03

BASIX COMMITMENTS

Project name	29-31 Castlereagh Street, Penrith 03
Street address	29-31 Castlereagh Street Penrith 2750
Local Government Area	Penrith City Council
Plan type and plan number	deposited 1190616
Lot no.	2
Section no.	-
Project type	
No. of residential flat buildings	1
No. of units in residential flat buildings	17
No. of multi-dwelling houses	0
No. of single dwelling houses	0
Site details	
Site area (m²)	887
Roof area (m²)	238
Non-residential floor area (m²)	0.0
Residential car spaces	22
Non-residential car spaces	0

Common area landscape		
Common area lawn (m²)	50.0	
Common area garden (m²)	179.4	
rea of indigenous or low water use pecies (m²)	0.0	
Assessor details		
Assessor number	BDAV/12/1475	
Certificate number	0004279140	
Climate zone	28	
Project score		
Vater	✓ 40	Target 40
hermal Comfort	✓ Pass	Target Pass
Energy	✓ 35	Target 35
	_	

Description of project

The tables below describe the dwellings and common areas within the project

Residential flat buildings - Building1, 17 dwellings, 5 storeys above ground

Dwelling no.	No. of bedrooms	ned (Unconditioned floor area (m²)	Area of garden & lawn (m²)	Indigenous species (min area m²)	Dwelling no.	No. of bedrooms	nditioned :a (m²)	Unconditioned floor area (m²)	Area of garden & lawn (m²)	Indigenous species (min area m²)	Dwelling no.	No. of bedrooms	Conditioned floor area (m²)	Unconditioned floor area (m²)	Area of garden & lawn (m²)	Indigenous species (min area m²)	Dwelling no.	No. of bedrooms	Conditioned floor area (m²)	Unconditioned floor area (m²)	Area of garden & lawn (m²)	Indigenous species (min area m²)
1	1	48.5	0.0	9.4	0.0	2	1	35.3	4.0	10.7	0.0	3	2	71.0	0.0	0.0	0.0	4	2	72.8	0.0	0.0	0.0
5	1	41.5	4.9	0.0	0.0	6	1	44.1	8.8	0.0	0.0	7	2	64.9	0.0	0.0	0.0	8	2	66.3	0.0	0.0	0.0
9	2	60.2	4.0	0.0	0.0	10	3	83.9	0.0	0.0	0.0	11	2	67.1	0.0	0.0	0.0	12	2	60.2	4.0	0.0	0.0
13	3	83.9	0.0	0.0	0.0	14	2	67.1	0.0	0.0	0.0	15	1	50.0	5.0	0.0	0.0	16	2	63.6	5.0	0.0	0.0
17	1	51.1	0.0	0.0	0.0																		

Description of project

The tables below describe the dwellings and common areas within the project

Common areas of unit building - Building1

Common area	Floor area (m²)	Common area	Floor area (m²)	Common area	Floor area (m²)
Car park area, basement LVL1	558.3	Car park area, basement LVL2	475.0	Lift car (No.1)	190
Waste Room	15.6	Other internal, storage	37.0	Ground floor lobby types	23.1
Hallway/lobby types	45.0				

The commitments set out below regulate how the proposed development is to be carried out. It is a condition of any development consent granted, or complying development certificate issued, for the proposed development, that BASIX commitments be complied with.


1. Commitments for Residential flat buildings - Building

(a) Dwellings

) Water	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must comply with the commitments listed below in carrying out the development of a dwelling listed in a table below	<i>i</i> .		
(b) The applicant must plant indigenous or low water use species of vegetation throughout the area of land specified for the dwelling in the "Indigenous species" column of the table below, as private landscaping for that dwelling. (This area of indigenous vegetatic is to be contained within the "Area of garden and lawn" for the dwelling specified in the "Description of Project" table.)	n 🎺	∀	
(c) If a rating is specified in the table below for a fixture or appliance to be installed in the dwelling, the applicant must ensure that each such fixture and appliance meets the rating specified for it.		V	V
(d) The applicant must install an on demand hot water recirculation system which regulates all hot water use throughout the dwelling where indicated for a dwelling in the "HW recirculation or diversion" column of the table below.	0	~	V
(e) The applicant must install:			
(aa) a hot water diversion system to all showers, kitchen sinks and all basins in the dwelling, where indicated for a dwelling in the "HW rediculation or diversion" column of the table below, and		⊌	¥
(bb) a separate diversion tank (or tanks) connected to the hot water diversion systems of at least 100 litres. The applicant must connect the hot water diversion tank to all toilets in the dwelling.		V	~
(e) The applicant must not install a private swimming pool or spa for the dwelling, with a volume exceeding that specified for it in the table below.	~	~	
(f) If specified in the table, that pool or spa (or both) must have a pool cover or shading (or both).		~	
(g) The pool or spa must be located as specified in the table.	~	V	
(h) The applicant must install, for the dwelling, each alternative water supply system, with the specified size, listed for that dwelling in the table below. Each system must be configured to collect run-off from the areas specified (excluding any area which supplies any other alternative water supply system), and to divert overflow as specified. Each system must be connected as specified.	~	V	V

(ii) Energy	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(f) This commitment applies to each room or area of the dwelling which is referred to in a heading to the "Natural lighting" column of the table below (but only to the extent specified for that room or area). The applicant must ensure that each such room or area is fitted with a window and/or skylight.	Val.	~	~
(g) This commitment applies if the applicant installs a water heating system for the dwelling's pool or spa. The applicant must:			
(aa) install the system specified for the pool in the "Individual Pool" column of the table below (or alternatively must not install any system for the pool). If specified, the applicant must install a timer, to control the pool's pump; and		<u> </u>	
(bb) install the system specified for the spa in the "Individual Spa" column of the table below (or alternatively must not install any system for the spa). If specified, the applicant must install a timer to control the spa's pump.		~	
(h) The applicant must install in the dwelling:			
(aa) the kitchen cook-top and oven specified for that dwelling in the "Appliances & other efficiency measures" column of the table below;		~	
(bb) each appliance for which a rating is specified for that dwelling in the "Appliances & other efficiency measures" column of the table, and ensure that the appliance has that minimum rating; and		~	
(cc) any clothes drying line specified for the dwelling in the "Appliances & other efficiency measures" column of the table.		~	
(i) If specified in the table, the applicant must carry out the development so that each refrigerator space in the dwelling is "well ventilated".		~	

	Hot water	Bathroom ven	tilation system	Kitchen venti	lation system	Laundry ventilation system		
Dwelling Hot water system no.		Each bathroom	Operation control	Each kitchen	Operation control	Each laundry	Operation control	
All dwellings	central hot water system 1	individual fan, ducted to taçade or root	manual switch on/off	individual fan, not ducted	manual switch on/off	individual fan, ducted to taçade or root	manual switch on/off	



	Fixtures						ances	Individual pool			Individual spa			
Dwelling no.	All shower- heads	All toilet flushing systems	All kitchen taps	All bathroom taps	HW recirculation or diversion	All clothes washers	All dish- washers	Volume (max volume)	Pool cover	Pool location	Pool shaded	Volume (max volume)	Spa cover	Spa shaded
All dwellings	3 star (> 4.5 but <= 6 L/min)	4 star	4 star	4 star	-	-	3 star	-)=:	-	-	-	-	-:

Dwelling no.	Alternative water supply systems	Size	Configuration	Landscape connection	Toilet connecti (s)		undry nnection	Pool top-up	Spa top-u
None	-1	-		-	-			-	/#I
(ii) Energy						Show on DA plans		v on CC/CDC s & specs	Certifier check
(b) The applied to	cant must install each hot v	ater system spec specifies a central	d below in carrying out the development of a dwellin fied for the dwelling in the table below, so that the hot water system for the dwelling, then the applica	welling's hot wa	ter is	4		~	<u> </u>
(c) The applic	cant must install, in each ba	throom, kitchen a	nt water is supplied by that central system. In a laundry of the dwelling, the ventilation system so The table.	pecified for that r	oom in			V	V
areas" he no cooling any such	adings of the "Cooling" and or heating system is spec	l "Heating" columi ified in the table for s specified beside	em/s specified for the dwelling under the "Living are is in the table below, in/for at least 1 living/bedroom ir "Living areas" or "Bedroom areas", then no syste an air conditioning system, then the system must p	area of the dwe	lling. If led in			*	~
the table lighting" for specified	below (but only to the exter or each such room in the d	nt specified for that welling is fluoresco a, then the light fit	welling which is referred to in a heading to the "Arti troom or area). The applicant must ensure that the ent lighting or light emitting diode (LED) lighting. If the ings in that room or area must only be capable of the	"primary type of ne term "dedicate	artificial			~	V

PROJECT STATUS:

	Cooling		Heating		Artificial lighting					Natural lighting		
Dwelling no.	living areas	bedroom areas	living areas	bedroom areas	No. of bedrooms &/or study	No. of living &/or dining rooms	Each kitchen	All bathrooms/ toilets	Each laundry	All hallways	No. of bathrooms &/or toilets	Main kitche
10, 13	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	3 (dedicated)	2 (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	0	yes
15, 16	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	2 (dedicated)	2 (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	1	yes
2, 4, 5, 6, 9, 12	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	2 (dedicated)	2 (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	1	no
All other dwellings	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	1-phase airconditioning 5 Star	2 (dedicated)	2 (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	yes (dedicated)	0	no

Dwelling no.	Individual pool		Individual spa		Appliances & other efficiency measures							
	Pool heating system	Timer	Spa heating system	Timer	Kitchen cooktop/oven	Refrigerator	Well ventilated fridge space	Dishwasher	Clothes washer	Clothes dryer	Indoor or sheltered dothes drying line	Private outdoor or unsheltered clothes drying line
1, 2, 3, 4	+	8	8	-	gas cooktop & electric oven	3.5 slar (new rating)	no	3.5 star	B	2 star	(8)	yes
All other dwellings	*:	-	-	-	gas cooktop & electric oven	3.5 star (new rating)	no	3.5 star	-	2 star	1(=)	-

(iii) Thermal Comfort	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must attach the certificate referred to under "Assessor details" on the front page of this BASIX certificate (the "Assessor Certificate") or the development application and construction certificate application for the proposed development (or, if the applicant is applying for a complying development certificate for the proposed development, to that applicant in must also attach the Assessor Certificate to the application for a final occupation certificate for the proposed development.			

pens Design Studio

			_ ^ ^ -	PTY LTD
Α	23.5.17	ISSUE FOR D.A.	$=(\Delta I)$	Plans
В		ISSUE FOR D.A.		1 Idilo
С	30.11.18	REFER TO NOTES AS REQUESTED BY COUNCIL	DESIGN	Solutions
D	30.08.19	AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19	39 Cumberland Rd Auburn NS	W 2144
Е	14.10.19	AMENDED AS REQUESTED BY COUNCIL	P: (02) 8068 2177	ABN 88 606 740 381

DIAL BEFORE YOU DIG

DEVELOPMENT APPLICATION

29-31 C/ 2750 CHEMIN STHE PROPERTY OF CAD PLANS PHY Ltd AND MUST

RESIDENTIAL BUILDING DEVELOPMENT
SITE ADDRESS:
29-31 CASTLEREAGH ST, PENRITH,NSW 2750

ROOF	TERRAC	CE		ISSUE:
DESIGN: NS	DRAWN: AJRSA	DATE: JUNE 2016	SCALE: A1 - 1:100 A3 - 1:200	16011 DA10

Document Set ID: 8892343

Version: 1, Version Date: 17/10/2019

W/1601129-31 castereaghst pennth/Architectural/REVIT/Series C/29-31 Castereagh St Pennth-Ser

BASIX COMMITMENTS

(iii) Thermal Comfort	Show on DA plans	Show on CC/CDC plans & specs	Certifier
(b) The Assessor Certificate must have been issued by an Accredited Assessor in accordance with the Thermal Comfort Protocol.			
(c) The details of the proposed development on the Assessor Certificate must be consistent with the details shown in this BASIX Certificate, including the details shown in the "Thermal Loads" table below.			
(d) The applicant must show on the plans accompanying the development application for the proposed development, all matters which the Thermal Comfort Protocol requires to be shown on those plans. Those plans must bear a stamp of endorsement from the Accredited Assessor, to carify that this is the case.	4		
(e) The applicant must show on the plans accompanying the application for a construction certificate (or complying development certificate, if applicable), all thermal performance specifications set out in the Assessor Certificate, and all aspects of the proposed development which were used to calculate those specifications.		~	
(f) The applicant must construct the development in accordance with all thermal performance specifications set out in the Assessor Certificate, and in accordance with hose aspects of the development application or application for a complying development certificate which were used to calculate those specifications.		~	v
(g) Where there is an in-slab heating or cooling system, the applicant must:	4	<u> </u>	·
(aa) Install insulation with an R-value of not less than 1.0 around the vertical edges of the perimeter of the slab; or			
(bb) On a suspended floor, install insulation with an R-value of not less than 1.0 underneath the slab and around the vertical edges of the perimeter of the slab.			
(h) The applicant must construct the floors and walls of the development in accordance with the specifications listed in the table below.	v.	•	

	Thermal loads						
Dwelling no.	Area adjusted heating load (in mJ/m²/yr)	Area adjusted cooling load (in mJ/m²/yr)					
1	60.6	31.9					
2	63.1	41.1					
3	59.7	25.5					
4	39.8	25.5					
5	40.8	48.6					
6	61.5	36.1					
7	49.4	36.9					
8	12.7	27.6					

	Thermal loads					
Dwelling no.	Area adjusted heating load (in mJ/m²/yr)	Area adjusted cooling load (in mJ/m²/yr)				
9	22.2	43.4				
10	51.2	38.0				
11	11.7	20.7				
12	22.4	43.4				
13	57.6	43.1				
14	12.3	35.6				
15	36.8	53.8				
16	63.0	54.5				
All other dwellings	32.7	48.8				

CAD Plans

DESIGN Solutions

(b) Common areas and central systems/facilities

(i) Water	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) If, in carrying out the development, the applicant installs a showerhead, toilet, tap or clothes washer into a common area, then that item must meet the specifications listed for it in the table.		~	4
(b) The applicant must install (or ensure that the development is serviced by) the alternative water supply system(s) specified in the "Central systems" column of the table below. In each case, the system must be sized, be configured, and be connected, as specified in the table.	*	~	¥
(c) A swimming pool or spa listed in the table must not have a volume (in kLs) greater than that specified for the pool or spa in the table.	4	~	
(d) A pool or spa listed in the table must have a cover or shading if specified for the pool or spa in the table.		✓	
(e) The applicant must install each fire sprinkler system listed in the table so that the system is configured as specified in the table.		✓	¥
(f) The applicant must ensure that the central cooling system for a cooling tower is configured as specified in the table.		✓	¥

Common area	Showerheads rating	Toilets rating	Taps rating	Clothes wa	shers rating	
All common areas	no common facility	4 star	4 star	no common	laundry facility	
(ii) Energy				Show DA pla		Certifier
			service a common area specified in the narea, and must meet the efficiency me	table	~	¥
specified in	the table below, the lighting spec nt must also install a centralised	ified for that common area. This ligh	of artificial lighting" for each common an nting must meet the efficiency measure fanagement System (BMS) for the com	specified.	*	~
		ktures specified in the "Central energe, and meet the specifications, liste	gy systems" column of the table below.	In each	_	-

	Common area	ventilation system	Common area lighting			
Common area	Ventilation system type	Ventilation efficiency measure	Primary type of artificial lighting	Lighting efficiency measure	Lighting control system/BMS	
Car park area, basement LVL1	vertilation (supply + exhaust)	carbon monoxide monitor + VSD fan	fluorescent	motion sensors	No	
Car park area, basement LVL2	vertilation (supply + exhaust)	carbon monoxide monitor + VSD fan	fluorescent	motion sensors	No	
Lift car (No.1)	-	-	compact fluorescent	connected to lift call button	No	
Waste Room	no mechanical ventilation	-	fluorescent	motion sensors	No	
Other internal, storage	vertilation supply only	time clock or BMS controlled	fluorescent	motion sensors	No	
Ground floor lobby types	no mechanical ventilation	-	compact fluorescent	manual on / timer off	No	
Hallway/lobby types	no mechanical ventilation	-	compact fluorescent	manual on / timer off	No	

Central energy systems	Туре	Specification	
Central hot water system (No. 1)	gas-fired storage (manifolded)	Piping insulation (ringnain & supply risers): (a) Piping external to building: R1.0 (~38 mm); (b) Piping internal to building: R1.0 (~38 mm)	
Lift (No. 1)	gearless traction with V V V F motor	Number of levels (including basement): 8	

AREA SCHEDULES

RESIDENTIAL BUILDING DEVELOPMENT

2750

29-31 CASTLEREAGH ST, PENRITH,NSW

ELEVATIONS

Ε

16011 DA11

AKEA	SCHEL	JULES						
UNIT NUMBER	NO. OF BED	UNIT AREA (m²)	BALCONY AREA (m²)	SOLAR ACCESS	CROSS VENTILATION	STORAGE UNIT (m³)	STORAGE BASEMENT(m³)	STORAGE TOTAL (m ²
1	1 BED	52.20m²	23.19m²	YES	YES	4.23m³	4.20m³	8.43m³
2	STUDIO	41.30m²	19.40m²	NO	YES	4.00m³	4.20m³	8.20m³
3	2 BED	75.90m²	17.20m²	YES	YES	4.00m³	4.66m³	8.66m³
4	2 BED	76.80m²	16.20m²	YES	YES	4.30m³	8.00m³	12.30m³
5	1 BED	50.40m²	8.20m²	YES	YES	3.50m³	4.66m³	8.16m³
6	1 BED	56.20m²	8.00m²	NO	YES	4.00m³	5.52m³	9.52m³
7	2 BED	70.00m²	10.10m²	YES	YES	4.00m³	5.14m³	9.14m³
8	2 BED	70.10m²	10.00m²	YES	YES	4.00m³	5.14m³	9.14m³
9	2 BED	70.10m²	10.10m²	YES	YES	4.00m³	5.14m³	9.14m³
10	3 BED	90.10m²	12.10m²	NO	YES	5.00m³	5.52m³	10.52m³
11	2 BED	70.10m²	10.00m²	YES	NO	4.00m³	8.72m³	12.72m³
12	2 BED	70.10m²	10.00m²	YES	YES	4.00m³	8.72m³	12.72m³
13	3 BED	90.10m²	12.10m²	YES	YES	5.00m³	10.42m³	15.42m³
14	2 BED	70.10m²	10.00m²	YES	NO	4.00m³	8.72m³	12.72m³
15	1 BED	59.80m²	8.00m²	YES	YES	4.00m³	4.80m³	8.80m³
16	2 BED	76.20m²	10.60m²	YES	YES	4.00m³	12.48m³	16.48m³
17	1 BED	51.29m²	8.00m²	YES	NO	3.20m³	4.80m³	8.00m ³



PROJECT STATUS:

DIAL BEFORE YOU DIG **DEVELOPMENT APPLICATION**

pens


 A
 23.5.17
 ISSUE FOR D.A.


 B
 ISSUE FOR D.A.


 C
 30.11.18
 REFER TO NOTES AS REQUESTED BY COUNCIL

 D
 30.08.19
 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19











SITE COVERAGE DIAGRAM

PROJECT STATUS:

DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH, NSW 2750

SHADOW DIAGRAMS


16011 DA14.1

Document Set ID: 8892343 Version: 1, Version Date: 17/10/2019

Design Studio 14.10.19 AMENDED AS REQUESTED BY COUNCIL CAD Plans DESIGN Solutions

DIAL BEFORE YOU DIG

SHADOW DIAGRAMS WINTER SOLSTICE **JUNE 21** 9:00 AM SCALE 1:300@A1 1:600@A3



SHADOW DIAGRAMS WINTER SOLSTICE **JUNE 21** 10:00 AM SCALE 1:300@A1 1:600@A3

pens
 A
 23.5.17
 ISSUE FOR D.A.

 B
 ISSUE FOR D.A.

 C
 30.11.18
 REFER TO NOTES AS REQUESTED BY COUNCIL

 D
 30.08.19
 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19
 Design Studio E 14.10.19 AMENDED AS REQUESTED BY COUNCIL

CAD Plans DESIGN Solutions

E: info@cadplans.net.au

DIAL BEFORE YOU DIG

DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH, NSW 2750

LOT 1 DP 1190616

CASTLEREAGH STREET

LOT 1 DP 1190616

CASTLEREAGH STREET

LOT 3 DP 1190616

LOT 4 DP 1190616

LOT 3 DP 1190616

SHADOW DIAGRAMS AJRSA

16011

DA14.2

LOT 132 DP 573847

LOT 132 DP 573847

SHADOW DIAGRAMS **WINTER SOLSTICE JUNE 21** 11:00 AM SCALE 1:300@A1 1:600@A3

STREET

SHADOW DIAGRAMS


WINTER SOLSTICE

JUNE 21

10:00 AM SCALE 1:300@A1 1:600@A3

PROJECT STATUS:

SHADOW DIAGRAMS WINTER SOLSTICE **JUNE 21** 1:00 PM SCALE 1:300@A1 1:600@A3



3:00 PM SCALE 1:300@A1 1:600@A3

pens **Design** Studio

Version: 1, Version Date: 17/10/2019

A 23.5.17 ISSUE FOR D.A.

B ISSUE FOR D.A.

C 30.11.18 REFER TO NOTES AS REQUESTED BY COUNCIL

D 30.08.19 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19 E 14.10.19 AMENDED AS REQUESTED BY COUNCIL E: info@cadplans.net.au

CAD Plans

DESIGN Solutions 39 Cumberland Rd Aubur P: (02) 8068 2177



PROJECT STATUS: DEVELOPMENT APPLICATION

DERBY STREET

SHADOW DIAGRAMS WINTER SOLSTICE

JUNE 21

2:00 PM SCALE 1:300@A1 1:600@A3

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH,NSW 2750

LOT 1 DP 1190616

CASTLEREAGH STREET

LOT 3 DP 1190616

LOT 4 DP 1190616


SHADOW DIAGRAMS AJRSA

Ε

LOT 132 DP 573847

16011 DA14.3


SHADOW DIAGRAMS WINTER SOLSTICE **JUNE 21**



1:200 @ A3

Eastern Solar Analysis-9 00am-Unit 1,5,9,12,15

Eastern Solar Analysis-9 00am - Unit 1,5,9,12,15



Eastern Solar Analysis-10 00am-Unit 1,5,9,12,15

Eastern Solar Analysis-10 00am - Unit 1,5,9,12,15 1:200 @ A3



Eastern Solar Analysis-11 00am-Unit 1,5,9,12,15 Eastern Solar Analysis-11 00am - Unit 1,5,9,12,15 1:200 @ A3



				PIYLID
Α	23.5.17	ISSUE FOR D.A.	('ΔΙ)	Plans
В		ISSUE FOR D.A.		i iaiis
С	30.11.18	REFER TO NOTES AS REQUESTED BY COUNCIL	DESIGN	Solutions
D	30.08.19	AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19	39 Cumberland Rd Auburn NSW	2144
E	14.10.19	AMENDED AS REQUESTED BY COUNCIL	P: (02) 8068 2177	ABN 88 606 740 381
			 M: 0416009172 E: info@cadplans.net.a 	
ISSUE	DATE	AMENDMENT	- L. IIIIO@Gaupians.net.a	iu

DIAL BEFORE YOU DIG

PROJECT STATUS: DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH, NSW 2750


	SHEET TITLE:			
V	SOLAR	ANALYSI	S	
-	DESIGN:	DRAWN: AJRSA	DATE: JUNE 2016	SC: A1 - A3 -

Ε 16011

DA14.11


Eastern Solar Analysis-9 00am-Unit 8,11,14,17

Eastern Solar Analysis-9 00am - Unit 8,11,14,17 1:200 @ A3



Eastern Solar Analysis-10 00am-Unit 8,11,14,17

Eastern Solar Analysis-10 00am - Unit 8,11,14,17 1:200 @ A3



Eastern Solar Analysis-11 00am-Unit 8,11,14,17

Eastern Solar Analysis-11 00am - Unit 8,11,14,17 1:100 @ A1 1:200 @ A3

pens **Design** Studio

 A
 23.5.17
 ISSUE FOR D.A.

 B
 ISSUE FOR D.A.

 C
 30.11.18
 REFER TO NOTES AS REQUESTED BY COUNCIL

 D
 30.08.19
 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19

CAD Plans DESIGN Solutions


DIAL BEFORE YOU DIG

DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH,NSW 2750

SOLAR ANALYSIS

Ε 16011 DA14.12



Northern Solar Analysis-9 40am-Unit 3,4,7



Northern Solar Analysis-9 40am - Unit 3,4,7



Northern Solar Analysis-11 40am-Unit 3,4,7



Northern Solar Analysis-10 40am-Unit 3,4,7



Northern Solar Analysis-10 40am - Unit 3,4,7

1:200 @ A3



Northern Solar Analysis-11 40am - Unit 3,4,7

PROJECT STATUS:

1:200 @ A3

DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH,NSW 2750

SOLAR ANALYSIS


Ε 16011 DA14.13

pens **Design** Studio


23.5.17 ISSUE FOR D.A.
ISSUE FOR D.A.
30.11.18 REFER TO NOTES AS REQUESTED BY COUNCIL

CAD Plans DESIGN Solutions D 30.08.19 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19


DIAL BEFORE YOU DIG




Northern Solar Analysis-12 30pm-Unit 13,16



Northern Solar Analysis-12 30pm - Unit 13,16 1:200 @ A3



Northern Solar Analysis-1 30pm-Unit 13,16



Northern Solar Analysis-1 30pm - Unit 13,16 1:200 @ A3



Northern Solar Analysis-2 30pm-Unit 13,16



Northern Solar Analysis-2 30pm - Unit 13,16 1:100 @ A1 1:200 @ A3

PROJECT STATUS:

DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT
SITE ADDRESS:
29-31 CASTLEREAGH ST, PENRITH,NSW
2750
CLIENT:

	SHEET TITLE:			
	SOLAR	ANALYS	SIS	
/				
	DESIGN: NS	DRAWN: AJRSA	DATE: JUNE 2016	SCALE: A1 - 1:100 A3 - 1:200

Ε 16011 DA14.14

pens **Design** Studio

 A
 23.5.17
 ISSUE FOR D.A.

 B
 ISSUE FOR D.A.


 C
 30.11.18
 REFER TO NOTES AS REQUESTED BY COUNCIL

 D
 30.08.19
 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19

CAD Plans

DESIGN Solutions

DIAL BEFORE YOU DIG



Design Studio

CAD Plans

DESIGN Solutions
 A
 23.5.17
 ISSUE FOR D.A.

 B
 ISSUE FOR D.A.

 C
 30.11.18
 REFER TO NOTES AS REQUESTED BY COUNCIL

 D
 30.08.19
 AMENDED AS REQUESTED BY COUNCIL DATED 29-08-19

DIAL BEFORE YOU DIG

DEVELOPMENT APPLICATION

RESIDENTIAL BUILDING DEVELOPMENT 29-31 CASTLEREAGH ST, PENRITH,NSW 2750 VIEW FROM SUN

DATE: SCALE: A1 - 1:100 A3 - 1:200 A3 - 1:200 A5 - 1:20



Penrith Local Planning Panel

Determination and Statement of Reasons

APPLICATION NUMBER	DA18/0132– 29 – 31 Castlereagh Street Penrith
DATE OF DETERMINATION	11 September 2019
PANEL MEMBERS	The Hon. Carl Scully (Chair) John Brunton (Expert) Mary-Lynne Taylor (Expert) Stephen Welsh (Community Representative)
DECLARATIONS OF INTEREST	No conflicts of interest were declared.
LISTED SPEAKER(S)	Nasr Atie - CAD Plans Pty Ltd (Director and Applicant) Barbara Brown - Resident

Public Meeting held at Penrith City Council on Wednesday 11 September 2019, opened at 3:00pm.

Matter Determined pursuant to Section 4.16 of the Environmental Planning and Assessment Act 1979

Development Application DA18/0132 at Lot 2 DP 1190616 at 29 – 31 Castlereagh Street, Penrith - Construction of a Five (5) Storey Residential Flat Building containing 17 Apartments & Two (2) Levels of Basement Car Parking.

Panel Consideration

The Panel had regard to the assessment report prepared by Council officers, submissions received, site observations, supplementary memo and the following plans;

- Local Environmental Plan 2010 (Amendment 4)
- Development Control Plan 2014
- State Environmental Planning Policy (Building Sustainability Index: BASIX) 2004
- State Environmental Planning Policy No 55 Remediation of Land
- State Environmental Planning Policy No 65 Design Quality of Residential Flat Development
- Sydney Regional Environmental Plan No 20 Hawkesbury Nepean River

In terms of considering community views, the Panel noted there were three (3) submissions received from the public notification of the Development Application.

Consideration of Recommendation

The Panel considered the report prepared by the assessment officer and a supplementary memorandum dated 11th September 2019 with revised concept ground floor plan and foreshadows the potential to further investigate and resolve waste management concerns raised by Council's Waste Management Section which have been outlined within the assessment report.

It is considered that the side setback non-compliance with the Apartment Design Guide to the southern adjoining property is not supportable given heritage conservation considerations and the proposal should be further amended to ensure a compliant 6.0m setback is provided for the first 15m into the site. This will necessitate further amendment of the development to achieve this setback and provide necessary ground floor waste storage and bulky waste storage provision for servicing as reflected within the revised concept plan.

Upon resolution of the above issue, the Panel finds that the proposal in terms of the amended built form, landscape design and architecture can be supported however it must still be demonstrated that resolution of waste management issues to meet the DCP and Guidelines does not unreasonably compromise these supported built form outcomes.

As such, the assessing officer's recommendation for the issue of a deferred commencement consent is not supported and it is instead resolved that the application be deferred by the Panel to enable the applicant to further liaise with Council to address the following matters:-

- Further amendment to the development to achieve a compliant 6.0m side southern boundary setback for the first 15m into the site as measured from the front property boundary:
- Further amendment of Unit 2 to accommodate an acceptable waste and bulky waste storage area similar to what is reflected within the concept plan supporting the above memorandum;
- Revision to the private open space for Unit 2 as indicated within the concept plan to provide built form / landscape separation to the proposed waste storage facilities and useable private open space areas for the use of the future residents of Unit 2;
- Amendment to the landscape plan to reflect the above design changes including paths
 of access from the kerb line to the waste storage areas. This includes deletion of front
 boundary fencing as indicated within the current architectural plans and embellished
 planting within the southern boundary setback zone;
- Deletion of the footpath within the southern side boundary setback zone
- Amendment to the civil design drawings to reflect the design changes referenced above:
- Submission of an amended BASIX Certificate that reflects the amended development resulting from the above requirements.

In the event that waste servicing by Council cannot be supported by Council's Waste Management Officers, a supplementary report is to be provided to the Panel that outlines the issues of concern and reasons why engagement of a private waste contractor is the only available or viable option to service the proposed development.

Upon resolution of the above issues, the matter be reported back and may be determined by the Local Planning Panel by way of electronic determination, subject to agreement from the Panel Chairperson.

Panel Decision

Pursuant to the provisions of Section 4.16 of the Environmental Planning and Assessment Act, 1979, Development Application DA18/0132 for Construction of a Five (5) Storey Residential Flat Building containing 17 Apartments & Two (2) Levels of Basement Car Parking at 29 – 31 Castlereagh Street Penrith be deferred for further amendments to be undertaken as outlined above.

Votes

The decision was unanimous.

The Hon. Carl Scully – Chair	John Brunton - Expert
Muly	Januar -
Mary-Lynne Taylor – Expert	Stephen Welsh – Community Representative
1111	-EML.



MEMORANDUM

To: Local Planning Panel

From: Lauren Van Etten, Development Assessment Planner

Date: 11 September 2019

Subject: DA18/0132 – 29 – 31 Castlereagh Street Penrith

I refer to the above matter scheduled for determination with the Local Planning Panel on 11 September 2019.

Concept Plan - Waste Management

In response to the deferred commencement recommendation, the applicant has provided a concept ground floor plan to incorporate a waste collection room and bulky waste collection room that better reflects the technical requirements within Council's DCP and Waste Management Guidelines.

The amended concept ground floor plan is attached for your information. The implications of the changes to the ground floor design is that now one unit has reduced in size to a studio unit and the private open space has slightly altered.

This ground floor amendment has been reviewed and spatially is in accordance with the waste requirements. There are however further amendments required with respect to the location and extent of private open space and implications on the front façade and streetscape elevation.

The submission of this plan does not satisfy the scope of amendments required by the deferred commencement conditions, however it does provide a more compliant and serviceable outcome which has the potential to support kerbside collection.

Since the finalisation and issue of the assessment report, further discussions with Council's Waste Management Officer have occurred which has identified a potential for Council's contracted Waste Service to support this development. The key remaining non compliances being inclusion of chutes and on-site collection still require a negotiated agreement which is yet to be secured.

Requested Condition Amendments Based on Current Recommendation

Deferred Commencement Condition 87(a) is recommended to be deleted and replaced as follows;

a) Prior to the issue of an operational consent, revised architectural plans and landscape plan(s) shall be provided to ensure the required waste storage area is provided on ground floor within 10m of the kerb, integrated into the design of the building and in accordance with the design requirements of Penrith Council's Residential flat building waste management guidelines and C5 of Development Control Plan 2014.

In addition, any fencing within the front setback alongside private open space and/or the waste areas and waste pathway shall provide masonry or face brick pilasters with horizontal or vertical slatting.



MEMORANDUM

Deferred Commencement Condition 87(d) is recommended to be added as follows;

d) Prior to the issue of an operational consent, the revised elevation plans shall incorporate face brickwork as per the endorsed perspective up until Level 4.

Deferred Commencement Condition 87(e) is recommended to be added as follows;

e) Prior to the issue of an operational consent, the civil design plans (stormwater management) are to be amended to ensure consistency with the finalised amended architectural drawings.

Lauren Van Etten

Development Assessment Planner