



NatHERS Rated
6.0/10 STARS*

*www.nathers.gov.au



BUILDING ENERGY EFFICIENCY CERTIFICATE

Rawson Homes

ISSUED TO

Lot 2309 Empire Circuit

ADDRESS

Site Lot 2309

THORNTON

NSW

2750

1006760720

CERTIFICATION NUMBER

19/08/2014

DATE

28

CLIMATE ZONE

BERS Professional - v4.2.110811/A (BERS Professional)

SOFTWARE

43.0 MJ/m² pa

SIMULATED ENERGY CONSUMPTION - HEATING

39.0 MJ/m² pa

SIMULATED ENERGY CONSUMPTION - COOLING

82.0 MJ/m² pa

TOTAL SIMULATED ENERGY CONSUMPTION

115.0 m²

FLOOR AREA - CONDITIONED

10.0 m²

FLOOR AREA - UNCONDITIONED

125.0 m²

FLOOR AREA - TOTAL

Fadi Sweis

ASSESSOR NAME

20390

ASSESSOR NUMBER

Energy Ratings Australia Pty Ltd

COMPANY

ASSESSOR SIGNATURE

Issued by a BUILDING THERMAL PERFORMANCE ASSESSOR accredited by the Association of Building Sustainability Assessors to provide NatHERS house energy ratings.