

PENRITH CITY COUNCIL

FAST LIGHT ASSESSMENT REPORT

Application number:	DA20/0276
Proposed development:	Demolition of Garage and Carport
Property address:	90 Canberra Street, OXLEY PARK NSW 2760
Property description:	Lot 192 DP 16937
Date received:	20 May 2020
Assessing officer	Louis Tuma
Zoning:	Zone R3 Medium Density Residential - LEP 2010
Class of building:	N/A
Recommendation:	Approve

Executive Summary

Council is in receipt of a development application for the subject development on the subject site and the proposal is a permissible land use with Council consent.

Site & Surrounds

The subject site is situated on the southern side of Canberra Street OXLEY PARK. It is 1074m² in area, is orientated in a northern direction and is considered to be relatively flat.

An inspection of the site was undertaken on 15/06/2020 and the site is currently occupied by a single storey dwelling and associated structures.

The surrounding area is characterised by residential development.

Proposal

The proposed development involves the demolition and removal of a garage, carport and external toilet.

Plans that apply

1996 CENSUS COLLECTORS DISTRICT
PENRITH DCP 2014
DRAFT AMENDMENT - DCP 2014 HOUSEKEEPING
DRAFT LEP 2010 (REVIEW PHASE 1)
GENERAL LIST
DCP 2014 - Tree Preservation Controls
DCP 2014 - General Information
PLAN INST - SREP NO 9 EXT IND (NO 2-1995) AA
PLAN INST - SREP NO 20 HAW NEP RIV (NO2-1997) AA
Local Environmental Plan 2010
Asbestos Policy
PRECINCT 2010
SEC 94 CONTRIB PLAN - CULTURAL FACILITIES
SEC 94 CONTRIB PLAN - LOCAL OPEN SPACE 2007
SEC 94 CONTRIB PLAN - DISTRICT OPEN SPACE FACILS
STATE ENV PLANNING POLICIES - GENERAL LIST
EAST WARD
Zone R3 Medium Density Residential - LEP 2010
LEP 2010 - Additional Land Use Notes

Planning Assessment

• Section 4.15 - Evaluation

The development has been assessed in accordance with the matters for consideration under Section 4.15 of the Environmental Planning and Assessment Act 1979.

Section 4.15(1)(a)(i) The provisions of any environmental planning instrument

Is the development permissible in the zone? **Complies**

Is the development consistent with any requirements of environmental planning instruments relevant to this proposal (including any applicable SEPP's, SREP's and LEP's)? **Complies**

Section 4.15(1)(a)(ii) The provisions of any draft environmental planning instrument

Is the development consistent with any draft planning instruments relevant to this proposal **N/A**

Section 4.15(1)(a)(iii) Any development control plan

Is the development consistent with the provisions of any development control plan relevant to this proposal? **Complies**

Section 4.15(1)(a)(iv) Any applicable regulations

Is the development consistent the provisions of any regulations relevant to this proposal? **Complies**

Section 4.15(1)(b) The likely impacts of the development

Context and setting

Is the development consistent with the bulk, scale colour and design of other development in the locality?	Complies
Will the development have only a minor impact of the amenity of the area and the streetscape?	Complies
Is the development compatible with surrounding and adjacent land uses	Complies
Will the development have no or minimal impact on the amenity of the area in terms of:	
Sunlight (overshadowing):	Complies
Visual and acoustic privacy:	Complies
Views or vista:	Complies

Access and Transport

Will the development have no or minimal impact on the local road system	Complies
Is the existing and any proposed access arrangements and car parking on site adequate for the development?	Complies

Heritage

The property is not subject to any heritage order or is identified as heritage under a planning instrument.	N/A
---	------------

Soil

The development will have minimal impact on soil erosion and sedimentation	Complies
--	-----------------

Natural and Technological Hazards

The development is not subject to flooding, subsidence or slip	Complies
Land is not considered to be contaminated:	Complies
Bushfire requirements provided for the development	N/A
Acoustic requirements provided for the development	Complies

Site design

The development is sensitive to environmental conditions and site attributes.	Complies
Does the development safe guard the health and safety of the occupants	Complies

Section 4.15(1)(c) The suitability of the site for development

Was the site inspected?	Yes
Does the proposal fit locality?	Yes
Are the site attributes conducive to development?	Yes
Will the proposal have minimal social and economic impacts on the locality?	Yes
Has any applicable 88b instrument been considered?	Yes
Does the development propose the removal of trees?	No
Have the plans been checked by any relevant developer groups?	N/A
Has a BASIX certificate been provided?	N/A

Section 4.15(1)(d) Any submissions made in accordance with the EPA Act and Regulations?

Was the application required to be publicly notified?	No
Were any submissions received during the public notification period?	N/A

Section 4.15(1)(e)Public Interest

The application will have minimal impacts on public interest	Complies
--	-----------------

Conclusion/Summary

The site is suitable for the proposed development, the proposal is in the public interest, and there is unlikely to be negative impacts arising from the proposed development.

Therefore, the application is worthy of support, subject to recommended conditions.

Recommendation

That DA20/0276 for the demolition and removal of a garage, carport and external toilet at 90 Canberra Street OXLEY PARK, be approved subject to the attached conditions.

CONDITIONS

General

1 [A02F - Approved Fast Light Das](#)

The development must be implemented substantially in accordance with the stamped-approved plans issued by Penrith City Council, the application form and any supporting information received with the application, except as may be amended in red on the attached plans and by the following conditions.

Demolition

2 [B001 - Demolition of existing structures](#)

The garage, carport and external toilet on the subject site are to be demolished as part of the approved work.

3 [B002 - AS FOR DEMOLITION AND DISPOSAL TO APPROVED LANDFILL SITE](#)

All demolition works are to be conducted in accordance with the provisions of AS 2601-1991 "The Demolition of Structures". **Prior to demolition**, all services shall be suitably disconnected and capped off or sealed to the satisfaction of the relevant service authority requirements.

All demolition and excavated material shall be disposed of at a Council approved site or waste facility. Details of the proposed disposal location(s) of all excavated material from the development site shall be provided to the Principal Certifying Authority **prior to commencement of demolition**.

4 [B003 - ASBESTOS \(amended from Council adopted version\)](#)

Prior to commencement of demolition works on site, a portaloo with appropriate washing facilities shall be located on the site and the Principal Certifying Authority is to be satisfied that:

- Measures are in place so as to comply with the WorkCover Authority's "Short Guide to Working with Asbestos Cement" and
- The person employed to undertake the works is a licensed asbestos removal contractor and is holder of a current WorkCover Asbestos Licence.

Any demolition works involving the removal of all asbestos shall only be carried out by a licensed asbestos removal contractor who has a current WorkCover Asbestos Licence.

All asbestos laden waste, including asbestos cement flat and corrugated sheeting must be disposed of at a tipping facility licensed by the Environmental Protection Authority to receive asbestos wastes.

5 [B004 - Dust](#)

Dust suppression techniques are to be employed during demolition to reduce any potential nuisances to surrounding properties.

6 [B005 - Mud/Soil](#)

Mud and soil from vehicular movements to and from the site must not be deposited on the road.

7 [B006 - Hours of work](#)

Demolition works will be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm (if inaudible on neighbouring residential premises), otherwise 8am to 1pm
- No demolition work is permitted on Sundays and Public Holidays.

In the event that the demolition relates to works inside the building and do not involve external walls or the roof, and do not involve the use of equipment that emits noise then the demolition works are not restricted to the hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

Environmental Matters

8 **D001 - Implement approved sediment& erosion control measures**

Erosion and sediment control measures shall be installed **prior to the commencement of works on site** including approved clearing of site vegetation. The erosion and sediment control measures are to be maintained in accordance with the approved erosion and sediment control plan(s) for the development and the Department of Housing's "Managing Urban Stormwater: Soils and Construction" 2004.

(Note: To obtain a copy of the publication, you should contact Landcom on (02) 98418600).

The approved sediment and erosion control measures are to be installed **prior to and maintained throughout the demolition phase of the development until the land, that was subject to the works, have been stabilised and grass cover established.** These measures shall ensure that mud and soil from vehicular movements to and from the site does not occur during the demolition of the development.

9 **D009 - Covering of waste storage area**

All waste materials stored on-site are to be contained within a designated area such as a waste bay or bin to ensure that no waste materials are allowed to enter the stormwater system or neighbouring properties. The designated waste storage areas shall provide at least two waste bays / bins so as to allow for the separation of wastes, and are to be fully enclosed when the site is unattended.

10 **D010 – Appropriate disposal of excavated or other waste**

All excavated material and other wastes generated as a result of the development are to be re-used, recycled or disposed of in accordance with the approved waste management plan.

Waste materials not specified in the approved waste management plan are to be disposed of at a lawful waste management facility. Where the disposal location or waste materials have not been identified in the waste management plan, details shall be provided to the Certifying Authority as part of the waste management documentation accompanying the Construction Certificate application.

All receipts and supporting documentation must be retained in order to verify lawful disposal of materials and are to be made available to Penrith City Council on request.

Construction

11 **H001 - Stamped plans and erection of site notice**

Stamped plans, specifications, a copy of the development consent, the Construction Certificate and any other Certificates to be relied upon shall be available on site at all times during construction.

The following details are to be displayed in a maximum of 2 signs to be erected on the site:

- the name of the Principal Certifying Authority, their address and telephone number,
- the name of the person in charge of the work site and telephone number at which that person may be contacted during work hours,
- that unauthorised entry to the work site is prohibited,
- the designated waste storage area must be covered when the site is unattended, and
- all sediment and erosion control measures shall be fully maintained until completion of the construction phase.

Signage but no more than 2 signs stating the above details is to be erected:

- at the commencement of, and for the full length of the, construction works onsite, and
- in a prominent position on the work site and in a manner that can be easily read by pedestrian traffic.

All construction signage is to be removed when the Occupation Certificate has been issued for the development.

12 H002 - All forms of construction

Prior to the commencement of construction works: *Nominate*

(a) Toilet facilities at or in the vicinity of the work site shall be provided at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:

- a standard flushing toilet connected to a public sewer, or
- if that is not practicable, an accredited sewage management facility approved by the council, or
- alternatively, any other sewage management facility approved by council.

(b) All excavations and backfilling associated with the erection or demolition of a building must be executed safely and in accordance with the appropriate professional standards. All excavations associated with the erection or demolition of a building must be properly guarded and protected to prevent them from being dangerous to life or property.

(c) If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation to be made:

- must preserve and protect the building from damage, and
- if necessary, must underpin and support the building in an approved manner, and
- must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished. The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this condition, whether carried out on the allotment of land being excavated or on the adjoining allotment of land, (includes a public road and any other public place).

Engineering

13 K026 - Stabilised access

All land required for vehicular access within the site is to be stabilised.

14 K041 - Infrastructure Bond

An Infrastructure Restoration Bond is to be lodged with Penrith City Council for development involving works around Penrith City Council's Public Infrastructure Assets. The bond is to be lodged with Penrith City Council prior to commencement of any works on site or prior to the issue of any Construction Certificate, whichever occurs first. The bond and applicable fees are in accordance with Council's adopted Fees and Charges.

An application form together with an information sheet and conditions are available on Council's website.

Contact Penrith City Council's City Works Department on (02) 4732 7777 or visit Penrith City Council's website for more information.

Landscaping

15 L008 - Tree Preservation Order

No trees are to be removed, ringbarked, cut, topped, or lopped or wilfully destroyed without the prior consent or Penrith City Council and in accordance with Council's Tree Preservation Order and Policy.

Appendix - Development Control Plan Compliance

Demolition Checklist	Compliance	Additional comments
Demolition of: <ul style="list-style-type: none"> · Dwelling · Garage · Carport · Driveway · Shed · Awnings · Swimming pool · Outbuilding · Other structure (specify) 	 X X X	Demolition and removal of a garage, carport and external toilet.
Waste Management Plan	X	
Sediment & Erosion barrier	X	Condition to apply
Waste covered and contained	X	Condition to apply
Waste removal method	X	Bingo Eastern Creek by licensed contractor DD Building Group
Dust containment	X	
Asbestos removal/disposal	X	Bingo Eastern Creek by licensed contractor DD Building Group (Non Friable Asbestos Removal Licence provided)
Waste disposal centre	X	Bingo Eastern Creek
Cost of works	X	\$2,760.00
Contractor/Trade company	X	Licensed Contractor: DD Building Group