

GETEX AIRBORNE ASBESTOS MONITORING REPORT

Report Number: 11538. 6 .AMON

Date of Report: 6/04/2021

Date of Analysis: 6/04/2021

Client Company: Penrith City Council

Site: 11a Canopus Close

PO Box 60

Erskine Park NSW 2759

PENRITH NSW 2751

GETEX PTY LTD

ABN 99 116 287 471

Unit 2, Building B, 64 Talavera Road
MACQUARIE PARK NSW 2113

Ph: (02) 9889 2488
Fax: (02) 9889 2499
Email: help@getex.com.au
Web: www.getex.com.au



"Urgent Solutions To Urgent Problems"

24 Hours 7 Days

Removal Contractor: N/A

Test Method: In accordance with NOHSC Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres 2nd Edition [NOHSC: 3003 (2005)]

Sample Number	Sample Date	Sample Type	Monitor Location	Air Flow On (L/min)	Air Flow Off (L/min)	Air Flow Average (L/min)	Time On	Time Off	Total Time (min)	Field Count	Fibre Count	Conc. (fibres/mL)	Remarks
Blank	31/03/2021	7	N/A			N/A		N/A		100	0	N/A	
DRW 33	31/03/2021	1	On southern temporary fence - 8m from the eastern end	2.95	2.95	2.95	7:03	10:17	194	100	1	< 0.01	
DRW 34	31/03/2021	1	On southern temporary fence - 6m from the western end	2.95	2.95	2.95	7:07	10:19	192	100	0	< 0.01	
DRW 35	31/03/2021	1	On western temporary fence - 6m from the southern end	2.95	2.95	2.95	7:11	10:21	190	100	0	< 0.01	
DRW 36	31/03/2021	1	On western temporary fence - 6m from the northern end	2.95	2.95	2.95	7:14	10:23	189	100	0	< 0.01	Sample rejected, flow fault
DRW 37	31/03/2021	1	On northern temporary fence - 6m from the western end	2.95	2.95	2.95	7:17	10:24	187	100	1	< 0.01	

Sample Types: 1 - Background 2 - Enclosure Set Up 3 - Removal/Treatment 4 - Enclosure Pull Down 5 - Clearance Monitoring 6 - Exposure Monitoring
7 - Blank 8 - Bag Out / Waste Removal

Note on Sampling:

The above results only relate to the samples tested. This report confirms preliminary report _____ N/A

Sampled by: Chris Chen

Counter Name: Geronimo Abrot

Counter Signature: [Redacted]

Approved Signatory Name: Justin Thompson-Laing

Approved Signatory: [Redacted]

NATA Accredited Laboratory
Number 15404:

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Accredited for compliance with ISO/IEC 17025 - Testing



This report shall not be reproduced except in full.

GETEX AIRBORNE ASBESTOS MONITORING REPORT

Report Number: 11538 . 6 .AMON

Date of Report: 6/04/2021

Date of Analysis: 6/04/2021

Client Company: Penrith City Council
PO Box 60
PENRITH NSW 2751

Site: 11a Canopus Close
Erskine Park NSW 2759



GETEX PTY LTD

ABN 99 116 287 471

Unit 2, Building B, 64 Talavera Road
MACQUARIE PARK NSW 2113

Ph: (02) 9889 2488
Fax: (02) 9889 2499
Email: help@getex.com.au
Web: www.getex.com.au

Removal Contractor: N/A

Test Method: In accordance with NOHSC Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres 2nd Edition [NOHSC: 3003 (2005)]

"Urgent Solutions To Urgent Problems"
24 Hours 7 Days

Sample Number	Sample Date	Sample Type	Monitor Location	Air Flow On (L/min)	Air Flow Off (L/min)	Air Flow Average (L/min)	Time On	Time Off	Total Time (min)	Field Count	Fibre Count	Conc. (fibres/mL)	Remarks
Blank	31/03/2021	7	N/A			N/A			N/A	100	0	N/A	
DRW 38	31/03/2021	1	On northern temporary fence - 6m from the eastern end	2.95	2.95	2.95	7:21	10:26	185	100	0	< 0.01	
DRW 39	31/03/2021	1	On eastern boundary fence - 6m from the northern end	2.95	2.95	2.95	7:24	10:28	184	100	0	< 0.01	
DRW 40	31/03/2021	1	On eastern boundary fence - 8m from the southern end	2.95	2.95	2.95	7:27	10:29	182	100	0	< 0.01	Sample rejected, flow fault

Sample Types: 1 - Background 2 - Enclosure Set Up 3 - Removal/Treatment 4 - Enclosure Pull Down 5 - Clearance Monitoring 6 - Exposure Monitoring
7 - Blank 8 - Bag Out / Waste Removal

Note on Sampling:

The above results only relate to the samples tested. This report confirms preliminary report _____ N/A

Sampled by: Chris Chen

Counter Name: Geronimo Abrot

Counter Signature: [Redacted]

Approved Signatory Name: Justin Thompson-Laing

Approved Signatory: [Redacted]

NATA Accredited Laboratory
Number 15404:

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Accredited for compliance with ISO/IEC 17025 - Testing



This report shall not be reproduced except in full.