

Nationwide House Energy Rating Scheme* — Multiple-dwelling summary




Certificate number: **0002292530**

Certificate Date: **15 Dec 2017**

★ Average Star rating: **5.7**

Assessor details

Accreditation number: **20920**
Name: **Terry Chapman**
Organisation: **Chapman Environmental services**
Email: **terry@basixcertificates.com.au**
Phone: **0414 265 292**
Declaration of interest: **None**
Software: **BERS Pro v4.3.0.2b (3.13)**
AAO: **ABSA**



Dwelling details

Street: **18 SYDNEY STREET**
Suburb: **ST MARYS**
State: **NSW**
Postcode: **2760**

Scan to access this certificate online and confirm this is valid.



Summary of all dwellings

Certificate Details

Certificate number	Dwelling/Unit number	Heating load	Cooling load	Total load	Star Rating
0002286581-01	1	46.5	55.9	102.4	5.4
0002286607-01	2	52.6	40.9	93.5	5.8
0002286623-01	3	44.0	47.9	91.8	5.8
0002286599-01	4	38.5	49.7	88.1	5.9
0002286615-01	5	40.1	55.3	95.4	5.7
0002286631-01	6	51.9	50.6	102.5	5.4

* Nationwide House Energy Rating Scheme (NatHERS) is an initiative of the Australian, state and territory governments.

For more details see www.nathers.gov.au