



FOOTING OF STRUCTURE TO BE OUTSIDE THE ZONE OF INFLUENCE OF WATER MAIN.

EXISTING 150mm DICL IN EXISTING FOOTPATH TO REMAIN.

TREES AND STRUCTURE TO BE CO-ORDINATED WITH SYDNEY WATER SEWER. CONFIRM WITH WSC.

150mm POTABLE WATER MAIN TO REMAIN.

CONNECT INTO EXISTING 150mm POTABLE WATER MAIN IN ACCORDANCE WITH SYDNEY WATER REQUIREMENTS.

NEW WATER METER AND RPZD ASSEMBLY TO BE LOCATED IN A VANDAL PROOF ENCLOSURE.

EXISTING GAS MAIN TO BE DEMOLISHED AND RELOCATED.

SEWER TO BE RELOCATED OR CONCRETE ENCASED AS PER COUNCIL REQUEST. DESIGN TO BE UNDERTAKEN BY WSC.

EXISTING MANHOLES TO REMAIN.

PROPOSED RELOCATION OF GAS MAIN. DESIGN TO BE UNDERTAKEN BY JEMENA OR HYDRAULIC CONSULTANT, TBC.

SD 150
FLOW

SD 150

W 150

Date:	15.01.2021	Project No:	SY192968
Project:	CITY PARK PENRITH		
Title:	HYDRAULIC SERVICES SEWER OPTIONS		
Drawing No:	HSK101	Revision:	4
Drawn:	SS	Scale:	1:200 @ A1

