

PENRITH CITY COUNCIL

FAST TRACK ASSESSMENT REPORT

Application number:	DA15/0582
Proposed development:	Demolition of existing Dwelling
Property address:	1 - 23 Lenore Drive, ERSKINE PARK NSW 2759
Property description:	Lot 1 DP 1071114
Date received:	16 June 2015
Assessing officer	Phillip Doy
Zoning:	SEPP - (WSEA) 2009 - ZONE IN1
Class of building:	N/A
Recommendations:	Approve

Executive Summary

Council is in receipt of a development application for the subject development on the subject site and the proposal is a permissible land use with Council consent.

Site & Surrounds

The subject site is situated on the south west corner of Lenore Drive Erskine Park. It is 1.122Ha in area, is orientated in a western direction and has a gentle slope towards the middle of the land.

An inspection of the site was undertaken on 30 June 2015 and the site is currently occupied by a dwelling.

The surrounding area is characterised by residential and industrial development.

Proposal

The proposed development involves:

- Demolition of an existing two-storey dwelling.

Plans that apply

- Penrith Local Environmental Plan No.258 - Consent for dwelling houses and other development
- Sydney Regional Environmental Plan No.20 - Hawkesbury Nepean River

Planning Assessment

- **Section 79C - Evaluation**

The development has been assessed in accordance with the matters for consideration under Section 79C of the Environmental Planning and Assessment Act 1979.

Section 79C(1)(a)(i) The provisions of any environmental planning instrument

Penrith Local Environmental Plan No.258 - Consent for dwelling houses and other development

Provision	Compliance
All Clauses - Consent for dwelling houses and other development	Complies

Sydney Regional Environmental Plan No.20 - Hawkesbury Nepean River

An assessment has been undertaken of the application against relevant criteria with Sydney Regional Environmental Plan No 20—Hawkesbury-Nepean River (No 2—1997) and the application is satisfactory subject to recommended conditions of consent.

Section 79C(1)(a)(iii) The provisions of any development control plan

Development Control Plan 2010

Provision	Compliance
Part B - DCP Principles	Complies
Part C 1 - Site planning and design principles	Complies
Part C2 - Vegetation management	Complies
Part C3 - Water management	Complies
Part C4 - Land management	Complies
Part C5 - Waste management	Complies
Part C6 - Landscape design	N/A
Part C7 - Culture and heritage	N/A
Part C8 - Public domain	N/A
Part C9 - Advertising and signage	N/A
Part C10 - Transport, access and parking	N/A
Part C11 - Subdivision	N/A
Part C12 - Noise and vibration	N/A
Part C13 - Infrastructure and services	N/A
Part D4 - Industrial development	Complies

Section 79C(1)(a)(iv) The provisions of the regulations

The regulations do not present any further restrictions or requirements for the proposed development on the subject site.

Section 79C(1)(b) The likely impacts of the development

Likely impacts of the proposed development as identified throughout the assessment process include:

Impact raised in submissions

N/A

Impacts raised in referral comments

N/A

Other impacts identified in assessment

(i) Context and Setting (environmental impacts and impacts on built environment)

The proposal is consistent with the bulk, scale, colour and design of other development in the locality.

The development will have only minor impact on the amenity of the area and the streetscape.

The development is compatible with the surrounding and adjacent land uses.

It is considered the development will have minimal impact on the amenity of the area in terms of Sunlight Access (overshadowing) / visual and acoustic privacy / views or vistas

The development will have minimal impacts on natural environment.

(ii) Access and transport

The development will have minimal impact on the local road system.

The existing access arrangements and car parking on site will be adequate for the development.

(iii) Heritage

The property is not subject to any Heritage Order or identified as a heritage item under a planning instrument.

(iv) Soil

The proposed development will have minimal impact on soil erosion and sedimentation:

Adequate sedimentation and erosion controls are proposed as part of the development.

(v) Natural and Technological Hazards

The development is not subject to flooding, subsidence or slip.

(vi) Site Design

The proposed development is sensitive to environmental conditions and site attributes:

The proposed development safeguards the health and safety of the occupants:

Section 79C(1)(c)The suitability of the site for the development

The site is suitable for the following reasons:

- The site is zoned to permit the proposed use
- The use is compatible with surrounding/adjoining land uses
- The grade of the site is suitable for the design proposed
- The site is able to drain to Council's satisfaction

Section 79C 1(d) Any submission made in accordance with this Act or the regulations

In accordance with the Act and Regulations, consideration has been given to any necessary referrals and any submissions made.

Community consultation

In accordance with Clause 4.4 of Appendix F4 of Penrith Development Control Plan 2014, the proposed development did not have to be notified to nearby and adjoining residents.

Section 79C(1)(e)The public interest

The proposed development will not generate any significant issues of public interest.

Conclusion

The site is suitable for the proposed development, the proposal is in the public interest, and there is unlikely to be negative impacts arising from the proposed development.

Therefore, the application is worthy of support, subject to recommended conditions.

Recommendation

That DA15/0582 for the demolition of an existing two-storey dwelling at Lot 1 DP 1071114, 1-23 Lenore Drive Erskine Park, be approved subject to the attached conditions (Development Assessment Report Part B).

CONDITIONS

General

1 [A02F - Approved Fast Light Das](#)

The development must be implemented substantially in accordance with the stamped-approved plans issued by Penrith City Council, the application form and any supporting information received with the application, except as may be amended in red on the attached plans and by the following conditions.

Demolition

2 [B001 - Demolition of existing structures](#)

The existing two storey dwelling on Lot 1 DP 1071114, 1-23 Lenore Lane Erskine Park is to be demolished as part of the approved work.

3 [B002 - AS FOR DEMOLITION AND DISPOSAL TO APPROVED LANDFILL SITE](#)

All demolition works are to be conducted in accordance with the provisions of AS 2601-1991 "The Demolition of Structures". **Prior to demolition**, all services shall be suitably disconnected and capped off or sealed to the satisfaction of the relevant service authority requirements.

All demolition and excavated material shall be disposed of at a Council approved site or waste facility. Details of the proposed disposal location(s) of all excavated material from the development site shall be provided to the Principal Certifying Authority **prior to commencement of demolition**.

4 [B003 - ASBESTOS \(amended from Council adopted version\)](#)

Prior to commencement of demolition works on site, a portaloo with appropriate washing facilities shall be located on the site and the Principal Certifying Authority is to be satisfied that:

- Measures are in place so as to comply with the WorkCover Authority's "Short Guide to Working with Asbestos Cement" and
- The person employed to undertake the works is a licensed asbestos removal contractor and is holder of a current WorkCover Asbestos Licence.

Any demolition works involving the removal of all asbestos shall only be carried out by a licensed asbestos removal contractor who has a current WorkCover Asbestos Licence.

All asbestos laden waste, including asbestos cement flat and corrugated sheeting must be disposed of at a tipping facility licensed by the Environmental Protection Authority to receive asbestos wastes.

5 [B004 - Dust](#)

Dust suppression techniques are to be employed during demolition to reduce any potential nuisances to surrounding properties.

6 [B005 - Mud/Soil](#)

Mud and soil from vehicular movements to and from the site must not be deposited on the road.

7 [B006 - Hours of work](#)

Demolition works will be restricted to the following hours in accordance with the NSW Environment Protection Authority Noise Control Guidelines:

- Mondays to Fridays, 7am to 6pm
- Saturdays, 7am to 1pm (if inaudible on neighbouring residential premises), otherwise 8am to 1pm
- No demolition work is permitted on Sundays and Public Holidays.

In the event that the demolition relates to works inside the building and do not involve external walls or the roof, and do not involve the use of equipment that emits noise then the demolition works are not restricted to the hours stated above.

The provisions of the Protection of the Environment Operations Act, 1997 in regulating offensive noise also apply to all construction works.

Environmental Matters

8 **D001 - Implement approved sediment& erosion control measures**

Erosion and sediment control measures shall be installed **prior to the commencement of works on site** including approved clearing of site vegetation. The erosion and sediment control measures are to be maintained in accordance with the approved erosion and sediment control plan(s) for the development and the Department of Housing's "Managing Urban Stormwater: Soils and Construction" 2004.

(Note: To obtain a copy of the publication, you should contact Landcom on (02) 98418600).

The approved sediment and erosion control measures are to be installed **prior to and maintained throughout the construction phase of the development until the land, that was subject to the works, have been stabilised and grass cover established.** These measures shall ensure that mud and soil from vehicular movements to and from the site does not occur during the construction of the development.

9 **D009 - Covering of waste storage area**

All waste materials stored on-site are to be contained within a designated area such as a waste bay or bin to ensure that no waste materials are allowed to enter the stormwater system or neighbouring properties. The designated waste storage areas shall provide at least two waste bays / bins so as to allow for the separation of wastes, and are to be fully enclosed when the site is unattended.

10 **D010 – Appropriate disposal of excavated or other waste**

All excavated material and other wastes generated as a result of the development are to be re-used, recycled or disposed of in accordance with the approved waste management plan.

Waste materials not specified in the approved waste management plan are to be disposed of at a lawful waste management facility. Where the disposal location or waste materials have not been identified in the waste management plan, details shall be provided to the Certifying Authority as part of the waste management documentation accompanying the Construction Certificate application.

All receipts and supporting documentation must be retained in order to verify lawful disposal of materials and are to be made available to Penrith City Council on request.

Construction

11 **H001 - Stamped plans and erection of site notice**

Stamped plans, specifications, a copy of the development consent, the Construction Certificate and any other Certificates to be relied upon shall be available on site at all times during construction.

The following details are to be displayed in a maximum of 2 signs to be erected on the site:

- the name of the Principal Certifying Authority, their address and telephone number,
- the name of the person in charge of the work site and telephone number at which that person may be contacted during work hours,
- that unauthorised entry to the work site is prohibited,
- the designated waste storage area must be covered when the site is unattended, and
- all sediment and erosion control measures shall be fully maintained until completion of the construction phase.

Signage but no more than 2 signs stating the above details is to be erected:

- at the commencement of, and for the full length of the, construction works onsite, and
- in a prominent position on the work site and in a manner that can be easily read by pedestrian traffic.

All construction signage is to be removed when the Occupation Certificate has been issued for the development.

12 H002 - All forms of construction

Prior to the commencement of construction works:

(a) Toilet facilities at or in the vicinity of the work site shall be provided at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:

- a standard flushing toilet connected to a public sewer, or
- if that is not practicable, an accredited sewage management facility approved by the council, or
- alternatively, any other sewage management facility approved by council.

(b) All excavations and backfilling associated with the erection or demolition of a building must be executed safely and in accordance with the appropriate professional standards. All excavations associated with the erection or demolition of a building must be properly guarded and protected to prevent them from being dangerous to life or property.

(c) If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation to be made:

- must preserve and protect the building from damage, and
- if necessary, must underpin and support the building in an approved manner, and
- must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished. The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this condition, whether carried out on the allotment of land being excavated or on the adjoining allotment of land, (includes a public road and any other public place).

Engineering

13 K026 - Stabilised access

All land required for vehicular access within the site is to be stabilised.

14 K041

An Infrastructure Restoration Bond is to be lodged with Penrith City Council for development involving works around Council's Public Infrastructure Assets. The bond is to be lodged with Council prior to the issue of a Construction Certificate. The bond is based upon the estimated value of the works with a bond of \$500 for residential payable for the subject development.

The bond is refundable once a final inspection has been carried out by Council's Works Department and the works have been completed to Council's satisfaction. The bond may be used to repair or reinstate any damage that occurs to Council's Public Infrastructure Assets as a result of the development works.

Contact Council's City Works Department on 4732 7777 or visit website to obtain the form and request for final inspection.

Landscaping

15 L008 - Tree Preservation Order

No trees are to be removed, ringbarked, cut, topped, or lopped or wilfully destroyed without the prior consent or Penrith City Council and in accordance with Council's Tree Preservation Order and Policy.